

SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER

Summary Page

PUBLIC WATER
SYSTEM NAME: City of Corsicana

PLANT NAME
OR NUMBER: Navarro Mills

I certify that I am familiar with the information contained in this report and that,
to the best of my knowledge, the information is true, complete, and accurate.

PWS ID No.: 1750002
Report for
the Month of: July 2012

Operator's Signature: _____
Certificate No. & Grade: WO0004220, A Date: August 1, 2012

TREATMENT PLANT PERFORMANCE

Total number of turbidity readings:	<u>186</u>	Number of 4-hour periods when plant was off-line:	<u>0</u>
Number of readings above 0.10 NTU:	<u>72</u>	Number of 4-hour periods when plant was on-line but turbidity data was not collected:	<u>0</u>
Number of readings above 0.3 NTU:	<u>0</u>	Number of days when plant was on-line but individual filter turbidity data was not collected:	<u>0</u>
Number of readings above 0.5 NTU:	<u>0</u>	Number of days with readings above 1.0 NTU:	<u>0</u> (2)
Number of readings above 1.0 NTU:	<u>0</u>	Number of days with readings above 5.0 NTU:	<u>0</u> (3)
Maximum allowable turbidity level:	<u>0.3</u>		
Percentage of readings above this limit:	<u>0.0</u> % (1)		
Statistical Summary		Maximum turbidity reading:	<u>0.18</u> NTU
		Minimum turbidity reading:	<u>0.06</u> NTU
		CFE 95 th percentile value:	<u>0.15</u> NTU
		Average turbidity value:	<u>0.10</u> NTU
		Standard deviation:	<u>0.027</u> NTU
		IFE 95 th percentile:	<u>0.285</u> NTU
Number of days with a low CT for no more than 4.0 consecutive hours:	<u>0</u>	Average log inactivation for Giardia:	<u>NA</u>
Number of days with a low CT for more than 4.0 consecutive hours:	<u>0</u> (4)	Average log inactivation for viruses:	<u>NA</u>
		Number of days when profiling data was not collected:	<u>31</u>
		Number of days when CT data was not collected:	<u>31</u>
Minimum disinfectant residual required leaving the plant:		<u>0.5</u> mg/L, measured as Total Chlorine	
Number of days with a low residual for no more than 4.0 consecutive hours:	<u>0</u>		
Number of days with a low residual for more than 4.0 consecutive hours:	<u>0</u> (5)	Number of days when disinfectant residual leaving the plant was not properly monitored:	<u>0</u>

DISTRIBUTION SYSTEM

Minimum disinfectant residual required in distribution system:	<u>0.5</u> mg/L, measured as Total Chlorine		
Total number of readings this month:	<u>61</u>	(at least 31 required) (8)	
Average disinfectant residual value:	<u>1.93</u>	Percentage of readings with a low residual this month:	<u>0.0</u> % (6A)
Number of readings with a low residual:	<u>0</u>		
Number of readings with no detectable residual:	<u>0</u>	Percentage of readings with a low residual last month:	<u>0.0</u> % (6B)

ADDITIONAL REPORTS & WORKSHEETS

The Page 1 Addendum (Public Notices) is required because there was at least one treatment technique or monitoring/reporting violation reported.

Additional report(s) for individual filter monitoring required: NONE Filter Profile Filter Assessment CPE

Additional report(s) for individual filter monitoring submitted: NONE Filter Profile (9) Filter Assessment (10) CPE (11)

No additional IFE Reports are required this month.

SURFACE WATER MONTHLY OPERATING REPORT
TEXAS COMMISSION ON ENVIRONMENTAL QUALITY
WATER SUPPLY DIVISION/PUBLIC DRINKING WATER SECTION (MC-155)
P.O. BOX 13087, AUSTIN, TEXAS 78711-3087

SURFACE WATER MONTHLY OPERATING REPORT
 FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES
 OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER (cont.)
Turbidity Data Page

PUBLIC WATER SYSTEM NAME: City of Corsicana

PLANT NAME OR NUMBER: Navarro Mills

PWS ID No.: 1750002

Connections: 10,845

Month: July Year: 2012

Population: 23,770

PERFORMANCE DATA																		
Date	Raw Water Pumpage (MGD)	Treated Water Pumpage (MGD)	RAW WATER ANALYSES		SETTLED WATER TURBIDITY (Mandatory Data)						FINISHED WATER QUALITY							
			NTU	Alk.	Basin No.						Turbidity						Lowest Residual	Time=
					1	2	3	4	5	6	NTU1	NTU2	NTU3	NTU4	NTU5	NTU6		
1	9.560	7.087	12	101	0.4	0.5	0.4	0.4	0.4	0.4	0.09	0.09	0.07	0.07	0.07	0.08	2.7	
2	5.850	6.427	16	98	0.4	0.3	0.4	0.3	0.4	0.4	0.09	0.09	0.10	0.09	0.09	0.08	2.7	
3	9.130	7.864	14	97	0.4	0.5	0.5	0.5	0.4	0.5	0.08	0.08	0.09	0.09	0.10	0.11	2.5	
4	9.080	8.675	12	96	0.5	0.4	0.5	0.6	0.6	0.6	0.15	0.15	0.14	0.14	0.15	0.15	3.2	
5	7.330	6.471	13	98	0.5	0.5	0.5	0.6	0.6	0.6	0.14	0.14	0.16	0.18	0.16	0.15	3.0	
6	7.520	7.785	15	99	0.5	0.5	0.6	0.5	0.5	0.6	0.14	0.13	0.14	0.15	0.15	0.14	2.9	
7	9.280	7.017	17	104	0.6	0.6	0.6	0.7	0.6	0.6	0.18	0.18	0.16	0.16	0.15	0.15	2.8	
8	5.350	4.912	18	104	0.4	0.4	0.4	0.5	0.4	0.4	0.14	0.14	0.14	0.11	0.12	0.13	2.4	
9	4.780	6.041	17	103	0.4	0.3	0.4	0.4	0.4	0.3	0.10	0.10	0.08	0.07	0.07	0.06	2.3	
10	9.510	6.661	19	100	0.5	0.5	0.5	0.5	0.5	0.4	0.08	0.11	0.10	0.10	0.10	0.11	2.4	
11	4.890	5.341	18	101	0.5	0.5	0.4	0.4	0.5	0.4	0.11	0.13	0.12	0.12	0.11	0.11	2.3	
12	6.590	5.193	20	102	0.4	0.4	0.4	0.5	0.4	0.4	0.09	0.11	0.09	0.10	0.09	0.09	2.4	
13	6.650	5.731	24	102	0.3	0.4	0.4	0.4	0.4	0.3	0.08	0.08	0.08	0.06	0.07	0.06	2.3	
14	9.440	7.370	27	104	0.5	0.5	0.6	0.6	0.5	0.5	0.06	0.07	0.08	0.08	0.08	0.07	2.7	
15	4.610	5.480	23	103	0.6	0.7	0.7	0.7	0.7	0.6	0.09	0.10	0.09	0.09	0.10	0.10	2.7	
16	4.660	4.725	25	100	0.9	0.8	1.0	0.7	0.7	0.6	0.11	0.11	0.12	0.13	0.14	0.13	2.4	
17	6.370	5.908	18	103	0.8	0.7	0.8	0.8	0.7	0.8	0.16	0.16	0.14	0.14	0.13	0.12	2.7	
18	9.180	7.686	14	102	0.5	0.5	0.5	0.5	0.6	0.5	0.12	0.13	0.11	0.09	0.09	0.08	3.0	
19	9.000	7.596	12	100	0.4	0.4	0.4	0.4	0.4	0.4	0.08	0.08	0.08	0.09	0.08	0.10	2.9	
20	8.950	7.806	13	99	0.7	0.4	0.4	0.3	0.4	0.4	0.08	0.08	0.09	0.11	0.11	0.08	2.9	
21	5.750	5.943	20	99	0.4	0.3	0.4	0.4	0.4	0.4	0.09	0.10	0.09	0.09	0.09	0.10	2.8	
22	6.310	7.194	18	99	0.3	0.3	0.3	0.4	0.3	0.3	0.08	0.08	0.08	0.06	0.06	0.06	2.3	
23	8.950	7.795	15	97	0.4	0.4	0.4	0.4	0.4	0.4	0.07	0.08	0.07	0.07	0.06	0.06	2.8	
24	8.940	7.704	15	97	0.4	0.4	0.5	0.5	0.4	0.4	0.10	0.10	0.07	0.08	0.08	0.11	2.7	
25	8.940	8.776	18	99	0.5	0.5	0.5	0.5	0.6	0.5	0.09	0.09	0.10	0.10	0.10	0.10	2.7	
26	7.300	6.652	19	100	0.4	0.5	0.5	0.5	0.4	0.5	0.09	0.10	0.11	0.12	0.11	0.11	2.7	
27	7.000	7.709	22	99	0.4	0.4	0.5	0.5	0.4	0.5	0.09	0.09	0.11	0.11	0.11	0.11	2.6	
28	9.070	8.493	27	102	0.5	0.5	0.6	0.6	0.6	0.6	0.11	0.12	0.11	0.12	0.11	0.12	2.9	
29	9.020	8.139	28	97	0.5	0.5	0.6	0.5	0.5	0.5	0.10	0.10	0.10	0.09	0.08	0.07	2.9	
30	8.950	8.913	22	96	0.4	0.5	0.6	0.5	0.5	0.5	0.08	0.09	0.09	0.08	0.07	0.07	2.9	
31	8.990	8.036	24	94	0.5	0.5	0.6	0.6	0.5	0.5	0.08	0.10	0.08	0.08	0.08	0.09	3.0	
Total	236.950	217.130																
Avg	7.644	7.004																
Max	9.560	8.913																
Min	4.610	4.725																

NOTE: ONLY use the "Time" column to show the length of time that the disinfectant residual entering the distribution system fell below the acceptable level.

SUBMITTED BY: _____ Certificate No. and Grade: WO0004220, A Date: August 1, 2012

SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER (cont.)

Filter Data Page

PUBLIC WATER
SYSTEM NAME: City of Corsicana

PWS ID No.: 1750002

PLANT NAME
OR NUMBER: Navarro Mills

Month: July Year: 2012

PERFORMANCE DATA																				
INDIVIDUAL FILTER TURBIDITY																				
Date	Filter No. 1		Filter No. 2		Filter No. 3		Filter No. 4		Filter No. 5		Filter No. 6		Filter No. 7		Filter No. 8		Filter No. 9		Filter No. 10	
	Max	4 Hrs	Max	4 Hrs																
1	0.07	x	0.19	0.11	0.14	x	0.13	x	0.12	x	x	x								
2	x	x	0.16	x	0.16	x	0.15	x	0.13	x	x	x								
3	0.19	0.16	0.16	x	0.24	x	0.13	x	0.12	x	0.18	0.15								
4	0.20	x	0.16	x	0.24	x	x	x	x	x	0.19	x								
5	0.20	0.16	x	x	0.24	x	0.31	0.30	x	x	0.19	x								
6	x	x	0.30	0.30	0.21	x	0.25	x	0.28	0.23	0.17	x								
7	0.23	0.18	0.26	x	x	x	0.22	x	0.23	x	0.15	x								
8	0.20	x	0.18	x	x	x	0.17	x	0.17	x	x	x								
9	0.12	x	0.10	x	x	x	0.09	x	0.09	x	x	x								
10	0.15	x	0.14	x	0.20	0.16	0.20	0.19	0.13	x	0.19	0.14								
11	0.11	x	x	x	0.14	x	0.18	x	x	x	0.13	x								
12	x	x	0.19	0.12	0.11	x	0.13	x	x	x	0.09	x								
13	x	x	0.08	x	x	x	0.07	x	0.33	0.09	0.06	x								
14	x	x	0.11	x	0.16	0.12	0.10	x	0.12	x	0.06	x								
15	0.24	0.15	0.22	0.17	0.15	x	0.10	x	0.12	x	x	x								
16	0.27	x	0.21	x	0.32	0.27	0.29	0.23	0.26	x	0.25	0.17								
17	0.37	0.21	0.28	0.10	0.30	x	0.25	x	0.27	x	0.25	x								
18	0.18	x	0.17	x	0.14	x	x	x	0.14	x	0.12	x								
19	0.11	x	0.10	x	0.10	x	0.22	0.16	0.25	x	0.08	x								
20	0.10	x	0.10	x	0.14	x	0.16	x	0.34	x	0.17	0.14								
21	0.09	x	x	x	0.14	x	0.13	x	0.13	x	0.11	x								
22	x	x	x	x	0.10	x	0.09	x	0.10	x	0.08	x								
23	0.16	0.12	x	x	0.10	x	0.09	x	0.09	x	0.08	x								
24	0.13	x	0.23	0.12	0.21	0.15	0.09	x	0.20	x	0.08	x								
25	0.14	x	0.15	x	0.16	x	x	x	0.15	x	0.16	0.14								
26	0.14	x	0.14	x	0.16	x	x	x	x	x	0.15	x								
27	x	x	0.11	x	0.14	x	0.25	0.18	0.23	0.18	0.12	x								
28	0.22	0.19	x	x	0.13	x	0.19	x	0.18	x	0.12	x								
29	0.15	x	0.18	0.15	x	x	0.15	x	0.14	x	0.10	x								
30	0.11	x	0.14	x	x	x	0.11	x	0.10	x	x	x								
31	0.11	x	0.13	x	0.23	0.14	0.11	x	0.10	x	0.20	0.14								

SUMMARY & COMPLIANCE ACTIONS	Criteria	Filter No.										Plant									
		1	2	3	4	5	6	7	8	9	10										
	Number of days with event(s) above 0.5 NTU at 4.0 hrs this month	0	0	0	0	0	0	0	0	0	0										
	Number of days with event(s) above 1.0 NTU this month	0	0	0	0	0	0	0	0	0	0										
	Number of days with event(s) above 1.0 NTU last month	0	0	0	0	0	0	0	0	0	0										
	Number of days with event(s) above 1.0 NTU two months ago	0	0	0	0	0	0	0	0	0	0										
	Total number of days with event(s) above 1.0 NTU in three months	0	0	0	0	0	0	0	0	0	0										
	Number of days with event(s) above 2.0 NTU this month											0									
	Number of days with event(s) above 2.0 NTU last month											0									
	Does the filter/plant have an approved Corrective Action Plan?	N	N	N	N	N	N	N	N	N	N										N
	Is the plant required to submit a Filter Profile Report?	N	N	N	N	N	N	N	N	N	N										
	Is the plant required to submit a Filter Assessment Report?	N	N	N	N	N	N	N	N	N	N										
	Is the plant required to submit a Request for Compliance CPE?											N									

SUBMITTED BY: _____ Certificate No. and Grade: WO0004220, A Date: August 1, 2012

SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER (cont.)
Disinfection Data Page

PUBLIC WATER SYSTEM NAME: City of Corsicana
PWS ID No.: 1750002

PLANT NAME OR NUMBER: Navarro Mills
Month: July Year: 2012

DISINFECTION PROCESS PARAMETERS							
APPROVED CT STUDY PARAMETERS					PERFORMANCE STANDARDS		
Parameters	Disinfection Zones					Log Inactivations	
	D1	D2	D3	D4	D5	Giardia lamblia Cysts	Viruses
Flow Rate (MGD)	20.250	20.250	20.250			0.5	2.0
T ₁₀ (minutes)	109.1	13.0	100.0				

PERFORMANCE DATA									
DISINFECTION PROCESS DATA									
Date	Disinfectant	C (mg/L)	Flow (MGD)	Temp (°C)	pH	Giardia Log	Virus Log	Inact. Ratio	Time=
1	NA D1								
	FCL D2	0.9	9.700	30.0	7.0				
	CLA D3	3.0	9.700	30.0	7.6				
	D4								
	D5								
2	NA D1								
	FCL D2	0.9	9.600	29.0	7.0				
	CLA D3	2.7	9.600	29.0	7.5				
	D4								
	D5								
3	NA D1								
	FCL D2	0.3	9.200	29.0	6.9				
	CLA D3	2.8	9.200	28.0	7.6				
	D4								
	D5								
4	NA D1								
	FCL D2	0.5	9.200	29.0	6.9				
	CLA D3	3.3	9.200	29.0	7.6				
	D4								
	D5								
5	NA D1								
	FCL D2	0.6	9.200	29.0	6.8				
	CLA D3	3.2	9.200	29.0	7.5				
	D4								
	D5								
6	NA D1								
	FCL D2	0.5	9.400	29.0	7.6				
	CLA D3	3.1	9.400	29.0	7.8				
	D4								
	D5								
7	NA D1								
	FCL D2	0.2	9.400	30.0	6.9				
	CLA D3	3.0	9.400	30.0	7.6				
	D4								
	D5								
8	NA D1								
	FCL D2	0.3	9.500	29.0	6.9				
	CLA D3	2.9	9.200	29.0	7.6				
	D4								
	D5								

PERFORMANCE DATA									
DISINFECTION PROCESS DATA									
Date	Disinfectant	C (mg/L)	Flow (MGD)	Temp (°C)	pH	Giardia Log	Virus Log	Inact. Ratio	Time=
9	NA D1								
	FCL D2	0.1	4.800	30.0	6.9				
	CLA D3	2.4	4.800	29.0	8.0				
	D4								
	D5								
10	NA D1								
	FCL D2	0.2	9.700	29.0	7.0				
	CLA D3	2.4	9.700	29.0	7.5				
	D4								
	D5								
11	NA D1								
	FCL D2	0.1	5.000	29.0	6.9				
	CLA D3	2.3	5.000	29.0	7.7				
	D4								
	D5								
12	NA D1								
	FCL D2	0.1	9.400	29.0	6.8				
	CLA D3	2.4	9.400	29.0	8.0				
	D4								
	D5								
13	NA D1								
	FCL D2	0.4	9.700	29.0	6.7				
	CLA D3	2.6	9.700	29.0	7.7				
	D4								
	D5								
14	NA D1								
	FCL D2	0.2	9.600	29.0	6.9				
	CLA D3	2.8	9.600	29.0	7.2				
	D4								
	D5								
15	NA D1								
	FCL D2	0.1	4.700	29.0	7.0				
	CLA D3	2.8	4.700	29.0	7.6				
	D4								
	D5								
16	NA D1								
	FCL D2	0.1	4.700	29.0	7.0				
	CLA D3	2.8	4.700	28.0	7.8				
	D4								
	D5								

NOTE: = ONLY use the "Time=" column to show the length of time that the total inactivation ratio was less than 1.00.

SUBMITTED BY: _____ Certificate No. and Grade: WO0004220, A Date: August 1, 2012

SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER (cont.)
Disinfection Data Page (cont.)

PUBLIC WATER SYSTEM NAME: City of Corsicana
PWS ID No.: 1750002

PLANT NAME OR NUMBER: Navarro Mills
Month: July Year: 2012

DISINFECTION PROCESS PARAMETERS							
APPROVED CT STUDY PARAMETERS					PERFORMANCE STANDARDS		
Parameters	Disinfection Zones					Log Inactivations	
	D1	D2	D3	D4	D5	Giardia lamblia Cysts	Virus
Flow Rate (MGD)	20.250	20.250	20.250			0.5	2.0
T ₁₀ (minutes)	109.1	13.0	100.0				

PERFORMANCE DATA									
Date	DISINFECTION PROCESS DATA								
	Disinfectant	C (mg/L)	Flow (MGD)	Temp (°C)	pH	Giardia Log	Virus Log	Inact. Ratio	Time=
17	NA D1								
	FCL D2	0.3	7.000	29.0	6.9				
	CLA D3	2.9	7.000	28.0	7.6				
	D4								
	D5								
18	NA D1								
	FCL D2	0.4	9.400	29.0	6.9				
	CLA D3	3.3	9.400	29.0	7.4				
	D4								
	D5								
19	NA D1								
	FCL D2	0.5	9.200	29.0	6.8				
	CLA D3	3.0	9.200	29.0	7.5				
	D4								
	D5								
20	NA D1								
	FCL D2	0.7	9.200	29.0	6.9				
	CLA D3	3.1	9.200	29.0	7.8				
	D4								
	D5								
21	NA D1								
	FCL D2	0.6	9.000	30.0	6.9				
	CLA D3	3.0	9.000	30.0	7.9				
	D4								
	D5								
22	NA D1								
	FCL D2	0.6	9.100	30.0	7.0				
	CLA D3	2.8	9.100	30.0	7.9				
	D4								
	D5								
23	NA D1								
	FCL D2	0.4	9.100	30.0	6.9				
	CLA D3	3.0	9.100	30.0	7.8				
	D4								
	D5								
24	NA D1								
	FCL D2	0.4	9.100	30.0	6.9				
	CLA D3	2.9	9.100	30.0	8.0				
	D4								
	D5								

PERFORMANCE DATA									
Date	DISINFECTION PROCESS DATA								
	Disinfectant	C (mg/L)	Flow (MGD)	Temp (°C)	pH	Giardia Log	Virus Log	Inact. Ratio	Time=
25	NA D1								
	FCL D2	0.5	9.100	30.0	6.9				
	CLA D3	2.7	9.100	30.0	7.9				
	D4								
	D5								
26	NA D1								
	FCL D2	0.5	8.900	30.0	7.0				
	CLA D3	2.8	8.900	30.0	7.9				
	D4								
	D5								
27	NA D1								
	FCL D2	0.4	9.100	30.0	7.1				
	CLA D3	2.7	9.100	30.0	8.2				
	D4								
	D5								
28	NA D1								
	FCL D2	0.4	9.200	30.0	7.0				
	CLA D3	3.0	9.200	30.0	7.6				
	D4								
	D5								
29	NA D1								
	FCL D2	0.5	9.100	30.0	7.0				
	CLA D3	2.9	9.100	30.0	7.5				
	D4								
	D5								
30	NA D1								
	FCL D2	0.4	9.000	30.0	7.0				
	CLA D3	2.9	9.000	30.0	7.6				
	D4								
	D5								
31	NA D1								
	FCL D2	0.5	9.100	30.0	6.9				
	CLA D3	3.1	9.100	30.0	7.7				
	D4								
	D5								
						Max	NA	NA	
						Min	NA	NA	
						Avg	NA	NA	
						SD	NA	NA	

NOTE: = ONLY use the "Time=" column to show the length of time that the total inactivation ratio was less than 1.00.

SUBMITTED BY: _____ Certificate No. and Grade: WO0004220, A Date: August 1, 2012

MONTHLY TOTAL ORGANIC CARBON REMOVAL REPORT (TOCMOR)

FOR SURFACE WATER OR GROUND WATER UNDER THE INFLUENCE OF SURFACE WATER SYSTEMS

PUBLIC WATER SYSTEM NAME: City of Corsicana
 PWS ID No.: 1750002
 Type of treatment: Conventional Unconventional explain: _____

PLANT NAME OR NUMBER: Navarro Mills
 Month: July Year: 2012

Note: Systems are required to run one TOC Sample Set every month. Additional space is provided for those systems that do additional sampling

Test No.	Test Date	Monthly TOC Sample Set			Actual % TOC Removed	Step 1 Required Removal %	Step 1 Removal Ratio	Optional data		COMPLIANCE REMOVAL RATIO
		Raw Alkalinity	Raw TOC	Treated TOC				Step 2 Required % Removal	Step 2 Removal Ratio	
		Enter the Sample Set results						<i>calculated</i>	<i>calculated from matrix</i>	
1	7/3	107	4.66	3.56	23.6	35	0.67	Not Amenable	NA	1.00
2										
3										
4										
5										
6										
7										
8										
9										
10										
11										
12										
13										
14										
15										
16										
17										
18										
19										
20										
21										
22										
23										
24										
25										
26										
27										
28										
29										
30										
31										
Avg		107.00	4.66	3.56	23.61		0.67		NA	1.00
Max		107.00	4.66	3.56	23.61		0.67		NA	1.00
Min		107.00	4.66	3.56	23.61		0.67		NA	1.00

TOTAL ORGANIC CARBON (TOC) REMOVAL SUMMARY

TOC Summary: Don't forget to include a copy of your P.8-TOC Step 2 worksheet with your report.					Monthly Compliance Ratio
Raw Water Alkalinity	Raw Water TOC	Treated Water TOC	TOC % Removal	ACC # used	
107	4.66	3.56	23.6	NA	1.00

I certify that I am familiar with the information contained in this report and that, to the best of my knowledge, the information is true, complete, and accurate.

Operator's Signature: _____ Certificate No. and Grade: WO0004220, A Date: August 1, 2012

Submit the report by the 10th of the month following the reporting period to:
 TEXAS COMMISSION ON ENVIRONMENTAL QUALITY
 WATER SUPPLY DIVISION/PUBLIC DRINKING WATER SECTION (MC-155)
 P.O. BOX 13087, AUSTIN, TEXAS 78711-3087

TOC ALTERNATIVE COMPLIANCE CRITERIA REPORT
FOR SURFACE WATER OR GROUND WATER UNDER THE INFLUENCE OF SURFACE WATER SYSTEMS

PUBLIC WATER SYSTEM NAME: City of Corsicana
PWS ID No.: 1750002

PLANT NAME OR NUMBER: Navarro Mills
Month: July Year: 2012

This Alternative Compliance Criteria (ACC) Report is being submitted to request the following ACC: (check one)
(Before you can begin entering data, you must put an "X" in the box that shows the number of the Alternative Compliance Criteria you are applying for.)

#1 #2 #3 #4 #5 #6 #7 #8

ACC #1	Source Water TOC less than 2.0? (either based on most recent month's data OR calculated quarterly as a running annual average)												
	Current Month TOC												
	Month/Year	Q1			Q2			Q3			Q4		
	Month/Year	07/2011	08/2011	09/2011	10/2011	11/2011	12/2011	01/2012	02/2012	03/2012	04/2012	05/2012	06/2012
	Average Raw Water TOC												
Quarterly Average													
RAA													

ACC #2	Treated Water TOC less than 2.0? (either based on most recent month's data OR calculated quarterly as a running annual average)												
	Current Month TOC	3.56											
	Month/Year	Q1			Q2			Q3			Q4		
	Month/Year	07/2011	08/2011	09/2011	10/2011	11/2011	12/2011	01/2012	02/2012	03/2012	04/2012	05/2012	06/2012
	Average Treated Water TOC												
Quarterly Average													
RAA													

ACC #3	Source Water TOC less than 4.0? (calculated quarterly as a running annual average) AND Source water alkalinity over 60 mg/L (as CaCO3)? (calculated quarterly as a running annual average)												
	Month/Year	Q1			Q2			Q3			Q4		
	Month/Year	07/2011	08/2011	09/2011	10/2011	11/2011	12/2011	01/2012	02/2012	03/2012	04/2012	05/2012	06/2012
	Average Raw Water TOC												
	Quarterly Average												
RAA													
Average Raw Water Alkalinity													
Quarterly Average													
RAA													
AND TTHM and HAA5 no greater than 0.040 mg/L and 0.030 mg/L, respectively? (calculated as a running annual average of quarterly averages)													
TTHM RAA for the 4 quarters that end June 2012: <input type="text"/> mg/L HAA5 RAA for the 4 quarter that end June 2012: <input type="text"/> mg/L													

ACC #4	TTHM and HAA5 no greater than 0.040 mg/L and 0.030 mg/L, respectively? (calculated as a running annual average of quarterly averages)											
	TTHM RAA for the 4 quarters that end June 2012: <input type="text"/> mg/L HAA5 RAA for the 4 quarters that end June 2012: <input type="text"/> mg/L											
	AND only chlorine is used in the whole plant and distribution system. Chlorine only?: <input type="text"/>											
I certify that for the last 12 months, only free chlorine was used as a disinfectant for primary disinfection and for maintenance of a residual in the distribution system.												
Certified Operators Signature/ Certificate Number / Date _____												

ACC #5	Source water SUVA less than or equal to 2.0 L/mg-m? (either based on most recent month's data OR calculated quarterly as a running annual average)												
	Current Month SUVA												
	Month/Year	Q1			Q2			Q3			Q4		
	Month/Year	07/2011	08/2011	09/2011	10/2011	11/2011	12/2011	01/2012	02/2012	03/2012	04/2012	05/2012	06/2012
	Monthly Raw Water SUVA												
Quarterly Average													
RAA													

ACC #6	Treated water SUVA less than or equal to 2.0 L/mg-m? (either based on most recent month's data OR calculated quarterly as a running annual average)												
	Treated water SUVA measured:	<input type="text"/>	In Plant										
		<input type="text"/>	By Finished Water SUVA Jar Test										
	I certify that an oxidant was used upstream of the Treated Water TOC monitoring point during the period for which treated water SUVA data is reported.												
	Certified Operators Signature / Certificate Number / Date _____												
Current Month SUVA													
Month/Year	Q1			Q2			Q3			Q4			
Month/Year	07/2011	08/2011	09/2011	10/2011	11/2011	12/2011	01/2012	02/2012	03/2012	04/2012	05/2012	06/2012	
Monthly Treated Water SUVA													
Quarterly Average													
RAA													

ACC #7	Treated water alkalinity less than 60 mg/L (as CaCO3)? (softening practiced) (either based on most recent month's data OR calculated quarterly as a running annual average)												
	Current Month ALK												
	Month/Year	Q1			Q2			Q3			Q4		
	Month/Year	07/2011	08/2011	09/2011	10/2011	11/2011	12/2011	01/2012	02/2012	03/2012	04/2012	05/2012	06/2012
	Monthly Treated Alkalinity												
Quarterly Average													
RAA													

ACC #8	Magnesium hardness removal greater than or equal to 10 mg/L (as CaCO3)? (softening practiced) (either based on most recent month's data OR calculated quarterly as a running annual average)											
	Current Month Mg Hardness											
	Raw											
	Treated											
	Removal											
Month/Year	Q1			Q2			Q3			Q4		
Month/Year	07/2011	08/2011	09/2011	10/2011	11/2011	12/2011	01/2012	02/2012	03/2012	04/2012	05/2012	06/2012
Monthly Raw Mg Hardness												
Monthly Treated Mg Hardness												
Monthly Mg Removal												
Quarterly Average Removal												
RAA Removal												

I certify that I am familiar with the information contained in this report and that, to the best of my knowledge, the information is true, complete, and accurate.

Operator's Signature: _____ Certificate No. and Grade: WO0004220, A Date: August 1, 2012

STEP 2 JAR TEST REPORT

FOR SURFACE WATER OR GROUND WATER UNDER THE INFLUENCE OF SURFACE WATER SYSTEMS


PUBLIC WATER SYSTEM NAME: City of Corsicana
 PWS ID No.: 1750002

PLANT NAME OR NUMBER: Navarro Mills
 DATE OF JAR TEST: August 10, 2012

PLANT CONDITIONS								
RAW WATER SOURCE(s)	COAGULANT		COAGULANT AID		FLOC AID		pH ADJUSTMENT	
	Type	Dose (mg/L)	Type	Dose (mg/L)	Type	Dose (mg/L)	Type	Dose (mg/L)
Navarro Mills	Alum	120.00	n/a	0.00	n/a	0.00	Caustic	24.00

STEP 2 JAR TEST PARAMETERS									
COAGULANT		BASE		JAR SIZE	JAR TEST CONDITIONS				
Type	Stock Solution Concentration (g/L)	Type	Stock Solution Concentration (g/L)	Volume (liters)	Rapid Mix		Flocculation		Settling
					Speed (rpm)	Duration (minutes)	Speed (rpm)	Duration (minutes)	Duration (minutes)
Alum	11	n/a	-	0.5	100.0	1.0	30.0	20.0	40.0

JAR TEST RESULTS										
Jar No.	COAGULANT		BASE		Alkalinity (mg/L as CaCO ₃)	pH	TOC (mg/L)	Incremental TOC Removal (mg/L TOC removed per 10 mg/L of alum)	Cumulative TOC Removal (%)	
	Dose (Alum eq.) (mg/L)	Volume (mL)	Dose (mg/L)	Volume (mL)						
RAW					109	7.7	4.4			
1	50	2.50	0.00		Target pH (based on raw water alkalinity) 6.3	7.3	3.7	0.1	14.6	
2	60	3.00	0.00			7.1	3.6	0.1	17.8	
3	70	3.50	0.00			7.0	3.4	0.2	21.5	
4	80	4.00	0.00			6.9	3.5	-0.1	bad data point	
5	90	4.50	0.00			6.7	3.5	0.0	20.6	
6	100	5.00	0.00			6.7	3.4	0.0	21.5	
7	110	5.50	0.00			6.7	3.6	-0.1	bad data point	
8	120	6.00	0.00			6.6	3.5	0.0	19.5	
9	130	6.50	0.00			6.5	3.4	0.1	21.3	
10	140	7.00	0.00			6.4	3.3	0.1	23.6	
11	150	7.50	0.00			6.4	3.6	-0.2	bad data point	
12	160	8.00	0.00			6.2	3.4	0.2	23.3	
Has the TCEQ approved this source as "Not Amenable" to Treatment even though Target pH was not reached? If "yes", provide the date of the TCEQ letter or e-mail.					TOC, % Removal at Apparent PODR:			Not Amenable		



I certify that I am familiar with the information contained in this report and that, to the best of my knowledge, the information is true, complete, and accurate.

Operator's Signature: _____

Certificate No. and Grade: WO0004220, A