

# SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES  
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER

Summary Page

PUBLIC WATER  
SYSTEM NAME: City of Corsicana

PLANT NAME  
OR NUMBER: Navarro Mills

I certify that I am familiar with the information contained in this report and that, to the best of my knowledge, the information is true, complete, and accurate.

PWS ID No.: 1750002  
Report for  
the Month of: September 2011

Operator's Signature: \_\_\_\_\_  
Certificate No. & Grade: WO0004220, A Date: October 3, 2011

## TREATMENT PLANT PERFORMANCE

Total number of turbidity readings:	180	Number of 4-hour periods when plant was off-line:	0
Number of readings above 0.10 NTU:	3	Number of 4-hour periods when plant was on-line but turbidity data was not collected:	0
Number of readings above 0.3 NTU:	0	Number of days when plant was on-line but individual filter turbidity data was not collected:	0
Number of readings above 0.5 NTU:	0	Number of days with readings above 1.0 NTU:	0 (2)
Number of readings above 1.0 NTU:	0	Number of days with readings above 5.0 NTU:	0 (3)
Maximum allowable turbidity level:	0.3		
Percentage of readings above this limit:	0.0 % (1)		

Statistical Summary	Maximum turbidity reading:	0.14 NTU	Average turbidity value:	0.06 NTU
	Minimum turbidity reading:	0.04 NTU	Standard deviation:	0.014 NTU
	CFE 95 <sup>th</sup> percentile value:	0.08 NTU	IFE 95 <sup>th</sup> percentile:	0.170 NTU

Number of days with a low CT for no more than 4.0 consecutive hours:	0	Average log inactivation for Giardia:	NA
Number of days with a low CT for more than 4.0 consecutive hours:	0 (4)	Average log inactivation for viruses:	NA
		Number of days when profiling data was not collected:	30
		Number of days when CT data was not collected:	30

Minimum disinfectant residual required leaving the plant:	0.5 mg/L, measured as Total Chlorine		
Number of days with a low residual for no more than 4.0 consecutive hours:	0		
Number of days with a low residual for more than 4.0 consecutive hours:	0 (5)	Number of days when disinfectant residual leaving the plant was not properly monitored:	0

## DISTRIBUTION SYSTEM

Minimum disinfectant residual required in distribution system:	0.5 mg/L, measured as Total Chlorine		
Total number of readings this month:	60	(at least 30 required) (8)	
Average disinfectant residual value:	2.59	Percentage of readings with a low residual this month:	0.0 % (6A)
Number of readings with a low residual:	0		
Number of readings with no detectable residual:	0	Percentage of readings with a low residual last month:	0.0 % (6B)

## ADDITIONAL REPORTS & WORKSHEETS

The Page 1 Addendum (Public Notices) is required because there was at least one treatment technique or monitoring/reporting violation reported.

#NAME?  NONE  Filter Profile  Filter Assessment  CPE

Additional report(s) for individual filter monitoring submitted:  NONE  Filter Profile (9)  Filter Assessment (10)  CPE (11)

No additional IFE Reports are required this month.

**SURFACE WATER MONTHLY OPERATING REPORT**  
TEXAS COMMISSION ON ENVIRONMENTAL QUALITY  
WATER SUPPLY DIVISION/PUBLIC DRINKING WATER SECTION (MC-155)  
P.O. BOX 13087, AUSTIN, TEXAS 78711-3087

# SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES  
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER (cont.)

*Turbidity Data Page*

PUBLIC WATER SYSTEM NAME: City of Corsicana PLANT NAME OR NUMBER: Navarro Mills

PWS ID No.: 1750002 Connections: 10,884

Month: September Year: 2011 Population: 23,770

PERFORMANCE DATA																		
Date	Raw Water Pumpage (MGD)	Treated Water Pumpage (MGD)	RAW WATER ANALYSES		SETTLED WATER TURBIDITY (Mandatory Data)						FINISHED WATER QUALITY							
			NTU	Alk.	Basin No.						Turbidity						Lowest Residual	Time†
					1	2	3	4	5	6	NTU1	NTU2	NTU3	NTU4	NTU5	NTU6		
1	9.710	9.435	28	97	0.4	0.6	0.5	0.6	0.4	0.5	0.06	0.06	0.07	0.07	0.06	0.10	2.9	
2	8.920	8.550	28	96	0.4	0.5	0.5	0.5	0.4	0.4	0.06	0.06	0.05	0.05	0.05	0.05	3.1	
3	8.880	9.089	32	99	0.4	0.7	0.4	0.5	0.4	0.4	0.05	0.05	0.05	0.05	0.05	0.05	3.3	
4	8.920	8.060	48	102	0.5	0.7	0.5	0.6	0.5	0.5	0.05	0.05	0.06	0.06	0.06	0.06	3.4	
5	10.200	9.826	36	99	0.6	0.6	0.7	0.5	0.6	0.5	0.07	0.07	0.07	0.07	0.06	0.06	3.4	
6	11.450	9.400	54	102	0.5	0.8	0.5	0.6	0.5	0.7	0.06	0.06	0.06	0.06	0.06	0.06	3.2	
7	10.920	10.808	65	100	0.7	0.7	0.7	0.9	0.8	0.7	0.05	0.06	0.07	0.08	0.07	0.06	2.9	
8	9.070	9.796	65	100	0.7	0.9	0.7	0.9	0.7	1.1	0.06	0.07	0.07	0.07	0.06	0.06	3.2	
9	8.660	7.647	64	99	0.8	0.9	0.9	0.8	0.7	0.9	0.06	0.07	0.08	0.07	0.07	0.07	3.1	
10	8.760	9.392	37	98	0.5	0.7	0.8	0.6	0.6	0.5	0.06	0.07	0.07	0.07	0.06	0.06	3.1	
11	8.810	8.523	34	91	0.4	0.9	0.5	0.6	0.4	0.4	0.06	0.05	0.05	0.06	0.06	0.05	3.1	
12	10.110	9.481	30	88	0.4	0.7	0.6	0.4	0.5	0.4	0.05	0.06	0.05	0.05	0.06	0.05	3.1	
13	10.810	9.401	26	86	0.3	0.6	0.4	0.5	0.3	0.7	0.05	0.06	0.07	0.06	0.06	0.05	3.1	
14	10.770	10.323	20	84	0.4	0.5	0.6	0.5	0.6	0.5	0.06	0.06	0.06	0.07	0.07	0.07	3.1	
15	10.760	10.492	21	95	0.4	0.6	0.5	0.6	0.4	1.1	0.07	0.07	0.07	0.07	0.06	0.05	3.0	
16	9.690	9.415	27	99	0.4	0.5	0.5	0.4	0.5	0.6	0.06	0.06	0.05	0.05	0.05	0.05	3.0	
17	8.460	8.437	26	94	0.3	0.7	0.5	0.4	0.4	0.6	0.05	0.05	0.05	0.05	0.05	0.05	3.0	
18	8.490	7.957	21	93	0.3	0.7	0.4	0.5	0.4	0.5	0.05	0.05	0.05	0.05	0.07	0.05	2.9	
19	8.630	7.223	31	93	0.7	1.3	1.0	0.8	0.9	0.8	0.07	0.06	0.07	0.14	0.14	0.10	2.9	
20	4.840	4.326	29	92	0.5	0.8	0.7	0.7	0.6	0.7	0.13	0.10	0.08	0.07	0.07	0.07	2.9	
21	7.450	7.226	27	94	0.4	0.7	0.6	0.4	0.5	0.6	0.08	0.07	0.07	0.07	0.06	0.05	2.8	
22	7.430	6.720	29	95	0.4	0.7	0.4	0.5	0.4	0.6	0.04	0.05	0.06	0.06	0.06	0.06	3.1	
23	6.020	5.278	30	96	0.3	0.6	0.5	0.4	0.4	0.5	0.06	0.06	0.05	0.05	0.05	0.05	2.9	
24	7.890	6.530	30	98	0.3	0.8	0.5	0.5	0.4	0.7	0.06	0.06	0.06	0.06	0.05	0.05	3.0	
25	9.210	7.651	26	99	0.3	0.7	0.4	0.4	0.4	0.6	0.05	0.05	0.06	0.06	0.05	0.06	2.8	
26	10.010	8.849	23	94	0.5	0.7	0.6	0.4	0.5	0.4	0.06	0.07	0.06	0.06	0.06	0.06	2.8	
27	6.130	6.096	35	97	0.5	0.5	0.5	0.5	0.4	1.3	0.07	0.07	0.07	0.07	0.07	0.06	2.9	
28	8.330	7.926	35	96	0.4	0.4	0.4	0.5	0.4	0.5	0.06	0.07	0.07	0.07	0.06	0.06	3.1	
29	9.370	7.283	34	99	0.5	0.5	0.4	0.5	0.4	0.9	0.06	0.07	0.07	0.07	0.07	0.06	3.0	
30	9.250	8.220	30	98	0.4	0.5	0.5	0.5	0.5	1.5	0.08	0.07	0.07	0.07	0.06	0.06	3.0	
31																		
Total	267.950	249.360																
Avg	8.932	8.312																
Max	11.450	10.808																
Min	4.840	4.326																

NOTE: ONLY use the "Time" column to show the length of time that the disinfectant residual entering the distribution system fell below the acceptable level.

SUBMITTED BY: \_\_\_\_\_ Certificate No. and Grade: WO0004220, A Date: October 3, 2011

# SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES  
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER (cont.)

Filter Data Page

PUBLIC WATER  
SYSTEM NAME: City of Corsicana

PLANT NAME  
OR NUMBER: Navarro Mills

PWS ID No.: 1750002

Month: September Year: 2011

PERFORMANCE DATA																				
INDIVIDUAL FILTER TURBIDITY																				
Date	Filter No. 1		Filter No. 2		Filter No. 3		Filter No. 4		Filter No. 5		Filter No. 6		Filter No. 7		Filter No. 8		Filter No. 9		Filter No. 10	
	Max	4 Hrs	Max	4 Hrs																
1	0.09	x	0.07	x	0.09	x	0.07	x	0.09	x	0.07	x								
2	0.07	x	0.06	x	0.07	x	0.06	x	0.08	x	0.06	x								
3	0.05	x	0.05	x	0.06	x	0.05	x	0.07	x	0.05	x								
4	0.06	x	0.11	0.08	0.07	x	0.12	0.07	0.16	0.11	0.11	0.07								
5	0.13	0.07	0.07	x	0.13	0.09	0.08	x	0.12	x	0.08	x								
6	0.08	x	0.08	x	0.08	x	0.08	x	0.10	x	0.08	x								
7	0.08	x	0.16	x	0.09	x	0.09	x	0.10	x	0.08	x								
8	0.08	x	0.10	0.10	0.08	x	0.08	x	0.10	x	0.08	x								
9	0.08	x	0.10	x	0.09	x	0.08	x	0.10	x	0.08	x								
10	0.07	x	0.08	x	0.07	x	0.07	x	0.09	x	0.07	x								
11	0.07	x	0.06	x	0.10	x	0.07	x	0.10	x	0.10	0.06								
12	0.06	x	0.06	x	0.11	0.08	0.13	0.07	0.08	x	0.08	x								
13	0.12	0.06	0.06	x	0.09	x	0.09	x	0.15	0.11	0.08	x								
14	0.10	x	0.11	0.06	0.09	x	0.09	x	0.11	x	0.08	x								
15	0.08	x	0.09	x	0.08	x	0.08	x	0.10	x	0.08	x								
16	0.06	x	0.07	x	0.07	x	0.06	x	0.10	x	0.06	x								
17	0.06	x	0.06	x	0.06	x	0.06	x	0.08	x	0.05	x								
18	0.08	x	0.08	x	0.11	0.07	0.08	x	0.10	x	0.09	x								
19	0.21	x	0.21	x	0.36	x	0.19	0.13	0.21	x	0.20	0.11								
20	0.17	x	0.09	x	0.10	x	0.12	x	0.13	x	0.11	x								
21	0.09	x	x	x	0.08	x	0.09	x	0.17	0.09	0.08	x								
22	0.07	x	x	x	0.07	x	0.07	x	0.09	x	0.07	x								
23	0.07	x	x	x	0.07	x	0.07	x	x	x	0.07	x								
24	0.08	x	x	x	0.07	x	0.08	x	0.25	x	0.09	x								
25	0.07	x	0.28	0.09	x	x	0.06	x	0.10	x	0.07	x								
26	0.11	x	0.10	x	0.13	0.10	0.12	x	0.13	x	0.09	x								
27	0.07	x	0.09	x	0.11	x	0.08	x	0.10	x	0.11	x								
28	0.11	0.08	0.07	x	0.09	x	0.12	0.09	0.09	x	0.10	x								
29	0.08	x	0.06	x	0.07	x	0.09	x	x	x	0.08	x								
30	0.09	x	0.07	x	0.08	x	0.09	x	x	x	0.11	x								
31																				

SUMMARY & COMPLIANCE ACTIONS	Criteria	Filter No.										Plant	
		1	2	3	4	5	6	7	8	9	10		
	Number of days with event(s) above 0.5 NTU at 4.0 hrs this month	0	0	0	0	0	0						
	Number of days with event(s) above 1.0 NTU this month	#####	#####	#####	#####	#####	#####						
	Number of days with event(s) above 1.0 NTU last month	0	0	0	0	0	0						
	Number of days with event(s) above 1.0 NTU two months ago	0	0	0	0	0	0						
	Total number of days with event(s) above 1.0 NTU in three months	#####	#####	#####	#####	#####	#####	#####	#####	#####	#####	#####	
	Number of days with event(s) above 2.0 NTU this month	#####	#####	#####	#####	#####	#####						#####
	Number of days with event(s) above 2.0 NTU last month												0
	Does the filter/plant have an approved Corrective Action Plan?	N	N	N	N	N	N						N
Is the plant required to submit a Filter Profile Report?	#####	#####	#####	#####	#####	#####	#####	#####	#####	#####	#####		
Is the plant required to submit a Filter Assessment Report?	#####	#####	#####	#####	#####	#####							
Is the plant required to submit a Request for Compliance CPE?												#####	

SUBMITTED BY: \_\_\_\_\_ Certificate No. \_\_\_\_\_ and Grade: WO0004220, A Date: October 3, 2011

# SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES  
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER (cont.)

*Disinfection Data Page*

PUBLIC WATER SYSTEM NAME: City of Corsicana  
PWS ID No.: 1750002

PLANT NAME OR NUMBER: Navarro Mills  
Month: September Year: 2011

DISINFECTION PROCESS PARAMETERS							
APPROVED CT STUDY PARAMETERS					PERFORMANCE STANDARDS		
Parameters	Disinfection Zones					Log Inactivations	
	D1	D2	D3	D4	D5	Giardia lamblia Cysts	Viruses
Flow Rate (MGD)	20.250	20.250	20.250			0.5	2.0
T <sub>10</sub> (minutes)	109.1	13.0	100.0				

PERFORMANCE DATA									
DISINFECTION PROCESS DATA									
Date	Disinfectant	C (mg/L)	Flow (MGD)	Temp (°C)	pH	Giardia Log	Virus Log	Inact. Ratio	Time†
1	NA D1								
	FCL D2	0.3	10.600	29.0	7.0				
	CLA D3	2.9	10.600	29.0	7.5				
	D4								
	D5								
2	NA D1								
	FCL D2	0.1	9.000	29.0	7.0				
	CLA D3	3.3	9.000	29.0	7.4				
	D4								
	D5								
3	NA D1								
	FCL D2	0.2	8.900	29.0	7.1				
	CLA D3	3.3	8.900	29.0	7.6				
	D4								
	D5								
4	NA D1								
	FCL D2	0.1	8.900	28.0	7.0				
	CLA D3	3.5	8.900	29.0	7.5				
	D4								
	D5								
5	NA D1								
	FCL D2	0.2	11.300	27.0	7.0				
	CLA D3	3.5	11.300	27.0	7.8				
	D4								
	D5								
6	NA D1								
	FCL D2	0.2	11.600	27.0	7.0				
	CLA D3	3.6	11.600	27.0	7.6				
	D4								
	D5								
7	NA D1								
	FCL D2	0.3	11.300	27.0	7.0				
	CLA D3	3.1	11.300	27.0	7.6				
	D4								
	D5								
8	NA D1								
	FCL D2	0.5	10.800	26.0	7.0				
	CLA D3	3.3	10.800	26.0	7.6				
	D4								
	D5								

PERFORMANCE DATA									
DISINFECTION PROCESS DATA									
Date	Disinfectant	C (mg/L)	Flow (MGD)	Temp (°C)	pH	Giardia Log	Virus Log	Inact. Ratio	Time†
9	NA D1								
	FCL D2	0.2	8.800	25.0	7.1				
	CLA D3	3.3	8.800	25.0	7.8				
	D4								
	D5								
10	NA D1								
	FCL D2	0.2	8.900	25.0	7.1				
	CLA D3	3.3	8.900	25.0	7.7				
	D4								
	D5								
11	NA D1								
	FCL D2	0.2	8.900	25.0	7.0				
	CLA D3	3.3	8.900	25.0	7.7				
	D4								
	D5								
12	NA D1								
	FCL D2	0.2	11.100	25.0	7.0				
	CLA D3	3.3	11.100	25.0	7.7				
	D4								
	D5								
13	NA D1								
	FCL D2	0.2	10.900	26.0	7.0				
	CLA D3	3.4	10.900	26.0	7.6				
	D4								
	D5								
14	NA D1								
	FCL D2	0.2	10.900	27.0	7.0				
	CLA D3	3.3	10.900	27.0	7.7				
	D4								
	D5								
15	NA D1								
	FCL D2	0.2	10.800	26.0	7.1				
	CLA D3	3.1	10.800	26.0	7.5				
	D4								
	D5								
16	NA D1								
	FCL D2	0.4	10.800	26.0	7.1				
	CLA D3	3.0	10.800	26.0	7.5				
	D4								
	D5								

NOTE: † ONLY use the "Time†" column to show the length of time that the total inactivation ratio was less than 1.00.

SUBMITTED BY: \_\_\_\_\_ Certificate No. and Grade: WO0004220, A Date: October 3, 2011

# SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES  
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER (cont.)  
*Disinfection Data Page (cont.)*

PUBLIC WATER SYSTEM NAME: City of Corsicana  
PWS ID No.: 1750002

PLANT NAME OR NUMBER: Navarro Mills  
Month: September Year: 2011

DISINFECTION PROCESS PARAMETERS							
APPROVED CT STUDY PARAMETERS					PERFORMANCE STANDARDS		
Parameters	Disinfection Zones					Log Inactivations	
	D1	D2	D3	D4	D5	Giardia lamblia Cysts	Virus
Flow Rate (MGD)	20.250	20.250	20.250			0.5	2.0
T <sub>10</sub> (minutes)	109.1	13.0	100.0				

PERFORMANCE DATA									
DISINFECTION PROCESS DATA									
Date	Disinfectant	C (mg/L)	Flow (MGD)	Temp (°C)	pH	Giardia Log	Virus Log	Inact. Ratio	Timet
17	NA D1								
	FCL D2	0.2	8.500	25.0	7.1				
	CLA D3	3.1	8.500	25.0	7.6				
	D4								
	D5								
18	NA D1								
	FCL D2	0.2	8.700	25.0	7.0				
	CLA D3	3.0	8.700	25.0	7.8				
	D4								
	D5								
19	NA D1								
	FCL D2	0.2	8.700	25.0	7.0				
	CLA D3	3.1	8.700	25.0	7.8				
	D4								
	D5								
20	NA D1								
	FCL D2	0.4	8.900	25.0	7.0				
	CLA D3	3.1	8.900	25.0	7.8				
	D4								
	D5								
21	NA D1								
	FCL D2	0.3	9.100	25.0	7.0				
	CLA D3	2.9	9.100	25.0	7.9				
	D4								
	D5								
22	NA D1								
	FCL D2	0.3	9.000	25.0	7.1				
	CLA D3	3.4	9.000	26.0	7.3				
	D4								
	D5								
23	NA D1								
	FCL D2	0.2	7.500	25.0	7.3				
	CLA D3	2.9	7.500	25.0	7.6				
	D4								
	D5								
24	NA D1								
	FCL D2	0.3	8.000	24.0	7.1				
	CLA D3	3.2	8.000	25.0	7.5				
	D4								
	D5								

PERFORMANCE DATA									
DISINFECTION PROCESS DATA									
Date	Disinfectant	C (mg/L)	Flow (MGD)	Temp (°C)	pH	Giardia Log	Virus Log	Inact. Ratio	Timet
25	NA D1								
	FCL D2	0.3	10.300	24.0	7.1				
	CLA D3	3.2	10.300	25.0	7.6				
	D4								
	D5								
26	NA D1								
	FCL D2	0.4	10.200	25.0	7.0				
	CLA D3	3.0	10.200	25.0	7.8				
	D4								
	D5								
27	NA D1								
	FCL D2	0.4	9.900	25.0	7.0				
	CLA D3	3.0	9.900	25.0	7.7				
	D4								
	D5								
28	NA D1								
	FCL D2	0.4	9.300	25.0	7.0				
	CLA D3	3.4	9.300	25.0	7.6				
	D4								
	D5								
29	NA D1								
	FCL D2	0.4	9.500	25.0	7.0				
	CLA D3	3.2	9.500	25.0	7.5				
	D4								
	D5								
30	NA D1								
	FCL D2	0.3	9.300	25.0	7.0				
	CLA D3	3.1	9.300	25.0	7.8				
	D4								
	D5								
31	D1								
	D2								
	D3								
	D4								
	D5								

Max	NA	NA
Min	NA	NA
Avg	NA	NA
SD	NA	NA

NOTE: † ONLY use the "Timet" column to show the length of time that the total inactivation ratio was less than 1.00.

SUBMITTED BY: \_\_\_\_\_ Certificate No. and Grade: WO0004220, A Date: October 3, 2011

# MONTHLY TOTAL ORGANIC CARBON REMOVAL REPORT (TOCMOR)

## FOR SURFACE WATER OR GROUND WATER UNDER THE INFLUENCE OF SURFACE WATER SYSTEMS

PUBLIC WATER SYSTEM NAME: City of Corsicana  
 PWS ID No.: 1750002

PLANT NAME OR NUMBER: Navarro Mills  
 Month: September Year: 2011

Type of treatment:  Conventional  Unconventional explain:

Note: Systems are required to run one TOC Sample Set every month. Additional space is provided for those systems that do additional sampling

Test No.	Test Date	Monthly TOC Sample Set			Actual % TOC Removed	Step 1 Required Removal %	Step 1 Removal Ratio	Optional data		COMPLIANCE REMOVAL RATIO
		Raw Alkalinity	Raw TOC	Treated TOC				Step 2 Required % Removal	Step 2 Removal Ratio	
		Enter the Sample Set results						calculated	calculated from matrix	
1	9/6	102	4.27	3.52	17.6	#NAME?	#NAME?			#NAME?
2										#NAME?
3										#NAME?
4										#NAME?
5										#NAME?
6										#NAME?
7										#NAME?
8										#NAME?
9										#NAME?
10										#NAME?
11										#NAME?
12										#NAME?
13										#NAME?
14										#NAME?
15										#NAME?
16										#NAME?
17										#NAME?
18										#NAME?
19										#NAME?
20										#NAME?
21										#NAME?
22										#NAME?
23										#NAME?
24										#NAME?
25										#NAME?
26										#NAME?
27										#NAME?
28										#NAME?
29										#NAME?
30										#NAME?
31										#NAME?
Avg		102.00	4.27	3.52	17.56		#NAME?			#NAME?
Max		102.00	4.27	3.52	17.56		#NAME?			#NAME?
Min		102.00	4.27	3.52	17.56		#NAME?			#NAME?

### TOTAL ORGANIC CARBON (TOC) REMOVAL SUMMARY

#NAME?					Monthly Compliance Ratio
Raw Water Alkalinity	Raw Water TOC	Treated Water TOC	TOC % Removal	ACC # used	
102	4.27	3.52	17.6	#NAME?	#NAME?
				#NAME?	#NAME?

I certify that I am familiar with the information contained in this report and that, to the best of my knowledge, the information is true, complete, and accurate.

Operator's Signature: \_\_\_\_\_ Certificate No. and Grade: WO0004220, A

Date: October 3, 2011

**Submit the report by the 10th of the month following the reporting period to:**  
 TEXAS COMMISSION ON ENVIRONMENTAL QUALITY  
 WATER SUPPLY DIVISION/PUBLIC DRINKING WATER SECTION (MC-155)  
 P.O. BOX 13087, AUSTIN, TEXAS 78711-3087

**TOC ALTERNATIVE COMPLIANCE CRITERIA REPORT**  
 FOR SURFACE WATER OR GROUND WATER UNDER THE INFLUENCE OF SURFACE WATER SYSTEMS

PUBLIC WATER SYSTEM NAME: City of Corsicana  
 PWS ID No.: 1750002

PLANT NAME OR NUMBER: Navarro Mills  
 Month: September Year: 2011

This Alternative Compliance Criteria (ACC) Report is being submitted to request the following ACC: (check one)  
 (Before you can begin entering data, you must put an "X" in the box that shows the number of the Alternative Compliance Criteria you are applying for.)

#1  #2  #3  #4  #5  #6  #7  #8

ACC #1

ACC #2

ACC #3

ACC #4

ACC #5 Source water SUVA less than or equal to 2.0 L/mg-m?  
 (either based on most recent month's data OR calculated quarterly as a running annual average)  
 (Source water SUVA is the dissolved organic carbon concentration divided by the ultraviolet light absorption at 254 nanometers in the source water before any treatment of any kind. Measure monthly.)

Current Month SUVA	
	1.79

ACC #6

ACC #7

ACC #8

I certify that I am familiar with the information contained in this report and that, to the best of my knowledge, the information is true, complete, and accurate.

Operator's Signature: \_\_\_\_\_ Certificate No. and Grade: WO0004220, A Date: October 3, 2011

# STEP 2 JAR TEST REPORT

FOR SURFACE WATER OR GROUND WATER UNDER THE INFLUENCE OF SURFACE WATER SYSTEMS

PUBLIC WATER SYSTEM NAME: City of Corsicana  
 PWS ID No.: 1750002

PLANT NAME OR NUMBER: Navarro Mills  
 DATE OF JAR TEST: \_\_\_\_\_


PLANT CONDITIONS								
RAW WATER SOURCE(s)	COAGULANT		COAGULANT AID		FLOC AID		pH ADJUSTMENT	
	Type	Dose (mg/L)	Type	Dose (mg/L)	Type	Dose (mg/L)	Type	Dose (mg/L)

STEP 2 JAR TEST PARAMETERS									
COAGULANT		BASE		JAR SIZE	JAR TEST CONDITIONS				
Type	Stock Solution Concentration (g/L)	Type	Stock Solution Concentration (g/L)	Volume (liters)	Rapid Mix		Flocculation		Settling
					Speed (rpm)	Duration (minutes)	Speed (rpm)	Duration (minutes)	Duration (minutes)

JAR TEST RESULTS									
Jar No.	COAGULANT		BASE		Alkalinity (mg/L as CaCO <sub>3</sub> )	pH	TOC (mg/L)	Incremental TOC Removal (mg/L TOC removed per 10 mg/L of alum)	Cumulative TOC Removal (%)
	Dose (Alum eq.) (mg/L)	Volume (mL)	Dose (mg/L)	Volume (mL)					
RAW	0								
1									
2									
3									
4									
5									
6									
7									
8									
9									
10									
11									
12									

Has the TCEQ approved this source as "Not Amenable" to Treatment even though Target pH was not reached?  
 If "yes", provide the date of the TCEQ letter or e-mail.

TOC, % Removal at Apparent PODR:



I certify that I am familiar with the information contained in this report and that, to the best of my knowledge, the information is true, complete, and accurate.

Operator's Signature: \_\_\_\_\_ Certificate No. \_\_\_\_\_ and Grade: WO0004220, A