

SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER

Summary Page

PUBLIC WATER SYSTEM NAME: City of Corsicana

PLANT NAME OR NUMBER: Navarro Mills

I certify that I am familiar with the information contained in this report and that, to the best of my knowledge, the information is true, complete, and accurate.

PWS ID No.: 1750002
Report for the Month of: April 2011

Operator's Signature: *Deborah W. [Signature]*
Certificate No. & Grade: WO0004220, A

Date: May 2, 2011

TREATMENT PLANT PERFORMANCE

Total number of turbidity readings:	180	Number of 4-hour periods when plant was off-line:	0
Number of readings above 0.10 NTU:	0	Number of 4-hour periods when plant was on-line but turbidity data was not collected:	0
Number of readings above 0.3 NTU:	0	Number of days when plant was on-line but individual filter turbidity data was not collected:	0
Number of readings above 0.5 NTU:	0	Number of days with readings above 1.0 NTU:	0 (2)
Number of readings above 1.0 NTU:	0	Number of days with readings above 5.0 NTU:	0 (3)
Maximum allowable turbidity level:	0.3		
Percentage of readings above this limit:	0.0 % (1)		
Statistical Summary		Maximum turbidity reading:	0.10 NTU
		Minimum turbidity reading:	0.03 NTU
		CFE 95 th percentile value:	0.06 NTU
		Average turbidity value:	0.04 NTU
		Standard deviation:	0.010 NTU
		IFE 95 th percentile:	0.107 NTU
Number of days with a low CT for no more than 4.0 consecutive hours:	0	Average log inactivation for Giardia:	3.92
Number of days with a low CT for more than 4.0 consecutive hours:	0 (4)	Average log inactivation for viruses:	42.16
		Number of days when profiling data was not collected:	0
		Number of days when CT data was not collected:	0
Minimum disinfectant residual required leaving the plant:	0.5 mg/L, measured as Total Chlorine		
Number of days with a low residual for no more than 4.0 consecutive hours:	0		
Number of days with a low residual for more than 4.0 consecutive hours:	0 (5)	Number of days when disinfectant residual leaving the plant was not properly monitored:	0

DISTRIBUTION SYSTEM

Minimum disinfectant residual required in distribution system:	0.5 mg/L, measured as Total Chlorine		
Total number of readings this month:	60	(at least 30 required)	(8)
Average disinfectant residual value:	2.53	Percentage of readings with a low residual this month:	0.0 % (6A)
Number of readings with a low residual:	0		
Number of readings with no detectable residual:	0	Percentage of readings with a low residual last month:	0.0 % (6B)

ADDITIONAL REPORTS & WORKSHEETS

The Page 1 Addendum (Public Notices) is not required because there were no treatment technique or monitoring/reporting violations reported.

Additional report(s) for individual filter monitoring required: NONE Filter Profile Filter Assessment CPE

Additional report(s) for individual filter monitoring submitted: NONE Filter Profile (9) Filter Assessment (10) CPE (11)

No additional IFE Reports are required this month.

SURFACE WATER MONTHLY OPERATING REPORT
TEXAS COMMISSION ON ENVIRONMENTAL QUALITY
WATER SUPPLY DIVISION/PUBLIC DRINKING WATER SECTION (MC-155)
P.O. BOX 13087, AUSTIN, TEXAS 78711-3087

FILE COPY

SURFACE WATER MONTHLY OPERATING REPORT
 FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES
 OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER (cont.)
 Turbidity Data Page

PUBLIC WATER SYSTEM NAME: City of Corsicana
PWS ID No.: 1750002
Month: April **Year:** 2011

PLANT NAME OR NUMBER: Navarro Mills
Connections: 10,838
Population: 23,770

PERFORMANCE DATA																		
Date	Raw Water Pumpage (MGD)	Treated Water Pumpage (MGD)	RAW WATER ANALYSES		SETTLED WATER TURBIDITY (Mandatory Data)						FINISHED WATER QUALITY							
			NTU	Alk.	Basin No.						Turbidity						Lowest Residual	Time
					1	2	3	4	5	6	NTU1	NTU2	NTU3	NTU4	NTU5	NTU6		
1	5.730	7.684	44	124	0.4	0.5	0.6	0.6	0.6	0.5	0.05	0.05	0.06	0.07	0.06	0.10	2.9	
2	7.340	6.186	45	127	0.3	0.3	0.3	0.4	0.4	0.4	0.10	0.09	0.08	0.06	0.06	0.05	3.0	
3	7.270	6.787	28	126	0.3	0.3	0.3	0.3	0.3	0.3	0.05	0.05	0.04	0.04	0.04	0.04	3.1	
4	4.730	5.325	37	123	0.3	0.4	0.4	0.3	0.3	0.3	0.04	0.05	0.04	0.04	0.04	0.04	2.8	
5	5.350	4.536	37	125	0.3	0.4	0.4	0.4	0.3	0.3	0.04	0.04	0.03	0.03	0.04	0.04	2.7	
6	7.140	6.132	37	127	0.4	0.4	0.5	0.5	0.4	0.4	0.04	0.04	0.05	0.04	0.05	0.06	2.9	
7	7.130	5.936	37	127	0.3	0.3	0.3	0.3	0.4	0.3	0.04	0.05	0.05	0.04	0.05	0.06	2.9	
8	4.900	4.966	33	127	0.2	0.3	0.3	0.2	0.2	0.3	0.05	0.04	0.04	0.04	0.04	0.04	2.8	
9	7.210	5.887	28	125	0.2	0.2	0.2	0.3	0.2	0.3	0.04	0.05	0.04	0.04	0.04	0.04	2.8	
10	6.570	6.034	26	126	0.2	0.2	0.3	0.2	0.2	0.2	0.04	0.04	0.03	0.03	0.04	0.04	2.8	
11	5.060	5.177	24	126	0.2	0.2	0.3	0.3	0.3	0.2	0.04	0.04	0.04	0.04	0.03	0.03	2.5	
12	5.090	4.923	28	128	0.2	0.3	0.3	0.2	0.2	0.2	0.04	0.04	0.03	0.04	0.04	0.04	2.6	
13	6.130	5.573	31	128	0.2	0.3	0.3	0.3	0.3	0.2	0.04	0.04	0.04	0.05	0.04	0.05	2.7	
14	7.210	6.289	29	128	0.3	0.3	0.3	0.3	0.3	0.3	0.05	0.05	0.05	0.05	0.04	0.04	2.8	
15	5.990	5.164	28	126	0.3	0.3	0.3	0.3	0.3	0.3	0.04	0.04	0.04	0.04	0.04	0.05	2.8	
16	5.010	5.073	29	129	0.3	0.3	0.4	0.3	0.2	0.3	0.05	0.04	0.04	0.05	0.05	0.05	2.9	
17	4.970	5.051	35	130	0.2	0.3	0.4	0.3	0.2	0.2	0.05	0.06	0.03	0.03	0.04	0.04	2.9	
18	6.450	5.934	39	129	0.3	0.2	0.4	0.3	0.3	0.2	0.04	0.04	0.03	0.03	0.03	0.03	2.9	
19	7.470	6.667	36	129	0.3	0.3	0.3	0.3	0.3	0.3	0.04	0.04	0.04	0.04	0.04	0.04	2.9	
20	6.400	5.390	32	129	0.2	0.2	0.2	0.2	0.2	0.2	0.04	0.05	0.04	0.04	0.04	0.04	3.1	
21	4.980	5.490	34	128	0.2	0.4	0.4	0.3	0.3	0.3	0.03	0.04	0.04	0.05	0.04	0.04	2.7	
22	5.890	5.088	33	129	0.2	0.2	0.3	0.3	0.3	0.2	0.04	0.04	0.03	0.03	0.04	0.04	2.7	
23	7.870	7.907	32	131	0.2	0.3	0.3	0.3	0.2	0.2	0.04	0.04	0.04	0.04	0.04	0.04	2.9	
24	7.820	6.399	31	129	0.2	0.2	0.3	0.3	0.3	0.2	0.04	0.04	0.03	0.03	0.04	0.04	3.2	
25	7.030	6.085	31	128	0.3	0.3	0.3	0.3	0.3	0.2	0.04	0.04	0.03	0.03	0.03	0.03	3.2	
26	4.880	4.946	30	127	0.2	0.3	0.3	0.3	0.2	0.2	0.04	0.04	0.03	0.03	0.04	0.04	2.6	
27	5.100	5.241	30	129	0.2	0.2	0.4	0.3	0.2	0.2	0.05	0.04	0.04	0.04	0.05	0.05	2.5	
28	5.100	4.743	26	127	0.2	0.2	0.3	0.2	0.2	0.2	0.05	0.05	0.04	0.05	0.05	0.05	2.4	
29	5.100	4.844	27	126	0.3	0.3	0.4	0.3	0.2	0.3	0.04	0.05	0.05	0.04	0.05	0.05	2.5	
30	5.020	5.077	25	126	0.3	0.3	0.3	0.3	0.2	0.2	0.04	0.04	0.04	0.04	0.05	0.05	2.6	
31																		
Total	181.940	170.334																
Avg	6.065	5.678																
Max	7.870	7.907																
Min	4.730	4.536																

NOTE: ONLY use the "Time" column to show the length of time that the disinfectant residual entering the distribution system fell below the acceptable level.

SUBMITTED BY: Douglas W. Sp... **Certificate No. and Grade:** WO0004220, A **Date:** May 2, 2011

SURFACE WATER MONTHLY OPERATING REPORT
 FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES
 OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER (cont.)
 Filter Data Page

PUBLIC WATER
 SYSTEM NAME: City of Corsicana

PLANT NAME
 OR NUMBER: Navarro Mills

PWS ID No.: 1750002

Month: April Year: 2011

PERFORMANCE DATA																				
Date	INDIVIDUAL FILTER TURBIDITY																			
	Filter No. 1		Filter No. 2		Filter No. 3		Filter No. 4		Filter No. 5		Filter No. 6		Filter No. 7		Filter No. 8		Filter No. 9		Filter No. 10	
	Max	4 Hrs	Max	4 Hrs	Max	4 Hrs	Max	4 Hrs	Max	4 Hrs	Max	4 Hrs	Max	4 Hrs	Max	4 Hrs	Max	4 Hrs	Max	4 Hrs
1	0.11	x	0.07	x	0.19	0.14	0.20	0.14	x	x	0.12	x								
2	0.04	x	x	x	0.06	x	0.06	x	x	x	0.05	x								
3	0.05	x	x	x	0.04	x	0.04	x	0.06	0.05	0.03	x								
4	x	x	x	x	0.04	x	0.03	x	0.04	x	0.03	x								
5	x	x	x	x	0.05	x	0.07	x	0.21	x	0.98	x								
6	0.10	0.05	x	x	0.05	x	0.07	x	0.04	x	0.03	x								
7	0.04	x	0.09	0.06	0.04	x	0.05	x	0.04	x	x	x								
8	0.04	x	0.05	x	x	x	0.03	x	0.07	x	0.06	0.04								
9	0.03	x	0.04	x	x	x	x	x	0.03	x	0.04	x								
10	0.03	x	0.03	x	x	x	x	x	0.03	x	0.03	x								
11	0.03	x	0.04	x	x	x	x	x	0.03	x	0.03	x								
12	0.04	x	0.04	x	x	x	x	x	x	x	0.04	x								
13	0.07	x	0.05	x	0.07	0.05	0.09	0.05	x	x	0.04	x								
14	0.06	0.04	0.03	x	0.05	x	0.04	x	x	x	0.03	x								
15	0.03	x	x	x	0.04	x	0.03	x	0.11	0.05	0.03	x								
16	x	x	x	x	0.04	x	0.03	x	0.05	x	x	x								
17	x	x	x	x	0.03	x	0.03	x	0.04	x	x	x								
18	0.03	0.03	0.07	0.04	0.06	x	0.05	x	0.03	x	0.09	0.04								
19	0.03	x	0.04	x	x	x	x	x	0.04	x	0.04	x								
20	0.03	x	0.03	x	x	x	0.04	0.04	0.03	x	0.03	x								
21	x	x	0.03	x	x	x	0.03	x	x	x	0.03	x								
22	x	x	0.03	x	0.06	0.04	0.03	x	0.09	0.04	0.03	x								
23	x	x	x	x	0.04	x	0.03	x	0.04	x	0.03	x								
24	x	x	0.06	0.04	0.04	x	0.03	x	0.04	x	0.03	x								
25	0.10	x	0.03	x	0.03	x	0.04	x	0.03	x	x	x								
26	x	x	0.03	x	0.04	x	x	x	0.03	x	x	x								
27	0.05	0.05	0.04	x	0.06	x	x	x	0.03	x	0.08	0.05								
28	0.04	x	0.04	x	x	x	x	x	x	x	0.04	x								
29	0.04	x	0.03	x	0.05	0.05	x	x	x	x	0.04	x								
30	0.03	x	x	x	0.04	x	x	x	x	x	0.03	x								
31																				

SUMMARY & COMPLIANCE ACTIONS	Criteria	Filter No.										Plant	
		1	2	3	4	5	6	7	8	9	10		
	Number of days with event(s) above 0.5 NTU at 4.0 hrs this month	0	0	0	0	0	0						
	Number of days with event(s) above 1.0 NTU this month	0	0	0	0	0	0						
	Number of days with event(s) above 1.0 NTU last month	0	0	0	0	0	0						
	Number of days with event(s) above 1.0 NTU two months ago	0	0	0	0	0	0						
	Total number of days with event(s) above 1.0 NTU in three months	0	0	0	0	0	0						
	Number of days with event(s) above 2.0 NTU this month												0
	Number of days with event(s) above 2.0 NTU last month												0
	Does the filter/plant have an approved Corrective Action Plan?	N	N	N	N	N	N						N
Is the plant required to submit a Filter Profile Report?	N	N	N	N	N	N							
Is the plant required to submit a Filter Assessment Report?	N	N	N	N	N	N							
Is the plant required to submit a Request for Compliance CPE?											N		

SUBMITTED BY: *Dayko W. Jan*

Certificate No. and Grade: WO0004220, A Date: May 2, 2011

SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER (cont.)
Disinfection Data Page

PUBLIC WATER SYSTEM NAME: City of Corsicana
PWS ID No.: 1750002


PLANT NAME OR NUMBER: Navarro Mills
Month: April Year: 2011

DISINFECTION PROCESS PARAMETERS									
APPROVED CT STUDY PARAMETERS						PERFORMANCE STANDARDS			
Parameters	Disinfection Zones					Log Inactivations			
	D1	D2	D3	D4	D5	Giardia lamblia Cysts		Viruses	
Flow Rate (MGD)	20.250	20.250	20.250			0.5		2.0	
T ₁₀ (minutes)	109.1	13.0	100.0						

PERFORMANCE DATA									
DISINFECTION PROCESS DATA									
Date	Disinfectant	C (mg/L)	Flow (MGD)	Temp (°C)	pH	Giardia Log	Virus Log	Inact. Ratio	Time
1	NA D1								
	FCL D2	0.3	7.400	18.0	7.3				
	CLA D3	3.0	7.400	18.0	7.8	2.48	18.46	4.96	
	D4							(G)	
	D5								
2	NA D1								
	FCL D2	0.8	7.500	18.0	7.3				
	CLA D3	3.1	7.500	18.0	7.8	3.29	40.96	6.58	
	D4							(G)	
	D5								
3	NA D1								
	FCL D2	0.7	7.400	18.0	7.3				
	CLA D3	3.1	7.400	18.0	7.9	3.18	36.94	6.37	
	D4							(G)	
	D5								
4	NA D1								
	FCL D2	0.8	7.300	18.0	7.3				
	CLA D3	3.1	7.300	19.0	8.1	3.50	42.44	7.00	
	D4							(G)	
	D5								
5	NA D1								
	FCL D2	0.8	7.300	19.0	7.4				
	CLA D3	2.8	7.300	19.0	8.2	3.33	44.59	6.66	
	D4							(G)	
	D5								
6	NA D1								
	FCL D2	0.4	7.200	19.0	7.4				
	CLA D3	3.0	7.200	19.0	7.9	2.87	25.38	5.74	
	D4							(G)	
	D5								
7	NA D1								
	FCL D2	0.5	7.200	19.0	7.4				
	CLA D3	3.0	7.200	19.0	8.0	3.04	30.42	6.07	
	D4							(G)	
	D5								
8	NA D1								
	FCL D2	0.6	7.200	19.0	7.4				
	CLA D3	2.8	7.200	19.0	8.0	3.06	35.12	6.12	
	D4							(G)	
	D5								

PERFORMANCE DATA									
DISINFECTION PROCESS DATA									
Date	Disinfectant	C (mg/L)	Flow (MGD)	Temp (°C)	pH	Giardia Log	Virus Log	Inact. Ratio	Time
9	NA D1								
	FCL D2	0.6	7.200	20.0	7.4				
	CLA D3	2.9	7.200	20.0	8.0	3.33	37.83	6.67	
	D4							(G)	
	D5								
10	NA D1								
	FCL D2	0.5	7.300	21.0	7.4				
	CLA D3	2.8	7.300	21.0	7.9	3.25	34.07	6.49	
	D4							(G)	
	D5								
11	NA D1								
	FCL D2	0.5	5.100	21.0	7.4				
	CLA D3	2.5	5.100	21.0	7.9	4.30	47.93	8.61	
	D4							(G)	
	D5								
12	NA D1								
	FCL D2	0.4	5.100	21.0	7.4				
	CLA D3	2.8	5.100	21.0	7.9	4.37	40.59	8.75	
	D4							(G)	
	D5								
13	NA D1								
	FCL D2	0.4	7.200	21.0	7.5				
	CLA D3	2.7	7.200	22.0	7.9	3.14	28.94	6.29	
	D4							(G)	
	D5								
14	NA D1								
	FCL D2	0.4	7.400	21.0	7.4				
	CLA D3	3.0	7.400	23.0	7.7	3.53	29.23	7.07	
	D4							(G)	
	D5								
15	NA D1								
	FCL D2	0.4	7.300	21.0	7.4				
	CLA D3	2.9	7.300	22.0	7.6	3.30	28.96	6.60	
	D4							(G)	
	D5								
16	NA D1								
	FCL D2	0.7	5.000	20.0	7.5				
	CLA D3	3.0	5.000	21.0	7.7	5.31	63.10	10.62	
	D4							(G)	
	D5								

NOTE: = ONLY use the "Time" column to show the length of time that the total inactivation ratio was less than 1.00.

SUBMITTED BY: 

Certificate No. and Grade: WO0004220, A Date: May 2, 2011

SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER (cont.)
Disinfection Data Page (cont.)

PUBLIC WATER SYSTEM NAME: City of Corsicana
PWS ID No.: 1750002

PLANT NAME OR NUMBER: Navarro Mills
Month: April Year: 2011

DISINFECTION PROCESS PARAMETERS							
APPROVED CT STUDY PARAMETERS					PERFORMANCE STANDARDS		
Parameters	Disinfection Zones					Log Inactivations	
	D1	D2	D3	D4	D5	Giardia lamblia Cysts	Virus
Flow Rate (MGD)	20.250	20.250	20.250			0.5	2.0
T ₁₀ (minutes)	109.1	13.0	100.0				

PERFORMANCE DATA									
Date	DISINFECTION PROCESS DATA								
	Disinfectant	C (mg/L)	Flow (MGD)	Temp (°C)	pH	Giardia Log	Virus Log	Inact. Ratio	Time
17	NA D1								
	FCL D2	0.6	4.900	21.0	7.4				
	CLA D3	3.0	4.900	21.0	7.9	5.35	59.86	10.71	
	D4							(G)	
	D5								
18	NA D1								
	FCL D2	0.4	7.300	21.0	7.4				
	CLA D3	3.0	7.300	21.0	7.8	3.21	28.75	6.43	
	D4							(G)	
	D5								
19	NA D1								
	FCL D2	0.5	7.600	21.0	7.4				
	CLA D3	3.0	7.600	21.0	7.7	3.27	33.11	6.54	
	D4							(G)	
	D5								
20	NA D1								
	FCL D2	0.2	7.400	22.0	7.3				
	CLA D3	3.3	7.400	22.0	7.6	3.23	18.93	6.47	
	D4							(G)	
	D5								
21	NA D1								
	FCL D2	0.5	5.000	22.0	7.4				
	CLA D3	2.8	5.000	22.0	7.7	5.08	53.32	10.16	
	D4							(G)	
	D5								
22	NA D1								
	FCL D2	0.6	8.000	24.0	7.5				
	CLA D3	2.9	8.000	22.0	7.8	3.56	44.09	7.12	
	D4							(G)	
	D5								
23	NA D1								
	FCL D2	0.9	8.200	24.0	7.4				
	CLA D3	3.2	8.200	23.0	7.7	4.52	62.81	9.04	
	D4							(G)	
	D5								
24	NA D1								
	FCL D2	0.9	8.100	23.0	7.4				
	CLA D3	3.3	8.100	23.0	7.8	4.53	59.96	9.06	
	D4							(G)	
	D5								

PERFORMANCE DATA									
Date	DISINFECTION PROCESS DATA								
	Disinfectant	C (mg/L)	Flow (MGD)	Temp (°C)	pH	Giardia Log	Virus Log	Inact. Ratio	Time
25	NA D1								
	FCL D2	0.6	8.000	23.0	7.4				
	CLA D3	3.4	8.000	23.0	7.7	4.11	42.94	8.22	
	D4							(G)	
	D5								
26	NA D1								
	FCL D2	0.3	5.000	23.0	7.3				
	CLA D3	2.6	5.000	23.0	7.7	4.56	37.32	9.12	
	D4							(G)	
	D5								
27	NA D1								
	FCL D2	0.5	5.100	23.0	7.4				
	CLA D3	2.6	5.100	23.0	7.7	5.09	55.98	10.17	
	D4							(G)	
	D5								
28	NA D1								
	FCL D2	0.6	5.200	23.0	7.4				
	CLA D3	2.4	5.200	23.0	7.7	5.03	62.90	10.06	
	D4							(G)	
	D5								
29	NA D1								
	FCL D2	0.5	5.100	23.0	7.4				
	CLA D3	2.7	5.100	23.0	7.7	5.22	55.70	10.44	
	D4							(G)	
	D5								
30	NA D1								
	FCL D2	0.6	5.100	23.0	7.4				
	CLA D3	2.6	5.100	23.0	7.9	5.39	64.78	10.79	
	D4							(G)	
	D5								
31	D1								
	D2								
	D3								
	D4								
	D5								

Max	5.39	64.78
Min	2.48	18.46
Avg	3.92	42.16
SD	0.87	13.48

NOTE: = ONLY use the "Time" column to show the length of time that the total inactivation ratio was less than 1.00.

SUBMITTED BY: *Daugh W. Sp...*
TCEQ - 0102C (06-01-09)

Certificate No. and Grade: WO0004220, A Date: May 2, 2011

MONTHLY TOTAL ORGANIC CARBON REMOVAL REPORT (TOCMOR)

FOR SURFACE WATER OR GROUND WATER UNDER THE INFLUENCE OF SURFACE WATER SYSTEMS

PUBLIC WATER SYSTEM NAME: City of Corsicana
 PWS ID No.: 1750002

PLANT NAME OR NUMBER: Navarro Mills
 Month: April Year: 2011

Type of treatment: Conventional Unconventional
 Unconventional explain: _____

Note: Systems are required to run one TOC Sample Set every month. Additional space is provided for those systems that do additional sampling

Test No.	Test Date	Monthly TOC Sample Set			Actual % TOC Removed	Step 1 Required % Removal	Step 1 Removal Ratio	Optional data		COMPLIANCE REMOVAL RATIO
		Raw Alkalinity	Raw TOC	Treated TOC				Step 2 Required % Removal	Step 2 Removal Ratio	
		Enter the Sample Set results						calculated	calculated from matrix	
1	4/5	126	4.00	2.66	33.5	15	2.23			2.23
2										
3										
4										
5										
6										
7										
8										
9										
10										
11										
12										
13										
14										
15										
16										
17										
18										
19										
20										
21										
22										
23										
24										
25										
26										
27										
28										
29										
30										
31										
Avg		126.00	4.00	2.66	33.50		2.23			2.23
Max		126.00	4.00	2.66	33.50		2.23			2.23
Min		126.00	4.00	2.66	33.50		2.23			2.23

TOTAL ORGANIC CARBON (TOC) REMOVAL SUMMARY

TOC Summary					Monthly Compliance Ratio
Raw Water Alkalinity	Raw Water TOC	Treated Water TOC	TOC % Removal	ACC # used	
126	4.00	2.66	33.5	NA	2.23

I certify that I am familiar with the information contained in this report and that, to the best of my knowledge, the information is true, complete, and accurate.

Operator's Signature: Douglas W. [Signature] Certificate No. and Grade: WO0004220, A

Date: May 2, 2011

Submit the report by the 10th of the month following the reporting period to:
 TEXAS COMMISSION ON ENVIRONMENTAL QUALITY
 WATER SUPPLY DIVISION/PUBLIC DRINKING WATER SECTION (MC-155)
 P.O. BOX 13087, AUSTIN, TEXAS 78711-3087