

SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER
Summary Page

PUBLIC WATER
SYSTEM NAME: City of Corsicana

PLANT NAME
OR NUMBER: Navarro Mills

I certify that I am familiar with the information contained in this report and that,
to the best of my knowledge, the information is true, complete, and accurate.

PWS ID No.: 1750002
Report for
the Month of: March 2010

Operator's Signature: _____
Certificate No. & Grade: WO0004220, A Date: April 1, 2010

TREATMENT PLANT PERFORMANCE

Total number of turbidity readings: <u>179</u>	Number of 4-hour periods when plant was off-line: <u>7</u>
Number of readings above 0.10 NTU: <u>34</u>	Number of 4-hour periods when plant was on-line but turbidity data was not collected: <u>0</u>
Number of readings above 0.3 NTU: <u>0</u>	Number of days when plant was on-line but individual filter turbidity data was not collected: <u>0</u>
Number of readings above 0.5 NTU: <u>0</u>	Number of days with readings above 1.0 NTU: <u>0</u> (2)
Number of readings above 1.0 NTU: <u>0</u>	Number of days with readings above 5.0 NTU: <u>0</u> (3)
Maximum allowable turbidity level: <u>0.3</u>	
Percentage of readings above this limit: <u>0.0</u> % (1)	

Statistical
Summary

Maximum turbidity reading: <u>0.14</u> NTU	Average turbidity value: <u>0.10</u> NTU
Minimum turbidity reading: <u>0.07</u> NTU	Standard deviation: <u>0.015</u> NTU
CFE 95 th percentile value: <u>0.12</u> NTU	IFE 95 th percentile: <u>0.188</u> NTU

Number of days with a low CT for no more than 4.0 consecutive hours: <u>0</u>	Average log inactivation for Giardia: <u>NA</u>
Number of days with a low CT for more than 4.0 consecutive hours: <u>0</u> (4)	Average log inactivation for viruses: <u>NA</u>
	Number of days when profiling data was not collected: <u>31</u>
	Number of days when CT data was not collected: <u>31</u>

Minimum disinfectant residual required leaving the plant: 0.5 mg/L, measured as Total Chlorine

Number of days with a low residual for no more than 4.0 consecutive hours: <u>0</u>	Number of days when disinfectant residual leaving the plant was not properly monitored: <u>0</u>
Number of days with a low residual for more than 4.0 consecutive hours: <u>0</u> (5)	

DISTRIBUTION SYSTEM

Minimum disinfectant residual required in distribution system: <u>0.5</u> mg/L, measured as Total Chlorine	
Total number of readings this month: <u>61</u> (at least 31 required) (8)	Percentage of readings with a low residual this month: <u>0.0</u> % (6A)
Average disinfectant residual value: <u>2.40</u>	Percentage of readings with a low residual last month: <u>0.0</u> % (6B)
Number of readings with a low residual: <u>0</u>	
Number of readings with no detectable residual: <u>0</u>	

ADDITIONAL REPORTS & WORKSHEETS

The Page 1 Addendum (Public Notices) is required because there was at least one treatment technique or monitoring/reporting violation reported.

Additional report(s) for individual filter monitoring required:	<input checked="" type="radio"/> NONE	<input type="radio"/> Filter Profile	<input type="radio"/> Filter Assessment	<input type="radio"/> CPE
Additional report(s) for individual filter monitoring submitted:	<input checked="" type="radio"/> NONE	<input type="radio"/> Filter Profile (9)	<input type="radio"/> Filter Assessment (10)	<input type="radio"/> CPE (11)
No additional IFE Reports are required this month.				

SURFACE WATER MONTHLY OPERATING REPORT
TEXAS COMMISSION ON ENVIRONMENTAL QUALITY
WATER SUPPLY DIVISION/PUBLIC DRINKING WATER SECTION (MC-155)
P.O. BOX 13087, AUSTIN, TEXAS 78711-3087

SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER (cont.)
Summary Page Addendum (Violations and Public Notices)

PUBLIC WATER SYSTEM NAME: City of Corsicana

PLANT NAME OR NUMBER: Navarro Mills

PWS ID No.: 1750002

Month: March

Year: 2010

PUBLIC NOTICES

VIOLATION TYPE	DESCRIPTION OF VIOLATION	VIOLATION OCCURRED?	NOTICE TO TCEQ <input checked="" type="checkbox"/>	NOTICE TO CUSTOMER *		VIOLATION DATES
			DATE OF NOTICE	DATE OF NOTICE	PENDING	
TREATMENT TECHNIQUE	Were more than 5.0% of the turbidity readings above the acceptable level? - see (1) on the <i>Summary Page</i>	No				
	Were there any days with turbidity readings above 1.0 NTU? - see (2) on the <i>Summary Page</i>	No				
	Were there any days with turbidity readings above 5.0 NTU? - see (3) on the <i>Summary Page</i>	No				
	Were there any periods when the plant failed to meet the CT requirements for more than 4.0 consecutive hours? - see (4) on the <i>Summary Page</i>	No				
	Were there any periods when the residuals leaving the plant fell below the acceptable level for more than 4.0 consecutive hours? - see (5) on the <i>Summary Page</i>	No				
	Were more than 5.0% of the residuals in the distribution system below the acceptable level for two months in a row? - see (6A) and (6B) on the <i>Summary Page</i>	No				
MONITORING & REPORTING	Were there any days when the plant failed to report all of the required Combined Filter Effluent (CFE) turbidity readings? - see the <i>Turbidity Data Page</i>	No				
	Were there any days when the plant failed to report all the CT data needed to evaluate the level of microbial inactivation achieved? - see the <i>Disinfection Data Page</i>	Yes				1, 2, 3, 4, 5, 6, 7, 8, 9, 10, 11, 12, 13, 14, 15, 16, 17, 18, 19, 20, 21, 22, 23, 24, 25, 26, 27, 28, 29, 30, 31,
	Were there any days when the plant failed to report the minimum disinfectant residual entering the distribution system? - see the <i>Turbidity Data Page</i>	No				
	Did the system fail to collect enough samples in the distribution system to meet the minimum disinfectant monitoring requirements? - see (8) on the <i>Summary Page</i>	No				
	Were there any days when the plant failed to report the maximum individual filter effluent (IFE) turbidity level produced by each filter? - see the <i>Filter Data Page</i>	No				
	Were there any days when the plant failed to report the IFE turbidity level 4-hours after beginning a filter run? - see the <i>Filter Data Page</i>	No				
	Did the plant fail to submit a Filter Profile Report if one was required? - see (9) on the <i>Summary page</i>	No				
	Did the plant fail to submit a Filter Assessment Report if one was required? - see (10) on the <i>Summary Page</i>	No				
	Did the plant fail to submit a Comprehensive Performance Evaluation Request if one was required? - see (11) on the <i>Summary Page</i>	No				
Did the plant fail to collect at least one Total Organic Carbon sample set? - see <i>TOCMOR Page</i>	No					

Treatment technique violation notices are due no later than the end of the next business day. Please include a copy if possible.

* Copies of each Public Notice must accompany this report if they have already been issued.

SUBMITTED BY: _____

Certificate No. and Grade: WO0004220, A

Date: April 1, 2010

SURFACE WATER MONTHLY OPERATING REPORT
 FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES
 OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER (cont.)
Turbidity Data Page

PUBLIC WATER SYSTEM NAME: City of Corsicana

PLANT NAME OR NUMBER: Navarro Mills

PWS ID No.: 1750002

Connections: 10,732

Month: March Year: 2010

Population: 28,500

PERFORMANCE DATA																		
Date	Raw Water Pumpage (MGD)	Treated Water Pumpage (MGD)	RAW WATER ANALYSES		SETTLED WATER TURBIDITY (Mandatory Data)						FINISHED WATER QUALITY							
			NTU	Alk.	Basin No.						Turbidity						Lowest Residual	Time ^h
					1	2	3	4	5	6	NTU1	NTU2	NTU3	NTU4	NTU5	NTU6		
1	4.390	4.072	41	131	1.5	1.5	1.9	1.7	1.5	1.4	0.09	0.08	0.08	0.08	0.12	0.10	3.4	
2	4.370	4.947	39	128	1.5	1.7	1.8	1.8	1.6	1.5	0.09	0.09	0.08	0.08	0.09	0.09	3.2	
3	4.370	4.207	37	129	1.3	1.5	1.7	1.7	1.6	1.3	0.10	0.10	0.08	0.08	0.08	0.08	3.1	
4	4.620	4.310	33	131	1.1	1.2	1.5	1.9	1.3	1.1	0.09	0.09	0.08	0.09	0.10	0.09	3.1	
5	5.010	5.271	33	129	1.2	1.1	1.2	1.5	1.3	1.1	0.09	0.09	0.10	0.09	0.10	0.10	2.9	
6	4.920	4.050	30	130	1.2	1.1	1.4	1.3	1.2	1.1	x	x	0.08	0.10	0.09	0.08	2.6	
7	4.840	4.904	28	134	1.0	0.9	1.2	1.1	1.0	0.9	0.08	0.09	0.07	0.08	0.09	0.08	2.4	
8	4.840	4.187	31	136	1.0	0.9	1.1	1.0	1.0	1.0	0.09	0.08	0.10	0.09	0.09	0.09	3.2	
9	4.870	5.272	32	136	1.1	1.1	1.2	1.2	1.3	1.1	0.09	0.10	0.09	0.10	0.10	0.13	2.8	
10	4.890	5.243	23	135	1.1	1.1	1.3	1.3	1.1	1.1	0.10	0.10	0.07	0.08	0.07	0.07	3.0	
11	4.880	4.375	22	134	1.0	1.1	1.2	1.3	1.0	1.0	0.07	0.07	0.07	0.08	0.07	0.09	3.0	
12	5.060	5.021	25	133	0.8	0.9	0.9	1.1	1.0	0.9	x	x	0.09	0.08	0.09	0.10	3.0	
13	4.910	4.205	22	135	0.8	0.8	0.9	1.0	0.8	0.8	0.11	0.12	0.10	0.10	0.11	0.10	2.9	
14	4.500	5.269	20	135	0.6	0.7	0.8	0.9	0.6	0.6	0.10	0.12	0.09	0.09	0.11	0.10	2.8	
15	4.400	4.111	16	136	0.8	0.7	0.9	0.9	1.0	0.9	0.11	0.10	0.10	0.09	0.10	0.10	2.8	
16	4.560	4.130	17	135	0.7	0.8	0.9	1.1	1.1	0.9	0.10	0.09	0.10	0.10	0.11	0.12	2.7	
17	4.630	5.020	18	141	0.6	0.7	0.8	0.9	0.9	0.7	0.12	0.11	0.09	0.10	0.09	0.09	2.4	
18	4.680	4.866	20	141	0.7	0.9	1.0	1.3	0.9	0.9	0.09	0.10	0.10	0.11	0.10	0.09	2.5	
19	4.760	4.357	22	139	0.8	0.8	1.1	1.1	1.0	0.9	0.10	0.11	0.11	0.10	0.11	0.11	2.5	
20	4.790	4.478	20	136	1.0	1.1	1.1	1.3	1.1	1.0	x	x	0.11	0.13	0.13	0.13	2.5	
21	4.940	4.975	25	136	0.8	0.9	0.9	1.2	0.9	0.8	0.12	0.12	0.12	0.12	0.12	0.13	2.6	
22	4.890	4.839	27	137	1.0	0.9	1.0	0.9	1.1	1.0	0.14	0.13	x	0.10	0.09	0.11	2.3	
23	4.840	4.181	27	138	1.0	1.3	1.3	1.6	1.2	1.1	0.10	0.10	0.09	0.09	0.10	0.10	2.5	
24	4.800	4.811	23	138	0.8	1.0	1.1	1.1	1.1	0.9	0.10	0.09	0.09	0.10	0.10	0.10	2.5	
25	4.870	4.680	23	142	1.8	1.2	1.2	2.0	1.0	0.8	0.11	0.10	0.10	0.10	0.09	0.13	2.6	
26	4.960	4.927	21	141	1.2	0.9	0.9	1.1	0.9	0.7	0.12	0.11	0.07	0.08	0.08	0.08	2.3	
27	4.910	4.409	20	140	1.0	1.0	1.1	1.5	0.9	0.9	0.08	0.08	0.08	0.07	0.08	0.09	2.2	
28	4.840	4.728	22	139	0.8	1.0	1.2	1.6	1.0	0.9	0.08	0.07	0.07	0.08	0.10	0.09	2.3	
29	4.860	4.121	23	140	0.8	1.0	1.0	1.0	0.9	1.0	0.09	0.09	0.09	0.10	0.10	0.09	2.3	
30	4.950	4.915	25	138	1.0	1.0	1.3	1.8	1.1	1.0	0.08	0.08	0.08	0.09	0.10	0.10	2.1	
31	4.960	4.470	27	139	1.0	1.1	1.4	1.4	1.3	1.2	0.08	0.09	0.09	0.10	0.10	0.10	2.3	
Total	148.110	143.351																
Avg	4.778	4.624																
Max	5.060	5.272																
Min	4.370	4.050																

NOTE: ONLY use the "Time*" column to show the length of time that the disinfectant residual entering the distribution system fell below the acceptable level.

SUBMITTED BY: _____ Certificate No. and Grade: WO0004220, A Date: April 1, 2010

SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER (cont.)
Filter Data Page

PUBLIC WATER
SYSTEM NAME: City of Corsicana
PWS ID No.: 1750002

PLANT NAME
OR NUMBER: Navarro Mills
Month: March Year: 2010

PERFORMANCE DATA																				
Date	INDIVIDUAL FILTER TURBIDITY																			
	Filter No. 1		Filter No. 2		Filter No. 3		Filter No. 4		Filter No. 5		Filter No. 6		Filter No. 7		Filter No. 8		Filter No. 9		Filter No. 10	
	Max	4 Hrs	Max	4 Hrs	Max	4 Hrs	Max	4 Hrs	Max	4 Hrs	Max	4 Hrs	Max	4 Hrs	Max	4 Hrs	Max	4 Hrs	Max	4 Hrs
1	x	x	0.12	x	0.09	x	0.10	x	0.11	x	x	x								
2	x	x	0.11	x	0.09	x	0.10	x	0.10	x	0.22	0.12								
3	0.22	0.14	0.10	x	0.19	0.10	0.25	0.12	0.09	x	0.11	x								
4	0.11	x	x	x	0.09	x	0.11	x	x	x	0.09	x								
5	0.10	x	x	x	0.09	x	0.10	x	x	x	0.09	x								
6	0.18	x	x	x	0.08	x	0.13	x	0.17	0.11	0.09	x								
7	0.17	0.12	0.17	0.12	0.08	x	0.11	x	0.11	x	0.17	0.11								
8	0.12	x	0.11	x	x	x	x	x	0.10	x	0.10	x								
9	0.07	x	0.06	x	x	x	x	x	0.06	x	0.05	x								
10	0.05	x	0.09	x	x	x	0.10	0.08	0.05	x	0.06	x								
11	0.22	x	0.11	0.09	0.08	0.07	0.09	x	0.07	0.05	0.07	x								
12	x	x	0.09	x	0.08	x	0.08	x	0.10	x	x	x								
13	x	x	0.09	x	0.09	x	0.08	x	0.09	x	x	x								
14	x	x	0.08	x	0.08	x	0.07	x	0.09	x	x	x								
15	0.11	0.11	0.09	x	0.09	x	0.12	0.10	0.10	x	0.09	0.07								
16	0.10	x	x	x	0.12	0.11	0.10	x	x	x	0.08	x								
17	0.08	x	x	x	0.09	x	0.08	x	x	x	0.10	x								
18	0.12	x	x	x	0.09	x	0.08	x	x	x	0.11	x								
19	0.13	0.12	0.14	0.13	0.09	x	0.08	x	0.10	0.08	0.12	x								
20	0.12	x	0.10	x	x	x	0.13	0.11	0.12	x	x	x								
21	0.10	x	0.09	x	x	x	0.10	x	0.49	x	0.09	0.09								
22	0.09	x	0.08	x	x	x	0.08	x	x	x	0.10	x								
23	0.07	x	0.07	x	0.11	0.10	0.07	x	0.08	0.07	0.11	x								
24	x	x	0.14	0.11	0.09	x	0.06	x	0.08	x	0.10	x								
25	x	x	0.09	x	0.08	x	x	x	0.07	x	0.08	x								
26	0.12	0.11	0.08	x	0.08	x	x	x	0.40	x	x	x								
27	0.08	x	0.07	x	0.06	x	0.09	0.09	0.13	x	x	x								
28	0.07	x	0.06	x	0.09	0.09	0.08	x	0.13	x	0.31	0.07								
29	0.07	x	x	x	0.09	x	0.07	x	x	x	0.08	x								
30	0.08	x	x	x	0.09	x	0.08	x	0.09	0.09	0.11	x								
31	x	x	0.12	0.11	0.09	x	0.08	x	0.12	x	0.10	x								

SUMMARY & COMPLIANCE ACTIONS	Criteria	Filter No.										Plant		
		1	2	3	4	5	6	7	8	9	10			
	Number of days with event(s) above 0.5 NTU at 4.0 hrs this month	0	0	0	0	0	0							
	Number of days with event(s) above 1.0 NTU this month	0	0	0	0	0	0							
	Number of days with event(s) above 1.0 NTU last month	0	0	0	0	0	0							
	Number of days with event(s) above 1.0 NTU two months ago	0	0	0	0	0	0							
	Total number of days with event(s) above 1.0 NTU in three months	0	0	0	0	0	0							
	Number of days with event(s) above 2.0 NTU this month											0		
	Number of days with event(s) above 2.0 NTU last month											0		
	Does the filter/plant have an approved Corrective Action Plan?	N	N	N	N	N	N							N
	Is the plant required to submit a Filter Profile Report?	N	N	N	N	N	N							
	Is the plant required to submit a Filter Assessment Report?	N	N	N	N	N	N							
	Is the plant required to submit a Request for Compliance CPE?											N		

SUBMITTED BY: _____ Certificate No. _____ and Grade: WO0004220, A Date: April 1, 2010

SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER (cont.)

Disinfection Data Page

PUBLIC WATER SYSTEM NAME: City of Corsicana
PWS ID No.: 1750002

PLANT NAME OR NUMBER: Navarro Mills
Month: March Year: 2010

DISINFECTION PROCESS PARAMETERS							
APPROVED CT STUDY PARAMETERS					PERFORMANCE STANDARDS		
Parameters	Disinfection Zones				Log Inactivations		
	D1	D2	D3	D4	D5	Giardia lamblia Cysts	Viruses
Flow Rate (MGD)	20.250	20.250	20.250			0.5	2.0
T ₁₀ (minutes)	109.1	13.0	100.0				

PERFORMANCE DATA									
DISINFECTION PROCESS DATA									
Date	Disinfectant	C (mg/L)	Flow (MGD)	Temp (°C)	pH	Giardia Log	Virus Log	Inact. Ratio	Time
1	NA D1								
	FCL D2	3.7	4.400	9.0	7.4				
	CLA D3	3.5	4.400	10.0	7.4				
	D4								
	D5								
2	NA D1								
	FCL D2	3.3	4.600	9.0	7.4				
	CLA D3	3.3	4.600	10.0	7.4				
	D4								
	D5								
3	NA D1								
	FCL D2	3.3	4.600	9.0	7.4				
	CLA D3	3.2	4.600	10.0	7.4				
	D4								
	D5								
4	NA D1								
	FCL D2	2.9	5.300	10.0	7.6				
	CLA D3	3.3	5.300	10.0	7.6				
	D4								
	D5								
5	NA D1								
	FCL D2	2.8	5.400	10.0	7.6				
	CLA D3	3.3	5.400	10.0	7.6				
	D4								
	D5								
6	NA D1								
	FCL D2	3.1	5.400	11.0	7.8				
	CLA D3	2.9	5.400	11.0	7.6				
	D4								
	D5								
7	NA D1								
	FCL D2	2.7	5.000	11.0	7.9				
	CLA D3	2.4	5.000	11.0	7.8				
	D4								
	D5								
8	NA D1								
	FCL D2	2.8	4.900	10.0	7.6				
	CLA D3	3.5	4.900	11.0	7.7				
	D4								
	D5								

PERFORMANCE DATA									
DISINFECTION PROCESS DATA									
Date	Disinfectant	C (mg/L)	Flow (MGD)	Temp (°C)	pH	Giardia Log	Virus Log	Inact. Ratio	Time
9	NA D1								
	FCL D2	3.1	5.000	11.0	7.7				
	CLA D3	2.9	5.000	11.0	7.7				
	D4								
	D5								
10	NA D1								
	FCL D2	2.9	5.000	12.0	7.6				
	CLA D3	3.1	5.000	12.0	7.7				
	D4								
	D5								
11	NA D1								
	FCL D2	3.3	5.100	13.0	7.5				
	CLA D3	3.0	5.100	13.0	7.6				
	D4								
	D5								
12	NA D1								
	FCL D2	2.3	5.200	14.0	7.3				
	CLA D3	3.4	5.200	14.0	7.4				
	D4								
	D5								
13	NA D1								
	FCL D2	2.3	5.000	14.0	7.4				
	CLA D3	3.1	5.000	14.0	7.4				
	D4								
	D5								
14	NA D1								
	FCL D2	2.7	4.900	14.0	7.4				
	CLA D3	2.9	4.900	14.0	7.4				
	D4								
	D5								
15	NA D1								
	FCL D2	2.2	4.700	14.0	7.3				
	CLA D3	3.0	4.700	14.0	7.3				
	D4								
	D5								
16	NA D1								
	FCL D2	2.5	4.700	14.0	7.3				
	CLA D3	2.8	4.700	14.0	7.3				
	D4								
	D5								

NOTE: = ONLY use the "Time=" column to show the length of time that the total inactivation ratio was less than 1.00.

SUBMITTED BY: _____ Certificate No. and Grade: WO0004220, A Date: April 1, 2010

MONTHLY TOTAL ORGANIC CARBON REMOVAL REPORT (TOCMOR)

FOR SURFACE WATER OR GROUND WATER UNDER THE INFLUENCE OF SURFACE WATER SYSTEMS

PUBLIC WATER SYSTEM NAME: City of Corsicana
 PWS ID No.: 1750002
 Type of treatment: Conventional Unconventional explain: _____

PLANT NAME OR NUMBER: Navarro Mills
 Month: March Year: 2010

Note: Systems are required to run one TOC Sample Set every month. Additional space is provided for those systems that do additional sampling

Test No.	Test Date	Monthly TOC Sample Set			Actual % TOC Removed	Step 1 Required Removal %	Step 1 Removal Ratio	Optional data		COMPLIANCE REMOVAL RATIO
		Raw Alkalinity	Raw TOC	Treated TOC				Step 2 Required % Removal	Step 2 Removal Ratio	
		Enter the Sample Set results						calculated	calculated from matrix	
1	3/2	123	4.78	3.49	27.0	25	1.08			1.08
2										
3										
4										
5										
6										
7										
8										
9										
10										
11										
12										
13										
14										
15										
16										
17										
18										
19										
20										
21										
22										
23										
24										
25										
26										
27										
28										
29										
30										
31										
Avg		123.00	4.78	3.49	26.99		1.08			1.08
Max		123.00	4.78	3.49	26.99		1.08			1.08
Min		123.00	4.78	3.49	26.99		1.08			1.08

TOTAL ORGANIC CARBON (TOC) REMOVAL SUMMARY

TOC Summary					Monthly Compliance Ratio
Raw Water Alkalinity	Raw Water TOC	Treated Water TOC	TOC % Removal	ACC # used	
123	4.78	3.49	27.0	NA	1.08

I certify that I am familiar with the information contained in this report and that, to the best of my knowledge, the information is true, complete, and accurate.

Operator's Signature: _____ Certificate No. and Grade: WO0004220, A

Date: April 1, 2010

Submit the report by the 10th of the month following the reporting period to:
 TEXAS COMMISSION ON ENVIRONMENTAL QUALITY
 WATER SUPPLY DIVISION/PUBLIC DRINKING WATER SECTION (MC-155)
 P.O. BOX 13087, AUSTIN, TEXAS 78711-3087

TOC ALTERNATIVE COMPLIANCE CRITERIA REPORT
FOR SURFACE WATER OR GROUND WATER UNDER THE INFLUENCE OF SURFACE WATER SYSTEMS

PUBLIC WATER SYSTEM NAME: City of Corsicana
PWS ID No.: 1750002

PLANT NAME OR NUMBER: Navarro Mills
Month: March Year: 2010

This Alternative Compliance Criteria (ACC) Report is being submitted to request the following ACC: (check one)
(Before you can begin entering data, you must put an "X" in the box that shows the number of the Alternative Compliance Criteria you are applying for.)

#1 #2 #3 #4 #5 #6 #7 #8

ACC #1	Source Water TOC less than 2.0? (either based on most recent month's data OR calculated quarterly as a running annual average)												
	Current Month TOC	Q1			Q2			Q3			Q4		
	4.78	04/2009	05/2009	06/2009	07/2009	08/2009	09/2009	10/2009	11/2009	12/2009	01/2010	02/2010	03/2010
	Average Raw Water TOC Quarterly Average RAA												

ACC #2	Treated Water TOC less than 2.0? (either based on most recent month's data OR calculated quarterly as a running annual average)												
	Current Month TOC	Q1			Q2			Q3			Q4		
	3.49	04/2009	05/2009	06/2009	07/2009	08/2009	09/2009	10/2009	11/2009	12/2009	01/2010	02/2010	03/2010
	Average Treated Water TOC Quarterly Average RAA												

ACC #3	Source Water TOC less than 4.0? (calculated quarterly as a running annual average) AND Source water alkalinity over 60 mg/L (as CaCO3)? (calculated quarterly as a running annual average)												
	Average Raw Water TOC Quarterly Average RAA	Q1			Q2			Q3			Q4		
		04/2009	05/2009	06/2009	07/2009	08/2009	09/2009	10/2009	11/2009	12/2009	01/2010	02/2010	03/2010
	Average Raw Water Alkalinity Quarterly Average RAA												

AND TTHM and HAA5 no greater than 0.040 mg/L and 0.030 mg/L, respectively? (calculated as a running annual average of quarterly averages)
TTHM RAA for the 4 quarters that end March 2010: mg/L HAA5 RAA for the 4 quarter that end March 2010: mg/L

ACC #4	TTHM and HAA5 no greater than 0.040 mg/L and 0.030 mg/L, respectively? (calculated as a running annual average of quarterly averages)												
	TTHM RAA for the 4 quarters that end March 2010: <input type="text"/> mg/L						HAA5 RAA for the 4 quarters that end March 2010: <input type="text"/> mg/L						
	AND only chlorine is used in the whole plant and distribution system. Chlorine only?: <input type="text"/>												

I certify that for the last 12 months, only free chlorine was used as a disinfectant for primary disinfection and for maintenance of a residual in the distribution system.

Certified Operators Signature/ Certificate Number / Date

ACC #5	Source water SUVA less than or equal to 2.0 L/mg-m? (either based on most recent month's data OR calculated quarterly as a running annual average) <small>(Source water SUVA is the dissolved organic carbon concentration divided by the ultraviolet light absorption at 254 nanometers in the source water before any treatment of any kind. Measure monthly.)</small>												
	Current Month SUVA	Q1			Q2			Q3			Q4		
		04/2009	05/2009	06/2009	07/2009	08/2009	09/2009	10/2009	11/2009	12/2009	01/2010	02/2010	03/2010
	Monthly Raw Water SUVA Quarterly Average RAA												

ACC #6	Treated water SUVA less than or equal to 2.0 L/mg-m? (either based on most recent month's data OR calculated quarterly as a running annual average) <small>(Treated water SUVA is the dissolved organic carbon concentration divided by the ultraviolet light absorption at 254 nanometers in the finished water before any disinfection of any kind, or measured using a finished water SUVA jar test. (See the Instructions worksheet for more info.) Measure monthly.)</small>												
	Treated water SUVA measured:	I certify that an oxidant was used upstream of the Treated Water TOC monitoring point during the period for which treated water SUVA data is reported.											
		_____ Certified Operators Signature / Certificate Number / Date											
	Current Month SUVA	Q1			Q2			Q3			Q4		

ACC #7	Treated water alkalinity less than 60 mg/L (as CaCO3)? (softening practiced) (either based on most recent month's data OR calculated quarterly as a running annual average)												
	Current Month ALK	Q1			Q2			Q3			Q4		
		04/2009	05/2009	06/2009	07/2009	08/2009	09/2009	10/2009	11/2009	12/2009	01/2010	02/2010	03/2010
	Monthly Treated Alkalinity Quarterly Average RAA												

ACC #8	Magnesium hardness removal greater than or equal to 10 mg/L (as CaCO3)? (softening practiced) (either based on most recent month's data OR calculated quarterly as a running annual average)												
	Current Month Mg Hardness	Q1			Q2			Q3			Q4		
	Raw	04/2009	05/2009	06/2009	07/2009	08/2009	09/2009	10/2009	11/2009	12/2009	01/2010	02/2010	03/2010
	Treated												

I certify that I am familiar with the information contained in this report and that, to the best of my knowledge, the information is true, complete, and accurate.

Operator's Signature: _____ Certificate No. and Grade: WO0004220, A Date: April 1, 2010

STEP 2 JAR TEST REPORT

FOR SURFACE WATER OR GROUND WATER UNDER THE INFLUENCE OF SURFACE WATER SYSTEMS

PUBLIC WATER
 SYSTEM NAME: City of Corsicana
 PWS ID No.: 1750002


PLANT NAME
 OR NUMBER: Navarro Mills
 DATE OF JAR TEST: _____

PLANT CONDITIONS								
RAW WATER SOURCE(s)	COAGULANT		COAGULANT AID		FLOC AID		pH ADJUSTMENT	
	Type	Dose (mg/L)	Type	Dose (mg/L)	Type	Dose (mg/L)	Type	Dose (mg/L)

STEP 2 JAR TEST PARAMETERS									
COAGULANT		BASE		JAR SIZE	JAR TEST CONDITIONS				
Type	Stock Solution Concentration (g/L)	Type	Stock Solution Concentration (g/L)	Volume (liters)	Rapid Mix		Flocculation		Settling
					Speed (rpm)	Duration (minutes)	Speed (rpm)	Duration (minutes)	Duration (minutes)

JAR TEST RESULTS									
Jar No.	COAGULANT		BASE		Alkalinity (mg/L as CaCO ₃)	pH	TOC (mg/L)	Incremental TOC Removal (mg/L TOC removed per 10 mg/L of alum)	Cumulative TOC Removal (%)
	Dose (Alum eq.) (mg/L)	Volume (mL)	Dose (mg/L)	Volume (mL)					
RAW									
1					Target pH (based on raw water alkalinity)				
2									
3									
4									
5									
6									
7									
8									
9									
10									
11									
12									

Has the TCEQ approved this source as "Not Amenable" to Treatment even though Target pH was not reached? If "yes", provide the date of the TCEQ letter or e-mail.		TOC, % Removal at Apparent PODR:
---	--	----------------------------------



I certify that I am familiar with the information contained in this report and that, to the best of my knowledge, the information is true, complete, and accurate.

Operator's Signature: _____

Certificate No. _____
 and Grade: WO0004220, A