

SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER

Summary Page

PUBLIC WATER SYSTEM NAME: City of Corsicana

PLANT NAME OR NUMBER: Navarro Mills

I certify that I am familiar with the information contained in this report and that, to the best of my knowledge, the information is true, complete, and accurate.

PWS ID No.: 1750002

Operator's Signature: _____

Report for the Month of: July 2009

Certificate No. & Grade: WO0004220 A

Date: August 3, 2009

TREATMENT PLANT PERFORMANCE

Total number of turbidity readings: <u>176</u>	Number of 4-hour periods when plant was off-line: <u>10</u>								
Number of readings above 0.10 NTU: <u>90</u>	Number of 4-hour periods when plant was on-line but turbidity data was not collected: <u>0</u>								
Number of readings above 0.3 NTU: <u>2</u>									
Number of readings above 0.5 NTU: <u>0</u>									
Number of readings above 1.0 NTU: <u>0</u>									
Maximum allowable turbidity level: <u>0.3</u>	Number of days with readings above 1.0 NTU: <u>0</u> (2)								
Percentage of readings above this limit: <u>1.1</u> % (1)	Number of days with readings above 5.0 NTU: <u>0</u> (3)								
<table style="width: 100%; border: none;"> <tr> <td style="width: 25%; border: none;">Statistical Summary</td> <td style="width: 25%; border: none;">Maximum turbidity reading: <u>0.40</u> NTU</td> <td style="width: 25%; border: none;">Average turbidity value: <u>0.14</u> NTU</td> <td style="width: 25%; border: none;"></td> </tr> <tr> <td style="border: none;"></td> <td style="border: none;">Minimum turbidity reading: <u>0.06</u> NTU</td> <td style="border: none;">Standard deviation: <u>0.077</u> NTU</td> <td style="border: none;"></td> </tr> </table>		Statistical Summary	Maximum turbidity reading: <u>0.40</u> NTU	Average turbidity value: <u>0.14</u> NTU			Minimum turbidity reading: <u>0.06</u> NTU	Standard deviation: <u>0.077</u> NTU	
Statistical Summary	Maximum turbidity reading: <u>0.40</u> NTU	Average turbidity value: <u>0.14</u> NTU							
	Minimum turbidity reading: <u>0.06</u> NTU	Standard deviation: <u>0.077</u> NTU							
Additional report(s) for individual filter monitoring required: <input checked="" type="radio"/> NONE <input type="radio"/> Filter Profile <input type="radio"/> Filter Assessment <input type="radio"/> CPE Additional report(s) for individual filter monitoring submitted: <input checked="" type="radio"/> NONE <input type="radio"/> Filter Profile <input type="radio"/> Filter Assessment <input type="radio"/> CPE									
#NAME? Number of days when plant was on-line but individual filter turbidity data was not collected: <u>0</u>									
Number of days with a low CT for no more than 4.0 consecutive hours: <u>0</u> Number of days with a low CT for more than 4.0 consecutive hours: <u>0</u> (4)									
Average log inactivation for Giardia: <u>NA</u> Average log inactivation for viruses: <u>NA</u> Number of days when profiling data was not collected: <u>31</u> Number of days when CT data was not collected: <u>31</u>									
Minimum disinfectant residual required leaving the plant: <u>0.2</u> mg/L <input type="radio"/> Free Chlorine <input checked="" type="radio"/> Total Chlorine									
Number of days with a low residual for no more than 4.0 consecutive hours: <u>0</u> Number of days with a low residual for more than 4.0 consecutive hours: <u>0</u> (5)									
Number of days when disinfectant residual leaving the plant was not properly monitored: <u>0</u>									

DISTRIBUTION SYSTEM

Minimum disinfectant residual required in distribution system: <u>0.2</u> mg/L <input type="radio"/> Free Chlorine <input checked="" type="radio"/> Total Chlorine	
Total number of readings this month: <u>61</u>	Percentage of readings with a low residual this month: <u>0.0</u> % (6A)
Average disinfectant residual value: <u>1.43</u>	Percentage of readings with a low residual last month: <u>0.0</u> % (6B)
Number of readings with a low residual: <u>0</u>	
Number of readings with no detectable residual: <u>0</u>	

PUBLIC NOTIFICATION

TREATMENT TECHNIQUE VIOLATIONS	YES/NO	If YES, date when notice was given to:	
		COMMISSIONERS	CUSTOMERS*
Were more than 5.0% of the turbidity readings above the acceptable level? - see (1) above	No		
Were there any days with turbidity readings above 1.0 NTU? - see (2) above	No		
Were there any days with turbidity readings above 5.0 NTU? - see (3) above	No		
Were there any periods when the plant failed to meet the CT requirements for more than 4.0 consecutive hours? - see (4) above	No		
Were there any periods when the residuals leaving the plant fell below the acceptable level for more than 4.0 consecutive hours? - see (5) above	No		
Were more than 5.0% of the residuals in the distribution system below the acceptable level for two months in a row? - see (6A) and (6B) above	No		

Due by the end of the next business day.

* Copies of each Public Notice must accompany this report.

Submit the report by the 10th of the month following the reporting period to:

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY
WATER SUPPLY DIVISION/PUBLIC DRINKING WATER SECTION (MC-155)
P.O. BOX 13087, AUSTIN, TEXAS 78711-3087

SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER (cont.)

Turbidity Data Page

PUBLIC WATER SYSTEM NAME: City of Corsicana

PLANT NAME OR NUMBER: Navarro Mills

PWS ID No.: 1750002

Connections: 11,050

Month: July Year: 2009

Population: 28,500

PERFORMANCE DATA																		
Date	Raw Water Pumpage (MGD)	Treated Water Pumpage (MGD)	RAW WATER ANALYSES		SETTLED WATER TURBIDITY (Optional Data)						FINISHED WATER QUALITY							
			NTU	Aik.	Basin No.						Turbidity						Lowest Residual	Time
					1	2	3	4	5	6	NTU1	NTU2	NTU3	NTU4	NTU5	NTU6		
1	6.800	6.969	21	97	0.6	0.6	0.6	0.6	0.7	0.5	0.10	X	0.09	0.10	0.11	0.17	2.7	
2	9.160	8.927	18	95	0.5	0.5	0.5	0.5	0.5	0.5	0.17	0.18	0.18	0.19	0.20	0.18	2.5	
3	9.180	9.243	21	99	0.6	0.7	0.6	0.6	0.6	0.6	0.17	0.17	0.13	0.12	0.11	0.10	2.6	
4	9.170	8.605	21	100	0.5	0.5	0.5	0.5	0.5	0.5	0.10	0.12	0.12	0.14	0.12	0.11	3.1	
5	8.410	8.057	24	100	0.9	1.3	1.1	1.2	1.1	1.3	0.10	0.10	0.10	0.11	0.10	0.10	3.1	
6	6.780	6.592	20	99	0.9	0.7	0.8	0.6	0.8	0.5	0.09	0.07	0.07	0.08	0.08	0.08	1.9	
7	4.930	4.662	20	97	0.6	0.7	0.5	0.6	0.5	0.6	0.07	0.07	0.07	0.08	0.08	0.10	2.6	
8	7.850	6.274	16	98	0.6	0.6	0.6	0.6	0.5	0.6	0.07	0.07	0.09	0.11	0.13	0.14	2.6	
9	6.990	6.927	16	101	0.5	0.5	0.5	0.6	0.5	0.5	0.16	0.18	0.15	0.13	0.12	0.12	2.6	
10	8.550	7.719	22	100	0.8	0.8	0.9	0.8	0.8	0.8	0.11	0.12	0.13	0.11	0.11	0.12	3.0	
11	6.450	6.875	16	97	1.9	1.9	1.6	1.7	2.1	1.7	X	X	0.09	0.13	0.20	0.25	2.6	
12	8.650	7.817	23	100	1.1	1.0	0.9	1.0	0.8	1.0	0.26	0.30	0.32	0.29	0.29	0.23	2.5	
13	6.440	7.041	16	92	1.0	0.9	1.0	1.0	1.0	1.0	X	X	0.18	0.20	0.21	0.23	2.6	
14	8.130	8.340	19	94	1.0	1.0	1.2	1.2	1.2	1.2	0.25	0.25	0.31	0.31	0.29	0.31	2.6	
15	8.370	8.131	20	94	1.4	1.3	1.5	1.4	1.5	1.3	0.28	0.33	0.23	0.32	0.27	0.29	2.2	
16	9.090	8.160	23	99	1.1	1.1	1.0	1.2	1.2	1.1	0.40	0.38	0.30	0.27	0.26	0.21	2.6	
17	7.560	8.134	28	101	0.7	0.7	0.7	0.7	0.6	0.7	0.19	0.20	0.20	0.24	0.19	0.17	2.7	
18	7.140	6.714	20	99	0.8	1.1	0.6	0.6	0.7	0.7	X	X	0.17	0.26	0.26	0.25	2.2	
19	9.090	8.346	20	102	0.5	0.5	0.4	0.4	0.4	0.4	0.22	0.17	0.13	0.11	0.11	0.08	2.4	
20	7.290	6.603	24	101	0.6	0.5	0.5	0.4	0.5	0.4	0.08	0.07	0.07	0.07	0.07	0.07	2.5	
21	5.070	4.710	22	102	0.6	0.8	0.5	0.6	0.5	0.6	0.07	0.07	0.07	0.07	0.07	0.08	2.6	
22	7.070	5.955	30	100	0.5	0.4	0.4	0.4	0.3	0.4	0.07	0.08	0.08	0.09	0.07	0.08	2.2	
23	8.680	7.560	34	97	0.5	0.8	0.4	0.5	0.6	0.4	0.10	0.13	0.09	0.08	0.07	0.10	2.7	
24	5.140	5.120	33	101	0.5	0.5	0.5	0.5	0.5	0.4	0.09	0.08	0.06	0.06	0.09	0.09	2.5	
25	6.450	6.104	27	103	0.5	0.5	0.4	0.4	0.3	0.4	0.06	0.07	0.06	0.07	0.06	0.06	2.4	
26	9.120	8.621	31	103	0.5	0.4	0.4	0.4	0.4	0.4	0.07	0.07	0.07	0.08	0.06	0.06	2.0	
27	7.670	6.246	45	102	0.6	0.5	0.5	0.5	0.5	0.4	0.07	0.08	0.07	0.07	0.09	0.08	2.9	
28	4.080	4.749	35	101	0.6	0.6	0.5	0.6	0.5	0.6	0.07	X	0.06	0.07	0.07	0.08	2.5	
29	7.610	6.517	31	103	0.7	0.6	0.6	0.5	0.5	0.5	0.09	0.09	0.07	0.09	0.11	0.13	2.2	
30	6.660	5.735	27	101	0.8	0.8	0.8	0.7	0.7	0.7	0.15	0.15	0.12	0.11	0.11	0.14	2.4	
31	5.550	5.315	29	100	0.4	0.5	0.5	0.5	0.5	0.5	X	X	0.10	0.10	0.10	0.16	2.0	
Total	229.130	216.768																
Avg	7.391	6.993																
Max	9.180	9.243																
Min	4.080	4.662																

NOTE: ONLY use the "Time" column to show the length of time that the disinfectant residual entering the distribution system fell below the acceptable level.

SUBMITTED BY: _____ Certificate No. and Grade: WO0004220 A Date: August 3, 2009

SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER (cont.)

Filter Data Page

PUBLIC WATER
SYSTEM NAME: City of Corsicana
PWS ID No.: 1750002

PLANT NAME
OR NUMBER: Navarro Mills
Month: July Year: 2009

PERFORMANCE DATA																				
INDIVIDUAL FILTER TURBIDITY																				
Date	Filter No. 1		Filter No. 2		Filter No. 3		Filter No. 4		Filter No. 5		Filter No. 6		Filter No. 7		Filter No. 8		Filter No. 9		Filter No. 10	
	Max	4 Hrs	Max	4 Hrs																
1	0.32	X	0.26	X	0.27	X	0.15	X	0.22	X	0.24	X								
2	0.29	X	0.25	X	0.24	X	0.22	X	0.23	X	0.28	X								
3	0.20	X	0.30	0.15	0.16	X	0.16	X	0.22	0.16	0.22	0.22								
4	0.38	0.19	0.26	0.16	0.30	0.15	0.31	0.21	0.19	X	0.22	X								
5	0.20	X	0.18	X	0.14	X	0.16	X	0.14	X	0.22	X								
6	0.12	X	0.11	X	0.08	X	0.10	X	0.09	X	0.22	X								
7	X	X	0.14	X	0.11	X	0.13	X	0.11	X	0.22	X								
8	0.16	X	0.15	X	0.13	X	0.30	0.27	0.32	0.23	0.13	0.13								
9	0.20	X	X	X	0.23	0.20	0.22	X	0.15	X	0.13	X								
10	0.16	X	0.26	0.26	0.16	X	0.14	X	0.14	X	0.20	X								
11	0.55	0.54	0.62	X	0.45	X	0.41	X	0.37	X	0.53	X								
12	0.52	X	0.41	X	0.59	0.23	0.38	X	0.49	0.43	0.87	0.52								
13	0.37	X	0.50	0.40	0.33	X	0.42	0.31	0.33	X	0.47	X								
14	0.64	0.50	0.50	X	0.34	X	0.44	X	0.33	X	0.47	X								
15	0.57	X	0.52	X	0.80	0.48	0.46	X	0.67	0.49	0.69	0.54								
16	0.41	X	0.64	0.28	0.45	X	0.35	X	0.44	X	0.58	X								
17	0.38	0.21	0.52	0.31	0.33	X	0.42	0.30	0.29	X	0.40	X								
18	0.44	X	0.35	X	0.62	0.31	0.37	X	0.50	0.22	0.40	X								
19	0.17	X	0.16	X	0.16	X	0.16	X	0.21	X	0.40	0.11								
20	0.12	X	0.33	0.13	0.08	X	0.11	X	0.11	X	0.14	X								
21	0.12	X	X	X	0.09	X	X	X	0.11	X	0.14	X								
22	0.21	0.20	0.20	X	0.19	0.14	0.16	X	0.14	X	0.14	X								
23	0.14	X	0.12	X	0.11	X	0.17	0.16	0.22	0.12	0.17	0.11								
24	0.09	X	0.08	X	0.06	X	X	X	X	X	0.13	X								
25	0.10	X	0.10	X	0.07	X	X	X	0.16	X	0.13	X								
26	0.11	X	0.14	0.13	0.07	X	0.16	X	0.21	X	0.12	X								
27	0.21	0.14	0.12	X	X	X	0.10	X	0.11	X	0.10	X								
28	0.16	X	0.16	X	X	X	0.12	X	0.14	X	X	X								
29	0.19	X	0.17	X	0.23	0.02	0.15	X	0.28	0.22	0.27	0.25								
30	0.17	X	0.17	X	0.18	X	0.21	0.17	0.21	X	0.19	X								
31	0.23	X	0.21	X	0.23	X	0.27	X	0.28	X	0.24	X								

SUMMARY & COMPLIANCE ACTIONS	Criteria										Plant	
	Filter No.											
	1	2	3	4	5	6	7	8	9	10		
	Number of days with event(s) above 0.5 NTU at 4.0 hrs this month											0
	Number of days with event(s) above 1.0 NTU this month											0
	Number of days with event(s) above 1.0 NTU last month											0
	Number of days with event(s) above 1.0 NTU two months ago											0
	Total number of days with event(s) above 1.0 NTU in three months											0
	Number of days with event(s) above 2.0 NTU this month											0
	Number of days with event(s) above 2.0 NTU last month											0
Does the plant have an approved Corrective Action Plan?											N	
Is the plant required to submit a Filter Profile Report?											N	
Is the plant required to submit a Filter Assessment Report?											N	
Is the plant required to submit a Request for Compliance CPE?											N	

SUBMITTED BY: _____ Certificate No. and Grade: WO0004220 A Date: August 3, 2009

SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER (cont.)

Disinfection Data Page

PUBLIC WATER SYSTEM NAME: City of Corsicana
PWS ID No.: 1750002

PLANT NAME OR NUMBER: Navarro Mills
Month: July Year: 2009

DISINFECTION PROCESS PARAMETERS							
APPROVED CT STUDY PARAMETERS					PERFORMANCE STANDARDS		
Parameters	Disinfection Zones					Log Inactivations	
	D1	D2	D3	D4	D5	Giardia lamblia Cysts	Viruses
Flow Rate (MGD)	20.250	20.250	20.250			0.5	2.0
T ₁₀ (minutes)	109.1	13.0	100.0				

PERFORMANCE DATA									
DISINFECTION PROCESS DATA									
Date	Disinfectant	C (mg/L)	Flow (MGD)	Temp (°C)	pH	Giardia Log	Virus Log	Inact. Ratio	Time _{min}
1	NA D1								
	FCL D2	4.2	9.100	30.0	7.5				
	FCL D3	2.7	9.100	30.0	7.4				
	D4								
	D5								
2	NA D1								
	FCL D2	4.1	9.200	30.0	7.5				
	FCL D3	2.7	9.200	32.0	7.4				
	D4								
	D5								
3	NA D1								
	FCL D2	4.0	9.100	30.0	7.4				
	FCL D3	2.9	9.100	32.0	7.4				
	D4								
	D5								
4	NA D1								
	FCL D2	4.3	9.200	30.0	7.5				
	FCL D3	3.3	9.200	32.0	7.4				
	D4								
	D5								
5	NA D1								
	FCL D2	4.2	9.200	31.0	7.4				
	FCL D3	3.4	9.200	31.0	7.4				
	D4								
	D5								
6	NA D1								
	FCL D2	2.7	9.200	30.0	7.4				
	FCL D3	2.4	9.200	30.0	7.3				
	D4								
	D5								
7	NA D1								
	FCL D2	4.3	5.000	31.0	7.4				
	FCL D3	3.3	5.000	30.0	7.3				
	D4								
	D5								
8	NA D1								
	FCL D2	3.9	9.100	30.0	7.4				
	FCL D3	2.8	9.100	30.0	7.4				
	D4								
	D5								

PERFORMANCE DATA									
DISINFECTION PROCESS DATA									
Date	Disinfectant	C (mg/L)	Flow (MGD)	Temp (°C)	pH	Giardia Log	Virus Log	Inact. Ratio	Time _{min}
9	NA D1								
	FCL D2	4.4	9.100	30.0	7.4				
	FCL D3	2.9	9.100	30.0	7.5				
	D4								
	D5								
10	NA D1								
	FCL D2	4.5	8.400	31.0	7.4				
	FCL D3	3.2	8.400	31.0	7.4				
	D4								
	D5								
11	NA D1								
	FCL D2	4.5	8.800	30.0	7.8				
	FCL D3	3.0	8.800	31.0	7.6				
	D4								
	D5								
12	NA D1								
	FCL D2	4.0	9.000	31.0	7.6				
	FCL D3	2.7	9.000	31.0	7.5				
	D4								
	D5								
13	NA D1								
	FCL D2	2.3	9.100	30.0	7.4				
	FCL D3	2.7	9.100	31.0	7.4				
	D4								
	D5								
14	NA D1								
	FCL D2	3.4	9.100	31.0	7.7				
	FCL D3	3.2	9.100	32.0	7.4				
	D4								
	D5								
15	NA D1								
	FCL D2	3.4	12.200	31.0	7.6				
	FCL D3	2.9	12.200	32.0	7.5				
	D4								
	D5								
16	NA D1								
	FCL D2	4.5	9.100	30.0	7.6				
	FCL D3	2.9	9.100	31.0	7.6				
	D4								
	D5								

NOTE: = ONLY use the "Time=" column to show the length of time that the total inactivation ratio was less than 1.00.

SUBMITTED BY: _____ Certificate No. and Grade: WO0004220 A Date: August 3, 2009

SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER (cont.)
Disinfection Data Page (cont.)

PUBLIC WATER SYSTEM NAME: City of Corsicana
PWS ID No.: 1750002

PLANT NAME OR NUMBER: Navarro Mills
Month: July Year: 2009

DISINFECTION PROCESS PARAMETERS							
APPROVED CT STUDY PARAMETERS					PERFORMANCE STANDARDS		
Parameters	Disinfection Zones					Log Inactivations	
	D1	D2	D3	D4	D5	Giardia lamblia Cysts	Virus
Flow Rate (MGD)	20.250	20.250	20.250			0.5	2.0
T ₁₀ (minutes)	109.1	13.0	100.0				

PERFORMANCE DATA									
Date	DISINFECTION PROCESS DATA								
	Disinfectant	C (mg/L)	Flow (MGD)	Temp (°C)	pH	Giardia Log	Virus Log	Inact. Ratio	Time
17	NA D1								
	FCL D2	4.7	9.100	31.0	7.5				
	FCL D3	3.4	9.100	32.0	7.5				
	D4								
	D5								
18	NA D1								
	FCL D2	4.5	9.000	30.0	7.6				
	FCL D3	3.2	9.000	31.0	7.6				
	D4								
	D5								
19	NA D1								
	FCL D2	3.6	9.100	30.0	7.5				
	FCL D3	2.8	9.100	30.0	7.5				
	D4								
	D5								
20	NA D1								
	FCL D2	4.5	9.100	30.0	7.5				
	FCL D3	3.0	9.100	30.0	7.4				
	D4								
	D5								
21	NA D1								
	FCL D2	3.7	5.000	29.0	7.5				
	FCL D3	3.3	5.000	29.0	7.4				
	D4								
	D5								
22	NA D1								
	FCL D2	4.1	9.200	29.0	7.5				
	FCL D3	2.8	9.200	29.0	7.4				
	D4								
	D5								
23	NA D1								
	FCL D2	4.1	9.200	29.0	7.6				
	FCL D3	2.7	9.200	29.0	7.5				
	D4								
	D5								
24	NA D1								
	FCL D2	3.2	5.100	29.0	7.4				
	FCL D3	2.9	5.100	29.0	7.5				
	D4								
	D5								

PERFORMANCE DATA									
Date	DISINFECTION PROCESS DATA								
	Disinfectant	C (mg/L)	Flow (MGD)	Temp (°C)	pH	Giardia Log	Virus Log	Inact. Ratio	Time
25	NA D1								
	FCL D2	2.1	9.100	30.0	7.8				
	FCL D3	2.7	9.100	29.0	7.6				
	D4								
	D5								
26	NA D1								
	FCL D2	4.5	9.100	30.0	7.6				
	FCL D3	3.4	9.100	29.0	7.6				
	D4								
	D5								
27	NA D1								
	FCL D2	4.4	9.200	29.0	7.6				
	FCL D3	3.4	9.200	29.0	7.5				
	D4								
	D5								
28	NA D1								
	FCL D2	4.1	5.100	28.0	7.6				
	FCL D3	2.9	5.100	29.0	7.5				
	D4								
	D5								
29	NA D1								
	FCL D2	4.2	9.200	28.0	7.9				
	FCL D3	2.7	9.200	29.0	7.7				
	D4								
	D5								
30	NA D1								
	FCL D2	4.2	9.200	28.0	7.8				
	FCL D3	2.8	9.200	29.0	7.7				
	D4								
	D5								
31	NA D1								
	FCL D2	3.7	9.200	29.0	7.7				
	FCL D3	2.4	9.200	29.0	7.6				
	D4								
	D5								

Max	NA	NA
Min	NA	NA
Avg	NA	NA
SD	NA	NA

NOTE: = ONLY use the "Time=" column to show the length of time that the total inactivation ratio was less than 1.00.

SUBMITTED BY: _____ Certificate No. _____ and Grade: WO0004220 A Date: August 3, 2009