

SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER

Summary Page

PUBLIC WATER SYSTEM NAME: <u>City of Corsicana</u>	PLANT NAME OR NUMBER: <u>Lake Halbert</u>
I certify that I am familiar with the information contained in this report and that, to the best of my knowledge, the information is true, complete, and accurate.	
PWS ID No.: <u>1750002</u> Report for the Month of: <u>August 2008</u>	Operator's Signature: _____ Certificate No. & Grade: <u>W00012234 A</u> Date: <u>September 2, 2008</u>

TREATMENT PLANT PERFORMANCE			
Total number of turbidity readings:	138	Number of 4-hour periods when plant was off-line:	48
Number of readings above 0.10 NTU:	18	Number of 4-hour periods when plant was on-line but turbidity data was not collected:	0
Number of readings above 0.3 NTU:	0		
Number of readings above 0.5 NTU:	0		
Number of readings above 1.0 NTU:	0		
Maximum allowable turbidity level:	0.3	Number of days with readings above 1.0 NTU:	0 (2)
Percentage of readings above this limit:	0.0 % (1)	Number of days with readings above 5.0 NTU:	0 (3)
Statistical Summary	Maximum turbidity reading:	Average turbidity value:	0.08 NTU
	Minimum turbidity reading:	Standard deviation:	0.021 NTU
Additional report(s) for individual filter monitoring required:		<input checked="" type="radio"/> NONE <input type="radio"/> Filter Profile <input type="radio"/> Filter Assessment <input type="radio"/> CPE	
Additional report(s) for individual filter monitoring submitted:		<input checked="" type="radio"/> NONE <input type="radio"/> Filter Profile <input type="radio"/> Filter Assessment <input type="radio"/> CPE	
		Number of days when plant was on-line but individual filter turbidity data was not collected: <u>0</u>	
Number of days with a low CT for no more than 4.0 consecutive hours:	0	Average log inactivation for Giardia:	NA
Number of days with a low CT for more than 4.0 consecutive hours:	0 (4)	Average log inactivation for viruses:	NA
		Number of days when profiling data was not collected:	30
		Number of days when CT data was not collected:	30
Minimum disinfectant residual required leaving the plant:	0.5 mg/L	<input type="radio"/> Free Chlorine <input checked="" type="radio"/> Total Chlorine	
Number of days with a low residual for no more than 4.0 consecutive hours:	0		
Number of days with a low residual for more than 4.0 consecutive hours:	0 (5)	Number of days when disinfectant residual leaving the plant was not properly monitored: <u>0</u>	

DISTRIBUTION SYSTEM			
Minimum disinfectant residual required in distribution system:	0.5 mg/L	<input type="radio"/> Free Chlorine <input checked="" type="radio"/> Total Chlorine	
Total number of readings this month:	61	Percentage of readings with a low residual this month:	0.0 % (6A)
Average disinfectant residual value:	1.99	Percentage of readings with a low residual last month:	0.0 % (6B)
Number of readings with a low residual:	0		
Number of readings with no detectable residual:	0		

PUBLIC NOTIFICATION			
TREATMENT TECHNIQUE VIOLATIONS	YES/NO	If YES, date when notice was given to:	
		COMMISSIONERS	CUSTOMERS*
Were more than 5.0% of the turbidity readings above the acceptable level? - see (1) above	No		
Were there any days with turbidity readings above 1.0 NTU? - see (2) above	No		
Were there any days with turbidity readings above 5.0 NTU? - see (3) above	No		
Were there any periods when the plant failed to meet the CT requirements for more than 4.0 consecutive hours? - see (4) above	No		
Were there any periods when the residuals leaving the plant fell below the acceptable level for more than 4.0 consecutive hours? - see (5) above	No		
Were more than 5.0% of the residuals in the distribution system below the acceptable level for two months in a row? - see (6A) and (6B) above	No		

Due by the end of the next business day.
 * Copies of each Public Notice must accompany this report.

Submit the report by the 10th of the month following the reporting period to:

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY
 WATER SUPPLY DIVISION/PUBLIC DRINKING WATER SECTION (MC-155)
 P.O. BOX 13087, AUSTIN, TEXAS 78711-3087

SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER (cont.)

Turbidity Data Page

PUBLIC WATER SYSTEM NAME: City of Corsicana

PLANT NAME OR NUMBER: Lake Halbert

PWS ID No.: 1750002

Connections: 11,500

Month: August Year: 2008

Population: 28,500

PERFORMANCE DATA																		
Date	Raw Water Pumpage (MGD)	Treated Water Pumpage (MGD)	RAW WATER ANALYSES		SETTLED WATER TURBIDITY (Optional Data)						FINISHED WATER QUALITY							
			NTU	Alk.	Basin No.						Turbidity						Lowest Residual	Time
					1	2	3	4	5	6	NTU1	NTU2	NTU3	NTU4	NTU5	NTU6		
1	3.375	3.365	25	117							0.08	0.09	0.06	0.06	0.08	0.08	3.4	
2	3.309	3.300	40	116							0.08	0.08	0.09	0.06	0.06	0.10	3.2	
3	1.570	1.548	40	116							X	X	X	X	0.09	0.06	2.5	
4	3.288	3.200	34	117							0.08	0.07	0.09	0.08	0.05	0.06	3.2	
5	3.555	3.300	46	117							0.07	0.07	0.08	0.08	0.06	0.07	3.2	
6	3.256	3.170	43	116							0.08	0.08	0.08	0.09	0.05	0.05	2.8	
7	3.402	3.369	33	113							0.08	0.08	0.09	0.07	0.07	0.06	3.3	
8	1.767	1.654	72	117							0.08	0.09	0.09	X	X	0.08	3.2	
9	3.395	3.314	30	120							0.08	0.07	0.06	0.06	0.07	0.08	3.3	
10	1.848	1.681	34	118							X	X	X	0.06	0.09	0.08	2.6	
11	3.252	3.200	29	118							0.11	0.10	0.10	0.09	0.07	0.08	3.3	
12	0.569	0.500	33	120							X	X	X	X	0.15	0.12	2.0	
13	1.745	1.740	45	116							0.11	0.11	0.09	0.10	0.06	0.06	3.1	
14	1.275	1.268	39	117							0.15	0.08	0.09	0.08	X	X	3.2	
15	1.014	0.840	50	103							X	X	X	0.13	0.12	0.09	2.5	
16	1.279	1.140	55	116							X	X	X	0.11	0.10	0.09	3.8	
17	1.908	1.895	43	116							0.11	0.10	0.07	0.09	0.10	0.12	3.4	
18	0.000	0.000	X	X	X	X					X	X	X	X	X	X	X	
19	2.012	1.846	39	115							X	0.13	0.14	0.16	0.08	0.08	2.7	
20	2.010	1.864	38	117							0.07	0.08	0.08	0.08	0.05	0.07	3.1	
21	0.750	0.727	35	118							X	X	X	X	0.13	0.09	3.1	
22	0.875	0.873	33	114							0.09	0.07	0.09	X	X	X	3.2	
23	2.005	1.862	53	115							X	0.10	0.14	0.11	0.11	0.09	2.6	
24	2.402	2.327	44	119							0.09	0.08	0.08	0.07	0.07	0.10	3.3	
25	2.093	2.059	42	117							0.08	0.08	0.09	0.07	0.07	0.08	2.6	
26	2.125	2.108	41	122							0.07	0.08	0.09	0.06	0.10	0.08	2.8	
27	1.614	1.497	32	122							X	X	X	0.07	0.08	0.08	2.5	
28	2.208	2.153	41	121							0.09	0.08	0.07	0.08	0.07	0.08	2.7	
29	0.800	0.775	53	114							0.07	0.06	X	X	X	X	3.1	
30	1.255	1.176	60	114							X	X	X	X	0.10	0.09	2.4	
31	1.562	1.461	42	127							0.09	0.07	0.08	0.07	0.10	X	2.9	
Total	61.518	59.212																
Avg	1.984	1.910																
Max	3.555	3.369																
Min	0.000	0.000																

NOTE: ONLY use the "Time" column to show the length of time that the disinfectant residual entering the distribution system fell below the acceptable level.

SUBMITTED BY: _____ Certificate No. and Grade: W00012234 A Date: September 2, 2008

SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER (cont.)

Filter Data Page

PUBLIC WATER
SYSTEM NAME: City of Corsicana
PWS ID No.: 1750002

PLANT NAME
OR NUMBER: Lake Halbert
Month: August Year: 2008

PERFORMANCE DATA																					
INDIVIDUAL FILTER TURBIDITY																					
Date	Filter No. 1		Filter No. 2		Filter No. 3		Filter No. 4		Filter No. 5		Filter No. 6		Filter No. 7		Filter No. 8		Filter No. 9		Filter No. 10		
	Max	4 Hrs	Max	4 Hrs																	
1	0.05	X	0.03	X	0.03	X	0.04	X													
2	0.03	X	0.03	0.03	0.06	0.06	0.04	X													
3	0.05	0.05	0.03	0.03	0.04	0.04	0.05	0.03													
4	0.04	X	0.02	X	0.04	X	0.05	0.05													
5	0.05	0.05	0.04	0.04	0.05	0.05	0.05	X													
6	0.05	X	0.03	0.03	0.05	X	0.03	X													
7	0.04	X	0.04	X	0.04	X	0.03	X													
8	0.09	0.09	0.04	0.02	0.04	0.03	0.05	0.05													
9	0.07	X	0.03	X	0.03	X	0.04	X													
10	0.04	0.04	0.05	0.05	0.09	0.09	0.07	0.05													
11	0.10	0.10	0.05	X	0.08	X	0.07	0.07													
12	0.06	0.06	0.07	0.07	0.05	0.05	X	X													
13	0.04	X	0.04	X	0.03	X	X	X													
14	0.03	X	0.02	X	0.03	X	X	X													
15	0.08	0.08	0.04	0.03	0.05	0.05	X	X													
16	0.07	0.07	0.06	0.06	0.06	0.06	X	X													
17	0.04	X	0.05	X	0.04	X	X	X													
18	X	X	X	X	X	X	X	X													
19	0.06	0.06	0.02	0.02	0.04	0.04	X	X													
20	0.03	X	0.04	0.04	0.05	0.05	X	X													
21	0.03	0.03	0.03	0.03	X	X	X	X													
22	0.03	X	0.02	X	0.03	0.03	X	X													
23	0.03	0.03	X	X	0.07	0.07	0.07	0.06													
24	X	X	X	X	0.05	X	0.05	X													
25	X	X	X	X	0.06	0.06	0.04	X													
26	X	X	X	X	0.04	X	0.04	X													
27	X	X	0.05	0.05	0.05	0.05	0.06	0.06													
28	X	X	0.05	X	0.05	X	0.03	X													
29	X	X	0.04	X	0.04	X	0.07	X													
30	0.08	0.08	0.04	0.04	0.04	0.04	X	X													
31	0.05	X	0.07	0.07	0.03	X	X	X													

SUMMARY & COMPLIANCE ACTIONS	Criteria	Filter No.										Plant	
		1	2	3	4	5	6	7	8	9	10		
	Number of days with event(s) above 0.5 NTU at 4.0 hrs this month	0	0	0	0								
	Number of days with event(s) above 1.0 NTU this month	0	0	0	0								
	Number of days with event(s) above 1.0 NTU last month	0	0	0	0								
	Number of days with event(s) above 1.0 NTU two months ago	0	0	0	0								
	Total number of days with event(s) above 1.0 NTU in three months	0	0	0	0								
	Number of days with event(s) above 2.0 NTU this month											0	
	Number of days with event(s) above 2.0 NTU last month											0	
	Does the plant have an approved Corrective Action Plan?	N	N	N	N							N	
Is the plant required to submit a Filter Profile Report?	N	N	N	N									
Is the plant required to submit a Filter Assessment Report?	N	N	N	N									
Is the plant required to submit a Request for Compliance CPE?											N		

SUBMITTED BY: _____ Certificate No. W00012234 A and Grade: _____ Date: September 2, 2008

SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER (cont.)
Disinfection Data Page

PUBLIC WATER SYSTEM NAME: City of Corsicana
PWS ID No.: 1750002

PLANT NAME OR NUMBER: Lake Halbert
Month: August Year: 2008

DISINFECTION PROCESS PARAMETERS							
APPROVED CT STUDY PARAMETERS					PERFORMANCE STANDARDS		
Parameters	Disinfection Zones					Log Inactivations	
	D1	D2	D3	D4	D5	Giardia lamblia Cysts	Viruses
Flow Rate (MGD)	4.000	4.000	4.000			0.5	2.0
T ₁₀ (minutes)	78.3	15.1	9.0				

PERFORMANCE DATA									
DISINFECTION PROCESS DATA									
Date	Disinfectant	C (mg/L)	Flow (MGD)	Temp (°C)	pH	Giardia Log	Virus Log	Inact. Ratio	Time
1	NA D1								
	FCL D2	3.9	3.800	26.0	7.2				
	FCL D3	3.6	3.800	30.0	7.1				
	D4								
	D5								
2	NA D1								
	FCL D2	4.4	3.800	27.0	7.3				
	FCL D3	3.6	3.800	30.0	7.2				
	D4								
	D5								
3	NA D1								
	FCL D2	2.9	3.800	29.0	7.0				
	FCL D3	2.5	3.800	29.0	7.0				
	D4								
	D5								
4	NA D1								
	FCL D2	3.6	3.800	30.0	7.2				
	FCL D3	3.3	3.800	31.0	7.2				
	D4								
	D5								
5	NA D1								
	FCL D2	3.5	3.800	30.0	7.1				
	FCL D3	3.3	3.800	31.0	7.0				
	D4								
	D5								
6	NA D1								
	FCL D2	3.6	3.800	29.0	7.1				
	FCL D3	3.3	3.800	31.0	7.2				
	D4								
	D5								
7	NA D1								
	FCL D2	3.8	3.800	29.0	7.0				
	FCL D3	3.3	3.800	30.0	7.1				
	D4								
	D5								
8	NA D1								
	FCL D2	4.0	3.800	26.0	7.6				
	FCL D3	3.5	3.800	29.0	7.4				
	D4								
	D5								

PERFORMANCE DATA									
DISINFECTION PROCESS DATA									
Date	Disinfectant	C (mg/L)	Flow (MGD)	Temp (°C)	pH	Giardia Log	Virus Log	Inact. Ratio	Time
9	NA D1								
	FCL D2	3.6	3.800	26.0	7.5				
	FCL D3	3.5	3.800	29.0	7.3				
	D4								
	D5								
10	NA D1								
	FCL D2	2.8	3.800	30.0	7.3				
	FCL D3	2.6	3.800	30.0	7.2				
	D4								
	D5								
11	NA D1								
	FCL D2	3.7	3.800	29.0	7.5				
	FCL D3	3.4	3.800	30.0	7.4				
	D4								
	D5								
12	NA D1								
	FCL D2	2.5	2.000	29.0	7.4				
	FCL D3	2.0	2.000	29.0	7.3				
	D4								
	D5								
13	NA D1								
	FCL D2	3.3	2.000	28.0	7.2				
	FCL D3	3.2	2.000	29.0	7.1				
	D4								
	D5								
14	NA D1								
	FCL D2	4.0	2.000	28.0	7.2				
	CLA D3	4.0	2.000	29.0	7.1				
	D4								
	D5								
15	NA D1								
	FCL D2	3.0	2.200	28.0	7.6				
	CLA D3	2.5	2.200	29.0	6.9				
	D4								
	D5								
16	NA D1								
	FCL D2	4.5	2.200	25.0	7.1				
	CLA D3	4.0	2.200	28.0	7.4				
	D4								
	D5								

NOTE: ONLY use the "Time" column to show the length of time that the total inactivation ratio was less than 1.00.

SUBMITTED BY: _____ and Grade: W00012234 A Certificate No. _____ Date: September 2, 2008

SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER (cont.)
Disinfection Data Page (cont.)

PUBLIC WATER SYSTEM NAME: City of Corsicana
PWS ID No.: 1750002

PLANT NAME OR NUMBER: Lake Halbert
Month: August Year: 2008

DISINFECTION PROCESS PARAMETERS							
APPROVED CT STUDY PARAMETERS					PERFORMANCE STANDARDS		
Parameters	Disinfection Zones					Log Inactivations	
	D1	D2	D3	D4	D5	Giardia lamblia Cysts	Virus
Flow Rate (MGD)	4.000	4.000	4.000			0.5	2.0
T ₁₀ (minutes)	78.3	15.1	9.0				

PERFORMANCE DATA										
DISINFECTION PROCESS DATA										
Date	Disinfectant	C (mg/L)	Flow (MGD)	Temp (°C)	pH	Giardia Log	Virus Log	Inact. Ratio	Time	
17	NA D1									
	FCL D2	3.2	2.200	27.0	7.4					
	CLA D3	2.9	2.200	28.0	7.3					
	D4									
	D5									
18	NA D1									
	NA D2									
	NA D3					NA	NA	NA		
	D4									
	D5									
19	NA D1									
	FCL D2	3.0	2.400	27.0	7.3					
	CLA D3	2.7	2.400	27.0	7.3					
	D4									
	D5									
20	NA D1									
	FCL D2	3.9	2.400	26.0	7.4					
	CLA D3	3.8	2.400	27.0	7.4					
	D4									
	D5									
21	NA D1									
	FCL D2	2.5	2.200	27.0	7.3					
	CLA D3	3.2	2.200	27.0	7.7					
	D4									
	D5									
22	NA D1									
	FCL D2	3.7	2.200	24.0	7.4					
	CLA D3	3.8	2.200	25.0	7.4					
	D4									
	D5									
23	NA D1									
	FCL D2	2.9	2.200	25.0	7.3					
	CLA D3	2.6	2.200	26.0	7.4					
	D4									
	D5									
24	NA D1									
	FCL D2	3.1	2.400	27.0	7.4					
	CLA D3	3.6	2.400	27.0	7.4					
	D4									
	D5									

PERFORMANCE DATA												
DISINFECTION PROCESS DATA												
Date	Disinfectant	C (mg/L)	Flow (MGD)	Temp (°C)	pH	Giardia Log	Virus Log	Inact. Ratio	Time			
25	NA D1											
	FCL D2	3.6	2.400	27.0	7.6							
	CLA D3	3.0	2.400	27.0	7.5							
	D4											
	D5											
26	NA D1											
	FCL D2	3.9	2.400	27.0	7.5							
	CLA D3	3.9	2.400	27.0	7.5							
	D4											
	D5											
27	NA D1											
	FCL D2	3.1	2.400	28.0	7.6							
	CLA D3	3.0	2.400	28.0	7.5							
	D4											
	D5											
28	NA D1											
	FCL D2	3.8	2.400	27.0	7.6							
	CLA D3	4.2	2.400	28.0	7.6							
	D4											
	D5											
29	NA D1											
	FCL D2	2.8	2.400	27.0	7.4							
	CLA D3	3.2	2.400	28.0	7.4							
	D4											
	D5											
30	NA D1											
	FCL D2	2.9	2.400	28.0	7.5							
	CLA D3	2.5	2.400	28.0	7.4							
	D4											
	D5											
31	NA D1											
	FCL D2	3.4	2.400	27.0	7.5							
	CLA D3	3.4	2.400	27.0	7.5							
	D4											
	D5											
										Max	NA	NA
										Min	NA	NA
										Avg	NA	NA
										SD	NA	NA

NOTE: ONLY use the "Time" column to show the length of time that the total inactivation ratio was less than 1.00.

SUBMITTED BY: _____ Certificate No. _____ and Grade: W00012234 A Date: September 2, 2008