

# SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES  
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER

## Summary Page

PUBLIC WATER SYSTEM NAME: City of Corsicana

PLANT NAME OR NUMBER: Lake Halbert

I certify that I am familiar with the information contained in this report and that, to the best of my knowledge, the information is true, complete, and accurate.

PWS ID No.: 1750002

Operator's Signature: \_\_\_\_\_

Report for the Month of: November 2007

Certificate No. & Grade: W00012234 A

Date: December 3, 2007

### TREATMENT PLANT PERFORMANCE

Total number of turbidity readings:	<u>107</u>	Number of 4-hour periods when plant was off-line:	<u>73</u>
Number of readings above 0.10 NTU:	<u>11</u>	Number of 4-hour periods when plant was on-line but turbidity data was not collected:	<u>0</u>
Number of readings above 0.3 NTU:	<u>0</u>		
Number of readings above 0.5 NTU:	<u>0</u>		
Number of readings above 1.0 NTU:	<u>0</u>		
Maximum allowable turbidity level:	<u>0.3</u>	Number of days with readings above 1.0 NTU:	<u>0</u> (2)
Percentage of readings above this limit:	<u>0.0</u> % (1)	Number of days with readings above 5.0 NTU:	<u>0</u> (3)
Statistical Summary	Maximum turbidity reading:	<u>0.13</u> NTU	Average turbidity value:
	Minimum turbidity reading:	<u>0.05</u> NTU	<u>0.09</u> NTU
		Average turbidity value:	<u>0.017</u> NTU
		Standard deviation:	
Additional report(s) for individual filter monitoring required:	<input checked="" type="radio"/> NONE <input type="radio"/> Filter Profile <input type="radio"/> Filter Assessment <input type="radio"/> CPE		
Additional report(s) for individual filter monitoring submitted:	<input checked="" type="radio"/> NONE <input type="radio"/> Filter Profile <input type="radio"/> Filter Assessment <input type="radio"/> CPE		
	Number of days when plant was on-line but individual filter turbidity data was not collected: <u>0</u>		
Number of days with a low CT for no more than 4.0 consecutive hours:	<u>0</u>	Average log inactivation for Giardia:	<u>NA</u>
Number of days with a low CT for more than 4.0 consecutive hours:	<u>0</u> (4)	Average log inactivation for viruses:	<u>NA</u>
		Number of days when profiling data was not collected:	<u>29</u>
		Number of days when CT data was not collected:	<u>29</u>
Minimum disinfectant residual required leaving the plant:	<u>0.5</u> mg/L	<input type="radio"/> Free Chlorine <input checked="" type="radio"/> Total Chlorine	
Number of days with a low residual for no more than 4.0 consecutive hours:	<u>0</u>		
Number of days with a low residual for more than 4.0 consecutive hours:	<u>0</u> (5)	Number of days when disinfectant residual leaving the plant was not properly monitored:	<u>0</u>

### DISTRIBUTION SYSTEM

Minimum disinfectant residual required in distribution system:	<u>0.5</u> mg/L	<input type="radio"/> Free Chlorine <input checked="" type="radio"/> Total Chlorine	
Total number of readings this month:	<u>60</u>	Percentage of readings with a low residual this month:	<u>0.0</u> % (6A)
Average disinfectant residual value:	<u>2.02</u>	Percentage of readings with a low residual last month:	<u>0.0</u> % (6B)
Number of readings with a low residual:	<u>0</u>		
Number of readings with no detectable residual:	<u>0</u>		

### PUBLIC NOTIFICATION

TREATMENT TECHNIQUE VIOLATIONS	YES/NO	If YES, date when notice was given to:	
		COMMISSIONERS	CUSTOMERS*
Were more than 5.0% of the turbidity readings above the acceptable level? - see (1) above	No		
Were there any days with turbidity readings above 1.0 NTU? - see (2) above	No		
Were there any days with turbidity readings above 5.0 NTU? - see (3) above	No		
Were there any periods when the plant failed to meet the CT requirements for more than 4.0 consecutive hours? - see (4) above	No		
Were there any periods when the residuals leaving the plant fell below the acceptable level for more than 4.0 consecutive hours? - see (5) above	No		
Were more than 5.0% of the residuals in the distribution system below the acceptable level for two months in a row? - see (6A) and (6B) above	No		

Due by the end of the next business day.

\* Copies of each Public Notice must accompany this report.

**Submit the report by the 10th of the month following the reporting period to:**

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY  
WATER SUPPLY DIVISION/PUBLIC DRINKING WATER SECTION (MC-155)  
P.O. BOX 13087, AUSTIN, TEXAS 78711-3087

# SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES  
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER (cont.)

## Turbidity Data Page

PUBLIC WATER SYSTEM NAME: City of Corsicana

PLANT NAME OR NUMBER: Lake Halbert

PWS ID No.: 1750002

Connections: 11,500

Month: November Year: 2007

Population: 28,500

PERFORMANCE DATA																		
Date	Raw Water Pumpage (MGD)	Treated Water Pumpage (MGD)	RAW WATER ANALYSES		SETTLED WATER TURBIDITY (Optional Data)						FINISHED WATER QUALITY							
			NTU	Alk.	Basin No.						Turbidity						Lowest Residual	Time
					1	2	3	4	5	6	NTU1	NTU2	NTU3	NTU4	NTU5	NTU6		
1	1.275	1.270	38	104							X	X	X	0.08	0.06	0.07	3.0	
2	1.050	1.038	25	103							X	X	X	0.05	0.05	0.07	3.4	
3	1.879	1.601	25	104							0.09	0.08	0.07	0.08	0.11	0.11	3.0	
4	1.275	1.257	23	106							X	X	X	0.10	0.09	0.09	2.9	
5	1.372	1.328	24	104							X	X	0.08	0.09	0.06	0.06	2.9	
6	1.886	1.765	25	103							0.09	0.08	0.05	0.05	0.05	0.05	3.4	
7	0.800	0.790	30	103							0.10	X	X	X	0.10	0.10	2.5	
8	0.723	0.717	28	85							X	X	X	X	0.09	0.09	2.9	
9	2.100	2.093	30	103							X	0.08	0.09	0.08	0.07	0.06	2.8	
10	0.713	0.658	28	106							0.06	X	X	X	0.08	0.10	2.6	
11	1.000	0.975	28	109							X	X	X	X	0.12	0.11	2.0	
12	2.237	2.136	29	105							0.11	0.09	0.08	0.07	0.08	0.06	2.5	
13	2.159	1.978	32	105							0.07	0.07	0.06	0.08	0.09	0.08	3.1	
14	1.200	1.177	30	105							0.09	0.08	0.09	0.08	X	X	3.3	
15	1.350	1.326	36	105							X	X	0.08	0.07	0.07	0.07	3.1	
16	0.725	0.708	31	107							0.09	X	X	X	0.10	0.10	3.5	
17	0.782	0.725	30	108							0.10	X	X	X	X	0.09	3.5	
18	1.600	1.582	30	109							0.08	0.08	0.08	0.08	0.09	X	3.1	
19	1.179	1.129	40	99							X	X	X	0.07	0.07	0.09	3.5	
20	1.851	1.792	33	102							0.09	0.10	0.09	0.11	0.10	0.09	3.0	
21	1.594	1.517	35	109							X	X	0.07	0.08	0.07	0.09	3.0	
22	1.023	0.960	40	111							0.10	X	X	0.10	0.10	X	3.0	
23	0.916	0.868	46	111							X	X	X	0.10	0.13	0.11	2.9	
24	0.775	0.764	44	112							X	0.09	0.10	X	X	X	2.8	
25	1.000	0.982	43	113							X	X	X	0.09	0.12	0.12	2.8	
26	0.590	0.529	43	114							X	X	X	X	X	0.11	3.5	
27	0.000	0.000	X	X	X	X					X	X	X	X	X	X	X	
28	2.275	2.268	37	116							X	0.09	0.10	0.10	0.08	0.09	2.5	
29	0.925	0.900	34	108							X	X	X	X	0.10	0.10	3.3	
30	1.711	1.624	31	114							0.09	0.08	0.10	0.10	0.09	X	1.2	
31																		
<b>Total</b>	37.965	36.457																
<b>Avg</b>	1.266	1.215																
<b>Max</b>	2.275	2.268																
<b>Min</b>	0.000	0.000																

NOTE: ONLY use the "Time" column to show the length of time that the disinfectant residual entering the distribution system fell below the acceptable level.

SUBMITTED BY: \_\_\_\_\_ Certificate No. and Grade: W00012234 A Date: December 3, 2007

# SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES  
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER (cont.)  
*Filter Data Page*

PUBLIC WATER  
SYSTEM NAME: City of Corsicana  
PWS ID No.: 1750002

PLANT NAME  
OR NUMBER: Lake Halbert  
Month: November Year: 2007

PERFORMANCE DATA																				
INDIVIDUAL FILTER TURBIDITY																				
Date	Filter No. 1		Filter No. 2		Filter No. 3		Filter No. 4		Filter No. 5		Filter No. 6		Filter No. 7		Filter No. 8		Filter No. 9		Filter No. 10	
	Max	4 Hrs																		
1	0.10	0.10	X	X	0.07	0.06	X	X												
2	0.09	0.09	0.12	0.12	0.07	0.05	X	X												
3	0.13	0.13	0.12	0.12	0.05	X	X	X												
4	0.12	0.12	X	X	0.12	0.12	X	X												
5	0.09	0.09	X	X	0.08	0.07	X	X												
6	0.14	0.13	0.06	0.06	0.07	0.07	X	X												
7	0.13	0.12	0.10	0.08	X	X	X	X												
8	0.10	0.10	0.08	0.08	X	X	X	X												
9	0.11	0.10	0.07	0.07	X	X	X	X												
10	0.10	X	0.05	X	0.12	0.12	0.14	0.14												
11	0.15	0.15	X	X	0.09	0.09	X	X												
12	0.13	X	X	X	0.09	X	X	X												
13	0.10	X	0.11	0.11	0.06	X	0.11	0.11												
14	X	X	0.08	X	X	X	0.11	X												
15	X	X	0.05	0.05	X	X	0.09	0.09												
16	0.13	0.13	X	X	0.12	0.12	X	X												
17	0.11	0.11	X	X	0.09	0.08	X	X												
18	0.11	X	X	X	0.11	X	X	X												
19	0.09	X	0.13	0.13	0.06	0.06	X	X												
20	0.14	0.14	0.08	0.08	X	X	X	X												
21	0.10	0.10	0.07	0.06	X	X	X	X												
22	0.09	0.09	0.11	0.11	0.10	0.10	X	X												
23	X	X	0.08	0.08	0.08	0.08	X	X												
24	0.13	0.13	0.06	0.06	X	X	X	X												
25	0.11	0.11	0.06	0.06	X	X	X	X												
26	0.10	0.10	X	X	0.08	0.08	X	X												
27	X	X	X	X	X	X	X	X												
28	0.09	0.09	0.11	0.11	0.06	0.06	X	X												
29	X	X	0.06	0.06	0.06	0.06	X	X												
30	0.13	0.13	0.06	X	X	X	0.10	0.10												
31																				

  

SUMMARY & COMPLIANCE ACTIONS	Filter No.											Plant
	Criteria											
	1	2	3	4	5	6	7	8	9	10		
	Number of days with event(s) above 0.5 NTU at 4.0 hrs this month											0
	Number of days with event(s) above 1.0 NTU this month											0
	Number of days with event(s) above 1.0 NTU last month											0
	Number of days with event(s) above 1.0 NTU two months ago											0
	Total number of days with event(s) above 1.0 NTU in three months											0
	Number of days with event(s) above 2.0 NTU this month											0
	Number of days with event(s) above 2.0 NTU last month											0
Does the plant have an approved Corrective Action Plan?											N	
Is the plant required to submit a Filter Profile Report?											N	
Is the plant required to submit a Filter Assessment Report?											N	
Is the plant required to submit a Request for Compliance CPE?											N	

SUBMITTED BY: \_\_\_\_\_ Certificate No. and Grade: W00012234 A Date: December 3, 2007

# SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES  
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER (cont.)  
*Disinfection Data Page*

PUBLIC WATER SYSTEM NAME: City of Corsicana  
PWS ID No.: 1750002

PLANT NAME OR NUMBER: Lake Halbert  
Month: November Year: 2007

DISINFECTION PROCESS PARAMETERS						
APPROVED CT STUDY PARAMETERS					PERFORMANCE STANDARDS	
Parameters	Disinfection Zones				Log Inactivations	
	D1	D2	D3	D4	D5	Giardia lamblia Cysts
Flow Rate (MGD)	4.000	4.000	4.000			0.5
T <sub>10</sub> (minutes)	78.3	15.1	9.0			2.0

PERFORMANCE DATA									
DISINFECTION PROCESS DATA									
Date	Disinfectant	C (mg/L)	Flow (MGD)	Temp (°C)	pH	Giardia Log	Virus Log	Inact. Ratio	Time <input type="checkbox"/>
1	NA D1								
	FCL D2	3.6	2.400	21.0	7.5				
	CLA D3	3.2	2.400	20.0	7.5				
	D4								
	D5								
2	NA D1								
	FCL D2	4.4	1.600	18.0	7.4				
	CLA D3	3.4	1.600	19.0	7.6				
	D4								
	D5								
3	NA D1								
	FCL D2	3.9	2.400	19.0	7.6				
	CLA D3	3.4	2.400	19.0	7.5				
	D4								
	D5								
4	NA D1								
	FCL D2	3.0	2.400	20.0	7.5				
	CLA D3	3.1	2.400	20.0	7.5				
	D4								
	D5								
5	NA D1								
	FCL D2	3.4	2.400	19.0	7.4				
	CLA D3	3.5	2.400	19.0	7.4				
	D4								
	D5								
6	NA D1								
	FCL D2	3.6	2.400	19.0	7.4				
	CLA D3	3.4	2.400	19.0	7.4				
	D4								
	D5								
7	NA D1								
	FCL D2	3.6	2.400	19.0	7.5				
	CLA D3	3.7	2.400	19.0	7.4				
	D4								
	D5								
8	NA D1								
	FCL D2	4.0	2.300	19.0	7.4				
	CLA D3	2.9	2.300	19.0	7.4				
	D4								
	D5								

PERFORMANCE DATA									
DISINFECTION PROCESS DATA									
Date	Disinfectant	C (mg/L)	Flow (MGD)	Temp (°C)	pH	Giardia Log	Virus Log	Inact. Ratio	Time <input type="checkbox"/>
9	NA D1								
	FCL D2	3.2	2.400	19.0	7.5				
	CLA D3	3.3	2.400	19.0	7.5				
	D4								
	D5								
10	NA D1								
	FCL D2	3.0	2.200	20.0	7.4				
	CLA D3	2.9	2.200	20.0	7.4				
	D4								
	D5								
11	NA D1								
	FCL D2	2.9	2.200	21.0	7.4				
	CLA D3	2.8	2.200	21.0	7.4				
	D4								
	D5								
12	NA D1								
	FCL D2	3.2	2.200	21.0	7.4				
	CLA D3	3.1	2.200	21.0	7.5				
	D4								
	D5								
13	NA D1								
	FCL D2	3.3	2.200	19.0	7.4				
	CLA D3	3.4	2.200	20.0	7.5				
	D4								
	D5								
14	NA D1								
	FCL D2	3.2	2.200	19.0	7.5				
	CLA D3	3.4	2.200	20.0	7.5				
	D4								
	D5								
15	NA D1								
	FCL D2	4.8	2.300	18.0	7.6				
	CLA D3	3.2	2.300	20.0	7.8				
	D4								
	D5								
16	NA D1								
	FCL D2	3.7	2.300	19.0	7.5				
	CLA D3	4.0	2.300	20.0	7.5				
	D4								
	D5								

NOTE:  ONLY use the "Time

SUBMITTED BY: \_\_\_\_\_ Certificate No. W00012234 A and Grade: \_\_\_\_\_ Date: December 3, 2007

# SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES  
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER (cont.)  
*Disinfection Data Page (cont.)*

PUBLIC WATER SYSTEM NAME: City of Corsicana  
PWS ID No.: 1750002

PLANT NAME OR NUMBER: Lake Halbert  
Month: November Year: 2007

DISINFECTION PROCESS PARAMETERS									
APPROVED CT STUDY PARAMETERS					PERFORMANCE STANDARDS				
Parameters	Disinfection Zones					Log Inactivations			
	D1	D2	D3	D4	D5	Giardia lamblia Cysts		Virus	
Flow Rate (MGD)	4.000	4.000	4.000			0.5		2.0	
T <sub>10</sub> (minutes)	78.3	15.1	9.0						

PERFORMANCE DATA									
DISINFECTION PROCESS DATA									
Date	Disinfectant	C (mg/L)	Flow (MGD)	Temp (°C)	pH	Giardia Log	Virus Log	Inact. Ratio	Time
17	NA D1								
	FCL D2	3.6	2.300	19.0	7.5				
	CLA D3	3.7	2.300	19.0	7.5				
	D4								
	D5								
18	NA D1								
	FCL D2	3.4	2.300	20.0	7.4				
	CLA D3	3.5	2.300	20.0	7.3				
	D4								
	D5								
19	NA D1								
	FCL D2	3.5	2.400	19.0	7.4				
	CLA D3	3.6	2.400	19.0	7.3				
	D4								
	D5								
20	NA D1								
	FCL D2	3.2	2.400	20.0	7.5				
	CLA D3	3.0	2.400	20.0	7.6				
	D4								
	D5								
21	NA D1								
	FCL D2	3.6	2.400	20.0	7.5				
	CLA D3	3.5	2.400	19.0	7.5				
	D4								
	D5								
22	NA D1								
	FCL D2	3.6	2.400	18.0	7.5				
	CLA D3	3.5	2.400	19.0	7.6				
	D4								
	D5								
23	NA D1								
	FCL D2	2.6	1.800	16.0	7.2				
	CLA D3	2.9	1.800	17.0	7.2				
	D4								
	D5								
24	NA D1								
	FCL D2	3.4	2.000	17.0	7.5				
	CLA D3	3.2	2.000	17.0	7.5				
	D4								
	D5								

PERFORMANCE DATA									
DISINFECTION PROCESS DATA									
Date	Disinfectant	C (mg/L)	Flow (MGD)	Temp (°C)	pH	Giardia Log	Virus Log	Inact. Ratio	Time
25	NA D1								
	FCL D2	2.8	2.400	19.0	7.6				
	CLA D3	2.8	2.400	18.0	7.7				
	D4								
	D5								
26	NA D1								
	FCL D2	3.7	2.400	16.0	7.4				
	CLA D3	3.5	2.400	16.0	7.4				
	D4								
	D5								
27	NA D1								
	NA D2								
	NA D3					NA	NA	NA	
	D4								
	D5								
28	NA D1								
	FCL D2	3.7	2.400	18.0	7.6				
	CLA D3	3.6	2.400	18.0	7.5				
	D4								
	D5								
29	NA D1								
	FCL D2	4.0	2.400	14.0	7.4				
	CLA D3	3.6	2.400	15.0	7.5				
	D4								
	D5								
30	NA D1								
	FCL D2	3.8	2.400	16.0	7.4				
	CLA D3	3.5	2.400	16.0	7.4				
	D4								
	D5								
31	D1								
	D2								
	D3								
	D4								
	D5								
	Max					NA	NA		
	Min					NA	NA		
	Avg					NA	NA		
	SD					NA	NA		

NOTE:  ONLY use the "Time" column to show the length of time that the total inactivation ratio was less than 1.00.

SUBMITTED BY: \_\_\_\_\_ Certificate No. and Grade: W00012234 A Date: December 3, 2007