

SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER

Summary Page

PUBLIC WATER SYSTEM NAME: <u>City of Corsicana</u>	PLANT NAME OR NUMBER: <u>Lake Halbert</u>
I certify that I am familiar with the information contained in this report and that, to the best of my knowledge, the information is true, complete, and accurate.	
PWS ID No.: <u>1750002</u> Report for the Month of: <u>October 2007</u>	Operator's Signature: _____ Certificate No. & Grade: <u>W00012234 A</u> Date: <u>November 5, 2007</u>

TREATMENT PLANT PERFORMANCE			
Total number of turbidity readings:	99	Number of 4-hour periods when plant was off-line:	87
Number of readings above 0.10 NTU:	22	Number of 4-hour periods when plant was on-line but turbidity data was not collected:	0
Number of readings above 0.3 NTU:	0		
Number of readings above 0.5 NTU:	0		
Number of readings above 1.0 NTU:	0		
Maximum allowable turbidity level:	0.3	Number of days with readings above 1.0 NTU:	0 (2)
Percentage of readings above this limit:	0.0 % (1)	Number of days with readings above 5.0 NTU:	0 (3)
Statistical Summary	Maximum turbidity reading:	0.24 NTU	Average turbidity value:
	Minimum turbidity reading:	0.05 NTU	0.09 NTU
			Standard deviation:
			0.030 NTU
Additional report(s) for individual filter monitoring required:		<input checked="" type="radio"/> NONE <input type="radio"/> Filter Profile <input type="radio"/> Filter Assessment <input type="radio"/> CPE	
Additional report(s) for individual filter monitoring submitted:		<input checked="" type="radio"/> NONE <input type="radio"/> Filter Profile <input type="radio"/> Filter Assessment <input type="radio"/> CPE	
		Number of days when plant was on-line but individual filter turbidity data was not collected: <u>0</u>	
Number of days with a low CT for no more than 4.0 consecutive hours:	0	Average log inactivation for Giardia:	NA
Number of days with a low CT for more than 4.0 consecutive hours:	0 (4)	Average log inactivation for viruses:	NA
		Number of days when profiling data was not collected:	30
		Number of days when CT data was not collected:	30
Minimum disinfectant residual required leaving the plant:	0.5 mg/L	<input type="radio"/> Free Chlorine <input checked="" type="radio"/> Total Chlorine	
Number of days with a low residual for no more than 4.0 consecutive hours:	0		
Number of days with a low residual for more than 4.0 consecutive hours:	0 (5)	Number of days when disinfectant residual leaving the plant was not properly monitored:	0

DISTRIBUTION SYSTEM			
Minimum disinfectant residual required in distribution system:	0.5 mg/L	<input type="radio"/> Free Chlorine <input checked="" type="radio"/> Total Chlorine	
Total number of readings this month:	61	Percentage of readings with a low residual this month:	0.0 % (6A)
Average disinfectant residual value:	1.67	Percentage of readings with a low residual last month:	0.0 % (6B)
Number of readings with a low residual:	0		
Number of readings with no detectable residual:	0		

PUBLIC NOTIFICATION			
TREATMENT TECHNIQUE VIOLATIONS	YES/NO	If YES, date when notice was given to:	
		COMMISSIONERS	CUSTOMERS*
Were more than 5.0% of the turbidity readings above the acceptable level? - see (1) above	No		
Were there any days with turbidity readings above 1.0 NTU? - see (2) above	No		
Were there any days with turbidity readings above 5.0 NTU? - see (3) above	No		
Were there any periods when the plant failed to meet the CT requirements for more than 4.0 consecutive hours? - see (4) above	No		
Were there any periods when the residuals leaving the plant fell below the acceptable level for more than 4.0 consecutive hours? - see (5) above	No		
Were more than 5.0% of the residuals in the distribution system below the acceptable level for two months in a row? - see (6A) and (6B) above	No		

Due by the end of the next business day.
 * Copies of each Public Notice must accompany this report.

Submit the report by the 10th of the month following the reporting period to:

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY
 WATER SUPPLY DIVISION/PUBLIC DRINKING WATER SECTION (MC-155)
 P.O. BOX 13087, AUSTIN, TEXAS 78711-3087

SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER (cont.)

Turbidity Data Page

PUBLIC WATER SYSTEM NAME: City of Corsicana

PLANT NAME OR NUMBER: Lake Halbert

PWS ID No.: 1750002

Connections: 11,500

Month: October Year: 2007

Population: 28,500

PERFORMANCE DATA																		
Date	Raw Water Pumpage (MGD)	Treated Water Pumpage (MGD)	RAW WATER ANALYSES		SETTLED WATER TURBIDITY (Optional Data)						FINISHED WATER QUALITY							
			NTU	Aik.	Basin No.						Turbidity						Lowest Residual	Time
					1	2	3	4	5	6	NTU1	NTU2	NTU3	NTU4	NTU5	NTU6		
1	2.275	2.262	26	101							X	X	0.12	0.12	0.13	0.10	2.3	
2	1.488	1.442	18	104							X	X	X	X	0.09	0.10	3.5	
3	1.225	1.206	38	103							X	X	X	0.10	0.11	0.10	2.8	
4	2.069	1.996	38	103							X	X	X	0.09	0.09	0.11	3.2	
5	2.275	2.254	40	102							X	X	X	0.08	0.10	0.16	3.4	
6	0.775	0.768	37	110							X	X	X	X	0.08	0.09	2.8	
7	1.625	1.559	42	108							X	X	X	X	0.10	0.13	3.2	
8	1.464	1.369	28	92							X	X	X	X	0.09	0.14	2.8	
9	2.225	2.210	32	104							X	X	X	0.11	0.09	0.08	3.3	
10	0.900	0.866	28	100							X	X	X	0.09	0.08	X	2.0	
11	2.050	2.025	21	102							X	X	X	0.08	0.07	0.10	3.2	
12	1.336	1.247	23	99							X	X	X	X	0.09	0.08	3.1	
13	1.096	1.044	19	100							X	X	X	X	0.08	0.14	3.6	
14	1.156	1.076	18	101							X	X	X	X	0.11	0.13	2.7	
15	1.536	1.494	20	93							0.11	0.10	0.14	0.15	0.15	0.13	3.1	
16	1.850	1.844	19	98							0.08	0.08	0.10	0.08	0.10	0.10	2.9	
17	1.133	0.957	18	95							X	X	0.06	0.06	X	X	2.9	
18	1.562	1.362	17	100							X	X	0.24	0.11	0.08	X	2.9	
19	0.600	0.581	27	100							X	X	X	X	0.10	0.07	2.4	
20	2.104	2.054	21	100							X	X	X	0.07	0.08	0.07	2.8	
21	0.821	0.719	17	102							X	X	X	X	X	0.11	2.8	
22	1.575	1.565	28	98							0.10	0.09	0.12	0.08	0.07	0.06	2.6	
23	1.594	1.467	32	102							0.07	0.07	0.06	0.06	0.06	0.09	3.1	
24	1.200	1.189	35	90							X	X	X	0.08	0.07	0.06	3.1	
25	2.517	2.447	37	100							0.06	0.07	0.09	0.09	0.09	0.08	3.0	
26	0.000	0.000	X	X	X	X					X	X	X	X	X	X	X	
27	2.325	2.303	37	113							X	0.07	0.08	0.07	X	X	3.0	
28	0.525	0.510	33	100							X	X	X	X	0.07	0.07	2.8	
29	1.992	1.930	30	104							0.07	0.06	0.05	0.05	0.05	0.06	3.2	
30	2.013	1.868	29	104							0.05	0.07	0.07	0.07	0.09	0.10	2.7	
31	1.350	1.344	28	95							X	X	X	0.19	0.10	0.09	2.5	
Total	46.656	44.958																
Avg	1.505	1.450																
Max	2.517	2.447																
Min	0.000	0.000																

NOTE: ONLY use the "Time" column to show the length of time that the disinfectant residual entering the distribution system fell below the acceptable level.

SUBMITTED BY: _____ Certificate No. and Grade: W00012234 A Date: November 5, 2007

SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER (cont.)
Filter Data Page

PUBLIC WATER
SYSTEM NAME: City of Corsicana
PWS ID No.: 1750002

PLANT NAME
OR NUMBER: Lake Halbert
Month: October Year: 2007

PERFORMANCE DATA																				
INDIVIDUAL FILTER TURBIDITY																				
Date	Filter No. 1		Filter No. 2		Filter No. 3		Filter No. 4		Filter No. 5		Filter No. 6		Filter No. 7		Filter No. 8		Filter No. 9		Filter No. 10	
	Max	4 Hrs																		
1	0.10	0.09	0.17	0.17	0.18	0.18	0.13	0.13												
2	0.09	0.08	0.09	0.09	0.11	0.10	0.12	0.12												
3	0.14	0.14	0.08	0.08	0.09	0.09	0.10	0.10												
4	0.12	0.10	0.06	0.06	0.09	0.08	0.21	0.18												
5	0.11	0.11	0.06	0.06	0.07	0.07	0.23	0.17												
6	0.10	0.10	0.05	0.05	0.08	0.08	0.19	0.19												
7	0.10	0.10	0.18	0.18	0.06	0.06	0.16	0.16												
8	0.18	0.18	0.10	0.10	0.20	0.20	0.13	0.13												
9	0.13	0.13	0.08	0.08	0.14	0.14	0.10	0.10												
10	0.10	0.10	0.05	0.05	0.09	0.08	0.10	0.10												
11	0.10	0.10	0.05	0.05	0.08	0.08	0.12	0.10												
12	0.10	0.10	0.05	0.05	0.07	0.07	0.10	0.10												
13	0.10	0.10	0.05	0.05	0.07	0.07	X	X												
14	0.09	0.09	0.13	0.13	0.07	0.07	0.19	0.18												
15	0.21	0.21	0.11	X	0.15	0.15	0.19	X												
16	0.10	X	X	X	0.08	X	0.14	X												
17	0.14	0.14	X	X	0.11	0.11	0.18	0.18												
18	0.11	0.11	0.10	0.10	0.09	0.09	X	X												
19	0.09	0.09	0.06	0.06	0.07	0.07	X	X												
20	0.09	0.09	0.05	0.05	0.07	0.07	0.13	0.13												
21	X	X	0.12	0.12	0.07	0.07	0.13	0.13												
22	0.14	X	0.10	X	0.07	X	0.12	X												
23	0.14	0.14	X	X	0.06	0.06	X	X												
24	0.11	0.11	X	X	X	X	0.09	0.09												
25	0.10	X	0.08	0.08	0.11	0.11	0.10	X												
26	X	X	X	X	X	X	X	X												
27	0.16	0.16	X	X	0.07	0.07	0.09	0.08												
28	0.09	0.09	0.05	0.05	0.06	0.06	X	X												
29	0.09	X	0.04	X	0.06	X	X	X												
30	0.15	0.15	0.06	X	0.12	0.12	0.13	0.13												
31	0.12	0.12	X	X	0.10	0.10	X	X												

SUMMARY & COMPLIANCE ACTIONS	Criteria											Plant
	Filter No.											
	1	2	3	4	5	6	7	8	9	10		
	Number of days with event(s) above 0.5 NTU at 4.0 hrs this month											0
	Number of days with event(s) above 1.0 NTU this month											0
	Number of days with event(s) above 1.0 NTU last month											0
	Number of days with event(s) above 1.0 NTU two months ago											0
	Total number of days with event(s) above 1.0 NTU in three months											0
	Number of days with event(s) above 2.0 NTU this month											0
	Number of days with event(s) above 2.0 NTU last month											0
Does the plant have an approved Corrective Action Plan?											N	
Is the plant required to submit a Filter Profile Report?											N	
Is the plant required to submit a Filter Assessment Report?											N	
Is the plant required to submit a Request for Compliance CPE?											N	

SUBMITTED BY: _____ Certificate No. and Grade: W00012234 A Date: November 5, 2007

SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER (cont.)
Disinfection Data Page

PUBLIC WATER SYSTEM NAME: City of Corsicana
PWS ID No.: 1750002

PLANT NAME OR NUMBER: Lake Halbert
Month: October Year: 2007

DISINFECTION PROCESS PARAMETERS							
APPROVED CT STUDY PARAMETERS					PERFORMANCE STANDARDS		
Parameters	Disinfection Zones				Log Inactivations		
	D1	D2	D3	D4	D5	Giardia lamblia Cysts	Viruses
Flow Rate (MGD)	4.000	4.000	4.000			0.5	2.0
T ₁₀ (minutes)	78.3	15.1	9.0				

PERFORMANCE DATA									
DISINFECTION PROCESS DATA									
Date	Disinfectant	C (mg/L)	Flow (MGD)	Temp (°C)	pH	Giardia Log	Virus Log	Inact. Ratio	Time <input type="checkbox"/>
1	NA D1								
	FCL D2	4.5	3.800	26.0	7.2				
	CLA D3	4.4	3.800	27.0	7.4				
	D4								
	D5								
2	NA D1								
	FCL D2	4.2	3.800	27.0	7.3				
	CLA D3	3.5	3.800	28.0	7.5				
	D4								
	D5								
3	NA D1								
	FCL D2	2.5	2.500	26.0	7.6				
	CLA D3	2.8	2.500	27.0	7.5				
	D4								
	D5								
4	NA D1								
	FCL D2	4.0	3.800	24.0	7.5				
	CLA D3	3.7	3.800	26.0	7.4				
	D4								
	D5								
5	NA D1								
	FCL D2	3.8	3.800	25.0	7.5				
	CLA D3	3.4	3.800	27.0	7.3				
	D4								
	D5								
6	NA D1								
	FCL D2	3.0	3.800	21.0	7.9				
	CLA D3	2.8	3.800	26.0	7.5				
	D4								
	D5								
7	NA D1								
	FCL D2	3.4	3.800	26.0	7.4				
	CLA D3	3.2	3.800	26.0	7.4				
	D4								
	D5								
8	NA D1								
	FCL D2	3.0	3.800	26.0	7.4				
	CLA D3	2.8	3.800	28.0	7.4				
	D4								
	D5								

PERFORMANCE DATA									
DISINFECTION PROCESS DATA									
Date	Disinfectant	C (mg/L)	Flow (MGD)	Temp (°C)	pH	Giardia Log	Virus Log	Inact. Ratio	Time <input type="checkbox"/>
9	NA D1								
	FCL D2	3.9	3.800	25.0	7.4				
	CLA D3	3.4	3.800	27.0	7.4				
	D4								
	D5								
10	NA D1								
	FCL D2	4.0	3.800	24.0	7.4				
	CLA D3	3.7	3.800	26.0	7.3				
	D4								
	D5								
11	NA D1								
	FCL D2	3.8	3.800	24.0	7.4				
	CLA D3	3.3	3.800	26.0	7.3				
	D4								
	D5								
12	NA D1								
	FCL D2	3.6	3.800	24.0	7.6				
	CLA D3	3.1	3.800	26.0	7.4				
	D4								
	D5								
13	NA D1								
	FCL D2	3.8	3.800	24.0	7.5				
	CLA D3	3.6	3.800	26.0	7.5				
	D4								
	D5								
14	NA D1								
	FCL D2	4.0	2.500	24.0	7.7				
	CLA D3	3.2	2.500	25.0	7.6				
	D4								
	D5								
15	NA D1								
	FCL D2	3.9	3.200	25.0	7.9				
	CLA D3	3.1	3.200	26.0	7.8				
	D4								
	D5								
16	NA D1								
	FCL D2	3.3	1.800	24.0	7.6				
	CLA D3	2.9	1.800	25.0	7.7				
	D4								
	D5								

NOTE: ONLY use the "Time" column to show the length of time that the total inactivation ratio was less than 1.00.

SUBMITTED BY: _____ Certificate No. W00012234 A and Grade: _____ Date: November 5, 2007

SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER (cont.)
Disinfection Data Page (cont.)

PUBLIC WATER SYSTEM NAME: City of Corsicana
PWS ID No.: 1750002

PLANT NAME OR NUMBER: Lake Halbert
Month: October Year: 2007

DISINFECTION PROCESS PARAMETERS							
APPROVED CT STUDY PARAMETERS					PERFORMANCE STANDARDS		
Parameters	Disinfection Zones					Log Inactivations	
	D1	D2	D3	D4	D5	Giardia lamblia Cysts	Virus
Flow Rate (MGD)	4.000	4.000	4.000			0.5	2.0
T ₁₀ (minutes)	78.3	15.1	9.0				

PERFORMANCE DATA									
DISINFECTION PROCESS DATA									
Date	Disinfectant	C (mg/L)	Flow (MGD)	Temp (°C)	pH	Giardia Log	Virus Log	Inact. Ratio	Time <input type="checkbox"/>
17	NA D1								
	FCL D2	3.5	2.100	23.0	7.5				
	CLA D3	2.9	2.100	24.0	7.4				
	D4								
	D5								
18	NA D1								
	FCL D2	3.4	2.500	23.0	7.4				
	CLA D3	2.9	2.500	24.0	7.3				
	D4								
	D5								
19	NA D1								
	FCL D2	3.5	2.500	22.0	7.6				
	CLA D3	2.4	2.500	23.0	7.5				
	D4								
	D5								
20	NA D1								
	FCL D2	3.9	3.800	22.0	7.4				
	CLA D3	2.8	3.800	23.0	7.5				
	D4								
	D5								
21	NA D1								
	FCL D2	4.0	3.800	21.0	7.7				
	CLA D3	3.0	3.800	23.0	7.6				
	D4								
	D5								
22	NA D1								
	FCL D2	3.8	3.800	23.0	7.6				
	CLA D3	3.5	3.800	23.0	7.5				
	D4								
	D5								
23	NA D1								
	FCL D2	3.0	2.100	20.0	7.4				
	CLA D3	3.1	2.100	21.0	7.4				
	D4								
	D5								
24	NA D1								
	FCL D2	2.9	1.600	20.0	7.5				
	CLA D3	3.1	1.600	20.0	7.5				
	D4								
	D5								

PERFORMANCE DATA									
DISINFECTION PROCESS DATA									
Date	Disinfectant	C (mg/L)	Flow (MGD)	Temp (°C)	pH	Giardia Log	Virus Log	Inact. Ratio	Time <input type="checkbox"/>
25	NA D1								
	FCL D2	3.7	3.700	19.0	7.5				
	CLA D3	3.8	3.700	19.0	7.7				
	D4								
	D5								
26	NA D1								
	NA D2								
	NA D3					NA	NA	NA	
	D4								
	D5								
27	NA D1								
	FCL D2	3.5	3.700	18.0	7.4				
	CLA D3	3.0	3.700	19.0	7.6				
	D4								
	D5								
28	NA D1								
	FCL D2	2.5	2.500	19.0	7.7				
	CLA D3	2.8	2.500	20.0	7.6				
	D4								
	D5								
29	NA D1								
	FCL D2	3.6	2.500	19.0	7.5				
	CLA D3	3.2	2.500	19.0	7.6				
	D4								
	D5								
30	NA D1								
	FCL D2	3.6	3.500	18.0	7.3				
	CLA D3	3.2	3.500	18.0	7.6				
	D4								
	D5								
31	NA D1								
	FCL D2	2.5	2.300	19.0	7.4				
	CLA D3	2.5	2.300	19.0	7.6				
	D4								
	D5								

Max	NA	NA
Min	NA	NA
Avg	NA	NA
SD	NA	NA

NOTE: ONLY use the "Time

SUBMITTED BY: _____ Certificate No. and Grade: W00012234 A Date: November 5, 2007