

# SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES  
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER

## Summary Page

<b>PUBLIC WATER SYSTEM NAME:</b> <u>City of Corsicana</u>	<b>PLANT NAME OR NUMBER:</b> <u>Navarro Mills</u>
I certify that I am familiar with the information contained in this report and that, to the best of my knowledge, the information is true, complete, and accurate.	
<b>PWS ID No.:</b> <u>1750002</u> <b>Report for the Month of:</b> <u>October 2007</u>	<b>Operator's Signature:</b> _____ <b>Certificate No. &amp; Grade:</b> <u>WO0004220 A</u> <b>Date:</b> <u>November 6, 2007</u>

TREATMENT PLANT PERFORMANCE			
Total number of turbidity readings:	186	Number of 4-hour periods when plant was off-line:	0
Number of readings above 0.10 NTU:	95	Number of 4-hour periods when plant was on-line but turbidity data was not collected:	0
Number of readings above 0.3 NTU:	4		
Number of readings above 0.5 NTU:	0		
Number of readings above 1.0 NTU:	0		
Maximum allowable turbidity level:	0.3	Number of days with readings above 1.0 NTU:	0 (2)
Percentage of readings above this limit:	2.2 % (1)	Number of days with readings above 5.0 NTU:	0 (3)
Statistical Summary	Maximum turbidity reading:	0.46 NTU	Average turbidity value:
	Minimum turbidity reading:	0.06 NTU	0.14 NTU
			Standard deviation:
			0.076 NTU
Additional report(s) for individual filter monitoring required:		<input checked="" type="radio"/> NONE <input type="radio"/> Filter Profile <input type="radio"/> Filter Assessment <input type="radio"/> CPE	
Additional report(s) for individual filter monitoring submitted:		<input checked="" type="radio"/> NONE <input type="radio"/> Filter Profile <input type="radio"/> Filter Assessment <input type="radio"/> CPE	
#NAME?		Number of days when plant was on-line but individual filter turbidity data was not collected:	0
Number of days with a low CT for no more than 4.0 consecutive hours:	0	Average log inactivation for Giardia:	NA
Number of days with a low CT for more than 4.0 consecutive hours:	0 (4)	Average log inactivation for viruses:	NA
		Number of days when profiling data was not collected:	31
		Number of days when CT data was not collected:	31
Minimum disinfectant residual required leaving the plant:	0.5 mg/L	<input checked="" type="radio"/> Free Chlorine <input type="radio"/> Total Chlorine	
Number of days with a low residual for no more than 4.0 consecutive hours:	0		
Number of days with a low residual for more than 4.0 consecutive hours:	0 (5)	Number of days when disinfectant residual leaving the plant was not properly monitored:	0

DISTRIBUTION SYSTEM			
Minimum disinfectant residual required in distribution system:	0.5 mg/L	<input checked="" type="radio"/> Free Chlorine <input type="radio"/> Total Chlorine	
Total number of readings this month:	61	Percentage of readings with a low residual this month:	0.0 % (6A)
Average disinfectant residual value:	1.67		
Number of readings with a low residual:	0	Percentage of readings with a low residual last month:	0.0 % (6B)
Number of readings with no detectable residual:	0		

PUBLIC NOTIFICATION			
TREATMENT TECHNIQUE VIOLATIONS	YES/NO	If YES, date when notice was given to:	
		COMMISSIONERS	CUSTOMERS*
Were more than 5.0% of the turbidity readings above the acceptable level? - see (1) above	No		
Were there any days with turbidity readings above 1.0 NTU? - see (2) above	No		
Were there any days with turbidity readings above 5.0 NTU? - see (3) above	No		
Were there any periods when the plant failed to meet the CT requirements for more than 4.0 consecutive hours? - see (4) above	No		
Were there any periods when the residuals leaving the plant fell below the acceptable level for more than 4.0 consecutive hours? - see (5) above	No		
Were more than 5.0% of the residuals in the distribution system below the acceptable level for two months in a row? - see (6A) and (6B) above	No		

Due by the end of the next business day.  
 \* Copies of each Public Notice must accompany this report.

**Submit the report by the 10th of the month following the reporting period to:**

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY  
 WATER SUPPLY DIVISION/PUBLIC DRINKING WATER SECTION (MC-155)  
 P.O. BOX 13087, AUSTIN, TEXAS 78711-3087

# SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES  
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER (cont.)

## Turbidity Data Page

PUBLIC WATER SYSTEM NAME: City of Corsicana

PLANT NAME OR NUMBER: Navarro Mills

PWS ID No.: 1750002

Connections: 11,050

Month: October Year: 2007

Population: 28,500

PERFORMANCE DATA																		
Date	Raw Water Pumpage (MGD)	Treated Water Pumpage (MGD)	RAW WATER ANALYSES		SETTLED WATER TURBIDITY (Optional Data)						FINISHED WATER QUALITY							
			NTU	Alk.	Basin No.						Turbidity						Lowest Residual	Time
					1	2	3	4	5	6	NTU1	NTU2	NTU3	NTU4	NTU5	NTU6		
1	7.440	5.467	32	112	0.7	0.7	1.0	1.5	0.8	0.8	0.09	0.08	0.07	0.06	0.13	0.13	2.8	
2	5.780	4.815	25	110	0.8	1.4	1.0	1.2	0.9	1.2	0.12	0.12	0.10	0.11	0.11	0.12	2.4	
3	7.050	5.647	34	110	1.0	1.3	1.4	1.1	1.3	1.3	0.10	0.10	0.08	0.09	0.09	0.10	2.6	
4	5.710	4.730	38	111	1.7	2.3	2.0	1.8	2.0	2.0	0.11	0.10	0.10	0.12	0.10	0.10	2.7	
5	5.650	5.431	40	109	2.1	2.3	2.8	1.9	2.2	2.3	0.09	0.08	0.18	0.17	0.11	0.08	2.6	
6	5.690	4.449	36	109	1.4	2.0	2.1	1.5	1.6	1.9	0.07	0.08	0.07	0.07	0.08	0.08	2.6	
7	7.850	5.163	40	109	1.1	1.4	1.6	1.4	1.3	1.4	0.08	0.09	0.07	0.11	0.11	0.12	2.6	
8	6.010	4.418	36	109	1.2	1.3	1.7	1.2	1.3	1.1	0.12	0.10	0.07	0.07	0.08	0.08	2.8	
9	7.660	5.768	28	105	1.1	1.4	1.6	1.2	1.2	1.2	0.08	0.10	0.14	0.10	0.10	0.10	2.9	
10	6.350	4.954	27	111	0.9	1.0	1.4	0.9	0.9	1.0	0.08	0.08	0.08	0.07	0.06	0.06	2.9	
11	6.540	5.257	26	109	0.7	0.9	0.8	0.9	0.7	0.7	0.07	0.07	0.09	0.08	0.07	0.07	2.9	
12	9.040	5.756	34	114	1.0	1.1	1.1	0.9	1.2	1.1	0.06	0.06	0.19	0.21	0.08	0.10	2.2	
13	6.300	5.226	29	108	1.2	1.7	1.6	1.1	1.3	1.3	0.08	0.07	0.07	0.07	0.08	0.07	3.2	
14	6.350	5.126	29	107	1.2	1.6	1.6	1.3	1.4	1.6	0.07	0.07	0.06	0.06	0.08	0.08	2.9	
15	6.270	3.932	32	104	1.4	1.7	1.9	1.5	1.7	1.7	0.07	0.07	0.08	0.08	0.17	0.16	2.9	
16	5.720	4.077	43	110	1.6	1.9	1.8	1.6	1.7	1.7	0.12	0.11	0.26	0.17	0.13	0.13	2.8	
17	6.750	5.385	49	111	1.6	2.1	2.4	1.7	2.1	2.0	0.13	0.12	0.08	0.07	0.07	0.08	2.7	
18	5.020	4.315	42	109	2.1	2.8	3.0	2.1	2.7	2.6	0.08	0.13	0.27	0.39	0.46	0.32	3.2	
19	4.840	4.476	36	107	2.1	2.5	2.7	2.5	3.0	2.8	0.29	0.22	0.15	0.13	0.13	0.24	3.4	
20	6.170	4.778	37	106	1.8	1.9	2.0	1.9	2.3	2.0	0.25	0.22	0.14	0.22	0.38	0.37	3.3	
21	5.360	4.718	37	115	1.5	1.9	1.8	1.8	1.8	1.8	0.31	0.24	0.19	0.19	0.21	0.19	3.1	
22	5.370	4.094	35	112	1.5	1.9	2.2	1.7	1.8	1.7	0.18	0.10	0.10	0.10	0.13	0.20	3.0	
23	5.370	4.245	36	112	1.6	2.1	2.0	1.9	2.0	2.2	0.15	0.16	0.25	0.26	0.18	0.17	3.2	
24	5.370	4.352	37	113	1.4	1.7	2.1	1.7	1.7	1.7	0.14	0.14	0.13	0.14	0.21	0.29	3.0	
25	5.350	4.682	37	110	1.3	1.8	2.1	1.4	1.9	1.6	0.24	0.14	0.13	0.29	0.23	0.15	3.0	
26	5.350	4.733	40	114	1.4	1.8	2.1	1.5	1.9	1.7	0.12	0.16	0.12	0.18	0.24	0.23	3.2	
27	5.540	4.405	51	114	1.4	1.9	2.6	1.6	1.8	1.7	0.26	0.26	0.29	0.25	0.25	0.28	3.2	
28	7.420	5.809	49	115	1.6	1.8	2.0	1.7	1.7	1.6	0.22	0.12	0.13	0.18	0.18	0.15	3.1	
29	5.010	4.737	52	118	1.3	1.6	2.3	1.8	1.5	1.4	0.13	0.07	0.07	0.07	0.09	0.10	3.4	
30	4.890	3.760	52	117	1.4	1.5	3.0	2.0	1.4	1.4	0.08	0.09	0.07	0.08	0.08	0.08	3.1	
31	6.960	5.033	45	115	1.3	1.6	2.1	1.5	1.7	1.7	0.07	0.07	0.08	0.18	0.27	0.21	3.0	
<b>Total</b>	190.180	149.738																
<b>Avg</b>	6.135	4.830																
<b>Max</b>	9.040	5.809																
<b>Min</b>	4.840	3.760																

NOTE: ONLY use the "Time" column to show the length of time that the disinfectant residual entering the distribution system fell below the acceptable level.

SUBMITTED BY: \_\_\_\_\_ Certificate No. and Grade: WO0004220 A Date: November 6, 2007

# SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES  
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER (cont.)  
*Filter Data Page*

PUBLIC WATER  
SYSTEM NAME: City of Corsicana  
PWS ID No.: 1750002

PLANT NAME  
OR NUMBER: Navarro Mills  
Month: October Year: 2007

PERFORMANCE DATA																				
INDIVIDUAL FILTER TURBIDITY																				
Date	Filter No. 1		Filter No. 2		Filter No. 3		Filter No. 4		Filter No. 5		Filter No. 6		Filter No. 7		Filter No. 8		Filter No. 9		Filter No. 10	
	Max	4 Hrs	Max	4 Hrs																
1	0.17	X	0.13	0.12	0.67	X	0.16	X	0.16	X	0.08	X								
2	0.79	X	0.14	X	0.12	X	0.30	0.24	0.15	X	0.20	0.20								
3	0.19	0.17	0.10	X	0.30	0.13	0.15	X	0.06	X	0.15	X								
4	0.10	X	0.27	X	X	X	0.11	X	0.09	0.08	0.09	X								
5	0.24	X	0.40	X	0.11	0.09	0.49	X	0.07	X	0.07	X								
6	0.50	X	X	X	0.07	X	0.82	X	0.05	X	0.12	X								
7	0.82	0.09	0.09	0.08	0.31	X	0.14	0.08	0.05	X	0.16	0.10								
8	0.08	X	0.09	X	0.17	X	0.08	X	X	X	0.09	X								
9	0.09	X	0.26	X	0.17	0.11	0.10	X	0.11	0.09	0.09	X								
10	0.07	X	0.14	X	X	X	0.07	X	0.07	X	0.07	X								
11	0.56	X	0.10	X	0.09	0.07	0.50	X	0.07	X	0.07	X								
12	0.53	0.09	0.11	0.09	0.14	X	0.15	0.11	0.11	X	0.16	0.11								
13	0.08	X	0.08	X	0.07	X	0.08	X	X	X	0.08	X								
14	0.07	X	0.10	X	0.07	X	0.07	X	X	X	0.07	X								
15	0.14	X	0.41	X	0.72	X	0.25	X	0.12	0.08	0.07	X								
16	0.67	X	0.17	0.11	0.09	0.08	0.30	0.10	0.09	X	0.20	0.09								
17	0.13	X	0.69	X	0.07	X	0.08	X	0.05	X	0.09	X								
18	X	X	0.23	X	0.08	X	0.11	X	0.05	X	0.07	X								
19	0.10	0.05	0.31	X	0.36	X	0.49	X	0.06	X	0.07	X								
20	0.79	X	0.59	X	0.14	0.08	0.72	X	0.16	0.05	0.39	X								
21	0.59	X	0.21	0.08	0.13	X	0.43	0.08	0.05	X	0.62	X								
22	0.36	X	0.42	X	0.08	X	0.07	X	0.05	X	X	X								
23	X	X	0.17	X	0.48	X	0.26	X	0.11	X	X	X								
24	X	X	0.12	0.09	0.64	X	0.70	X	0.14	X	0.16	0.08								
25	0.18	0.07	0.90	X	X	X	0.47	X	X	X	0.07	X								
26	0.63	X	0.78	X	X	X	X	X	X	X	0.39	X								
27	0.81	X	0.52	X	0.08	0.06	0.10	0.08	0.09	0.07	0.40	0.09								
28	X	X	X	X	0.07	X	0.09	X	0.06	X	0.09	X								
29	X	X	X	X	0.14	X	0.07	X	0.05	X	0.07	X								
30	X	X	X	X	0.34	X	0.16	X	0.04	X	0.07	X								
31	0.41	0.08	0.21	0.07	0.98	X	0.85	X	0.11	0.07	0.30	X								

  

SUMMARY & COMPLIANCE ACTIONS	Criteria										Filter No.	Plant	
	1	2	3	4	5	6	7	8	9	10			
	Number of days with event(s) above 0.5 NTU at 4.0 hrs this month											0	
	Number of days with event(s) above 1.0 NTU this month											0	
	Number of days with event(s) above 1.0 NTU last month											0	
	Number of days with event(s) above 1.0 NTU two months ago											0	
	Total number of days with event(s) above 1.0 NTU in three months											0	
	Number of days with event(s) above 2.0 NTU this month											0	0
	Number of days with event(s) above 2.0 NTU last month											0	0
	Does the plant have an approved Corrective Action Plan?											N	N
Is the plant required to submit a Filter Profile Report?											N	N	
Is the plant required to submit a Filter Assessment Report?											N	N	
Is the plant required to submit a Request for Compliance CPE?											N	N	

SUBMITTED BY: \_\_\_\_\_ Certificate No. and Grade: WO0004220 A Date: November 6, 2007

# SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES  
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER (cont.)

*Disinfection Data Page*

PUBLIC WATER SYSTEM NAME: City of Corsicana  
PWS ID No.: 1750002

PLANT NAME OR NUMBER: Navarro Mills  
Month: October Year: 2007

DISINFECTION PROCESS PARAMETERS							
APPROVED CT STUDY PARAMETERS					PERFORMANCE STANDARDS		
Parameters	Disinfection Zones					Log Inactivations	
	D1	D2	D3	D4	D5	Giardia lamblia Cysts	Viruses
Flow Rate (MGD)	20.250	20.250	20.250			0.5	2.0
T <sub>10</sub> (minutes)	109.1	13.0	100.0				

PERFORMANCE DATA									
DISINFECTION PROCESS DATA									
Date	Disinfectant	C (mg/L)	Flow (MGD)	Temp (°C)	pH	Giardia Log	Virus Log	Inact. Ratio	Time <sub>min</sub>
1	NA D1								
	FCL D2	3.1	9.900	26.0	7.4				
	CLA D3	3.0	9.900	27.0	7.4				
	D4								
	D5								
2	NA D1								
	FCL D2	3.0	5.900	26.0	7.4				
	CLA D3	2.8	5.900	27.0	7.4				
	D4								
	D5								
3	NA D1								
	FCL D2	3.1	10.000	27.0	7.4				
	CLA D3	2.8	10.000	27.0	7.4				
	D4								
	D5								
4	NA D1								
	FCL D2	3.1	5.800	27.0	7.4				
	CLA D3	3.0	5.800	27.0	7.4				
	D4								
	D5								
5	NA D1								
	FCL D2	3.0	5.600	27.0	7.4				
	CLA D3	2.8	5.600	27.0	7.4				
	D4								
	D5								
6	NA D1								
	FCL D2	3.3	5.700	27.0	7.4				
	CLA D3	2.7	5.700	27.0	7.4				
	D4								
	D5								
7	NA D1								
	FCL D2	3.0	10.600	27.0	7.5				
	CLA D3	2.9	10.600	27.0	7.4				
	D4								
	D5								
8	NA D1								
	FCL D2	2.7	6.300	27.0	7.5				
	CLA D3	3.3	6.300	27.0	7.5				
	D4								
	D5								

PERFORMANCE DATA									
DISINFECTION PROCESS DATA									
Date	Disinfectant	C (mg/L)	Flow (MGD)	Temp (°C)	pH	Giardia Log	Virus Log	Inact. Ratio	Time <sub>min</sub>
9	NA D1								
	FCL D2	3.2	10.600	26.0	7.4				
	CLA D3	3.1	10.600	27.0	7.4				
	D4								
	D5								
10	NA D1								
	FCL D2	3.0	6.400	26.0	7.4				
	CLA D3	3.2	6.400	26.0	7.4				
	D4								
	D5								
11	NA D1								
	FCL D2	3.1	6.300	26.0	7.4				
	CLA D3	3.1	6.300	26.0	7.4				
	D4								
	D5								
12	NA D1								
	FCL D2	3.2	10.600	26.0	7.5				
	CLA D3	2.2	10.600	26.0	7.4				
	D4								
	D5								
13	NA D1								
	FCL D2	3.1	6.400	26.0	7.5				
	CLA D3	3.4	6.400	26.0	7.5				
	D4								
	D5								
14	NA D1								
	FCL D2	2.9	6.400	25.0	7.5				
	CLA D3	3.2	6.400	26.0	7.5				
	D4								
	D5								
15	NA D1								
	FCL D2	2.5	6.400	25.0	7.5				
	CLA D3	3.1	6.400	25.0	7.5				
	D4								
	D5								
16	NA D1								
	FCL D2	3.3	6.300	25.0	7.4				
	CLA D3	3.3	6.300	25.0	7.4				
	D4								
	D5								

NOTE: = ONLY use the "Time=" column to show the length of time that the total inactivation ratio was less than 1.00.

SUBMITTED BY: \_\_\_\_\_ Certificate No. \_\_\_\_\_ and Grade: WO0004220 A Date: November 6, 2007

# SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES  
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER (cont.)  
*Disinfection Data Page (cont.)*

PUBLIC WATER SYSTEM NAME: City of Corsicana  
PWS ID No.: 1750002

PLANT NAME OR NUMBER: Navarro Mills  
Month: October Year: 2007

DISINFECTION PROCESS PARAMETERS							
APPROVED CT STUDY PARAMETERS					PERFORMANCE STANDARDS		
Parameters	Disinfection Zones					Log Inactivations	
	D1	D2	D3	D4	D5	Giardia lamblia Cysts	Virus
Flow Rate (MGD)	20.250	20.250	20.250			0.5	2.0
T <sub>10</sub> (minutes)	109.1	13.0	100.0				

PERFORMANCE DATA									
Date	DISINFECTION PROCESS DATA								
	Disinfectant	C (mg/L)	Flow (MGD)	Temp (°C)	pH	Giardia Log	Virus Log	Inact. Ratio	Time
17	NA D1								
	FCL D2	3.5	9.900	25.0	7.4				
	CLA D3	2.9	9.900	25.0	7.4				
	D4								
	D5								
18	NA D1								
	FCL D2	3.2	5.100	25.0	7.4				
	CLA D3	3.7	5.100	25.0	7.4				
	D4								
	D5								
19	NA D1								
	FCL D2	3.4	5.100	24.0	7.6				
	CLA D3	3.6	5.100	25.0	7.5				
	D4								
	D5								
20	NA D1								
	FCL D2	3.7	10.000	23.0	7.7				
	CLA D3	3.6	10.000	24.0	7.7				
	D4								
	D5								
21	NA D1								
	FCL D2	2.6	5.300	24.0	7.7				
	CLA D3	3.1	5.300	24.0	7.7				
	D4								
	D5								
22	NA D1								
	FCL D2	2.9	5.400	23.0	7.7				
	CLA D3	3.1	5.400	24.0	7.7				
	D4								
	D5								
23	NA D1								
	FCL D2	3.2	5.500	21.0	7.7				
	CLA D3	3.5	5.500	22.0	7.7				
	D4								
	D5								
24	NA D1								
	FCL D2	2.9	5.300	21.0	7.6				
	CLA D3	3.2	5.300	21.0	7.6				
	D4								
	D5								

PERFORMANCE DATA									
Date	DISINFECTION PROCESS DATA								
	Disinfectant	C (mg/L)	Flow (MGD)	Temp (°C)	pH	Giardia Log	Virus Log	Inact. Ratio	Time
25	NA D1								
	FCL D2	3.4	5.400	21.0	7.6				
	CLA D3	3.0	5.400	21.0	7.6				
	D4								
	D5								
26	NA D1								
	FCL D2	3.0	5.400	20.0	7.6				
	CLA D3	3.2	5.400	21.0	7.6				
	D4								
	D5								
27	NA D1								
	FCL D2	3.0	5.400	20.0	7.6				
	CLA D3	3.3	5.400	20.0	7.7				
	D4								
	D5								
28	NA D1								
	FCL D2	3.2	8.400	18.0	7.6				
	CLA D3	3.7	8.400	19.0	7.6				
	D4								
	D5								
29	NA D1								
	FCL D2	3.0	5.100	19.0	7.6				
	CLA D3	3.7	5.100	19.0	7.6				
	D4								
	D5								
30	NA D1								
	FCL D2	2.8	5.200	19.0	7.6				
	CLA D3	3.2	5.200	19.0	7.6				
	D4								
	D5								
31	NA D1								
	FCL D2	2.5	8.300	18.0	7.6				
	CLA D3	3.1	8.300	18.0	7.7				
	D4								
	D5								
						Max	NA	NA	
						Min	NA	NA	
						Avg	NA	NA	
						SD	NA	NA	

NOTE: = ONLY use the "Time=" column to show the length of time that the total inactivation ratio was less than 1.00.

SUBMITTED BY: \_\_\_\_\_ Certificate No. \_\_\_\_\_ and Grade: WO0004220 A Date: November 6, 2007