

SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER

Summary Page

PUBLIC WATER SYSTEM NAME: <u>City of Corsicana</u>	PLANT NAME OR NUMBER: <u>Lake Halbert</u>
I certify that I am familiar with the information contained in this report and that, to the best of my knowledge, the information is true, complete, and accurate.	
PWS ID No.: <u>1750002</u> Report for the Month of: <u>June 2007</u>	Operator's Signature: _____ Certificate No. & Grade: <u>W00012234 A</u> Date: <u>July 2, 2007</u>

TREATMENT PLANT PERFORMANCE			
Total number of turbidity readings:	75	Number of 4-hour periods when plant was off-line:	105
Number of readings above 0.10 NTU:	15	Number of 4-hour periods when plant was on-line but turbidity data was not collected:	0
Number of readings above 0.3 NTU:	0		
Number of readings above 0.5 NTU:	0		
Number of readings above 1.0 NTU:	0		
Maximum allowable turbidity level:	0.3	Number of days with readings above 1.0 NTU:	0 (2)
Percentage of readings above this limit:	0.0 % (1)	Number of days with readings above 5.0 NTU:	0 (3)
Statistical Summary	Maximum turbidity reading:	Average turbidity value:	0.09 NTU
	Minimum turbidity reading:	Standard deviation:	0.022 NTU
Additional report(s) for individual filter monitoring required:		<input checked="" type="radio"/> NONE <input type="radio"/> Filter Profile <input type="radio"/> Filter Assessment <input type="radio"/> CPE	
Additional report(s) for individual filter monitoring submitted:		<input checked="" type="radio"/> NONE <input type="radio"/> Filter Profile <input type="radio"/> Filter Assessment <input type="radio"/> CPE	
		Number of days when plant was on-line but individual filter turbidity data was not collected: <u>0</u>	
Number of days with a low CT for no more than 4.0 consecutive hours:	0	Average log inactivation for Giardia:	NA
Number of days with a low CT for more than 4.0 consecutive hours:	0 (4)	Average log inactivation for viruses:	NA
		Number of days when profiling data was not collected:	27
		Number of days when CT data was not collected:	27
Minimum disinfectant residual required leaving the plant:	0.5 mg/L	<input type="radio"/> Free Chlorine <input checked="" type="radio"/> Total Chlorine	
Number of days with a low residual for no more than 4.0 consecutive hours:	0		
Number of days with a low residual for more than 4.0 consecutive hours:	0 (5)	Number of days when disinfectant residual leaving the plant was not properly monitored:	0

DISTRIBUTION SYSTEM			
Minimum disinfectant residual required in distribution system:	0.5 mg/L	<input type="radio"/> Free Chlorine <input checked="" type="radio"/> Total Chlorine	
Total number of readings this month:	60	Percentage of readings with a low residual this month:	0.0 % (6A)
Average disinfectant residual value:	1.67	Percentage of readings with a low residual last month:	0.0 % (6B)
Number of readings with a low residual:	0		
Number of readings with no detectable residual:	0		

PUBLIC NOTIFICATION			
TREATMENT TECHNIQUE VIOLATIONS	YES/NO	If YES, date when notice was given to:	
		COMMISSIONERS	CUSTOMERS*
Were more than 5.0% of the turbidity readings above the acceptable level? - see (1) above	No		
Were there any days with turbidity readings above 1.0 NTU? - see (2) above	No		
Were there any days with turbidity readings above 5.0 NTU? - see (3) above	No		
Were there any periods when the plant failed to meet the CT requirements for more than 4.0 consecutive hours? - see (4) above	No		
Were there any periods when the residuals leaving the plant fell below the acceptable level for more than 4.0 consecutive hours? - see (5) above	No		
Were more than 5.0% of the residuals in the distribution system below the acceptable level for two months in a row? - see (6A) and (6B) above	No		

Due by the end of the next business day.
 * Copies of each Public Notice must accompany this report.

Submit the report by the 10th of the month following the reporting period to:

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY
 WATER SUPPLY DIVISION/PUBLIC DRINKING WATER SECTION (MC-155)
 P.O. BOX 13087, AUSTIN, TEXAS 78711-3087

SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER (cont.)

Turbidity Data Page

PUBLIC WATER SYSTEM NAME: City of Corsicana

PLANT NAME OR NUMBER: Lake Halbert

PWS ID No.: 1750002

Connections: 11,500

Month: June Year: 2007

Population: 28,500

PERFORMANCE DATA																		
Date	Raw Water Pumpage (MGD)	Treated Water Pumpage (MGD)	RAW WATER ANALYSES		SETTLED WATER TURBIDITY (Optional Data)						FINISHED WATER QUALITY							
			NTU	Alk.	Basin No.						Turbidity						Lowest Residual	Time
					1	2	3	4	5	6	NTU1	NTU2	NTU3	NTU4	NTU5	NTU6		
1	0.000	0.000	X	X	X	X						X	X	X	X	X	X	X
2	1.155	1.151	58	86								X	X	X	0.11	0.09	0.07	2.5
3	0.496	0.409	46	87								X	X	X	X	X	0.10	2.9
4	0.818	0.721	47	88								0.07	0.08	0.09	X	X	X	3.5
5	1.450	1.433	50	92								X	X	X	X	0.14	0.13	3.3
6	0.000	0.000	X	X	X	X						X	X	X	X	X	X	X
7	2.350	2.346	30	91								X	X	X	0.10	0.11	0.10	3.0
8	0.625	0.619	32	92								0.10	0.11	X	X	X	X	3.0
9	2.025	2.011	42	85								X	X	X	0.15	0.10	0.08	3.2
10	1.400	1.392	35	86								0.07	0.06	X	X	X	X	3.3
11	1.907	1.769	48	86								X	X	0.08	0.07	0.08	0.09	2.6
12	1.750	1.742	56	87								0.10	0.08	0.09	0.08	X	X	3.2
13	2.288	2.136	39	88								X	X	X	0.07	0.07	0.08	3.0
14	2.375	2.367	56	88								0.11	0.10	0.10	0.10	0.06	X	3.0
15	0.000	0.000	X	X	X	X						X	X	X	X	X	X	X
16	1.332	1.226	35	87								X	X	X	X	0.09	0.06	3.1
17	0.300	0.277	43	90								0.12	X	X	X	X	X	3.4
18	1.200	1.189	49	94								X	X	X	X	0.11	0.09	3.4
19	1.155	1.096	43	91								0.08	0.08	0.09	0.09	X	X	3.2
20	1.520	1.280	56	79								X	X	X	0.12	0.10	0.07	3.3
21	0.630	0.623	61	90								0.11	0.10	X	X	X	X	3.7
22	1.230	1.266	56	111								X	X	X	X	0.09	0.07	1.3
23	2.725	2.708	49	95								0.15	0.13	0.10	0.09	0.07	0.06	2.9
24	0.375	0.366	40	95								0.06	0.08	X	X	X	X	3.3
25	1.600	1.595	50	81								X	0.13	0.09	0.08	0.07	0.08	1.6
26	1.608	1.566	34	71								X	X	X	X	0.10	0.09	3.4
27	0.850	0.847	31	101								X	X	X	0.13	0.10	X	2.7
28	1.175	1.166	32	93								X	X	0.09	0.08	X	X	2.8
29	1.375	1.368	30	91								X	X	X	0.07	0.07	0.06	2.1
30	0.300	0.286	36	90								0.06	0.06	X	X	X	X	3.5
31																		
Total	36.014	34.955																
Avg	1.200	1.165																
Max	2.725	2.708																
Min	0.000	0.000																

NOTE: ONLY use the "Time" column to show the length of time that the disinfectant residual entering the distribution system fell below the acceptable level.

SUBMITTED BY: _____ Certificate No. and Grade: W00012234 A Date: July 2, 2007

SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER (cont.)

Filter Data Page

PUBLIC WATER
SYSTEM NAME: City of Corsicana
PWS ID No.: 1750002

PLANT NAME
OR NUMBER: Lake Halbert
Month: June Year: 2007

PERFORMANCE DATA																				
INDIVIDUAL FILTER TURBIDITY																				
Date	Filter No. 1		Filter No. 2		Filter No. 3		Filter No. 4		Filter No. 5		Filter No. 6		Filter No. 7		Filter No. 8		Filter No. 9		Filter No. 10	
	Max	4 Hrs																		
1	X	X	X	X	X	X	X	X												
2	0.07	0.07	0.05	0.05	0.07	0.07	0.11	0.11												
3	0.06	0.06	0.05	0.05	0.07	0.07	0.12	0.12												
4	0.09	X	0.05	X	0.18	0.18	0.13	X												
5	0.15	0.15	0.14	0.14	0.13	0.13	0.15	0.15												
6	X	X	X	X	X	X	X	X												
7	0.10	0.10	0.10	0.10	0.11	0.10	0.12	0.11												
8	0.09	X	0.10	X	0.11	X	0.12	X												
9	0.07	0.07	0.08	0.08	0.09	0.09	0.10	0.10												
10	0.05	X	0.05	X	0.08	X	0.09	X												
11	0.19	0.19	0.06	0.04	0.06	0.06	0.17	0.14												
12	0.11	X	0.05	X	0.06	X	0.16	X												
13	0.09	0.08	0.06	0.05	0.17	0.17	0.12	0.11												
14	0.06	X	0.13	0.09	0.12	0.11	0.10	0.09												
15	X	X	X	X	X	X	X	X												
16	0.04	0.04	0.10	0.10	0.09	0.09	0.09	0.09												
17	0.05	X	0.09	X	0.09	X	X	X												
18	0.05	0.05	0.08	0.08	0.08	0.08	0.14	0.14												
19	0.04	X	0.07	X	0.07	X	0.11	X												
20	0.13	0.13	0.07	0.07	0.18	0.18	0.13	0.10												
21	0.10	X	0.16	0.15	0.13	X	0.13	X												
22	0.09	0.09	0.19	0.18	0.14	0.14	0.21	0.21												
23	0.08	X	0.12	X	0.11	X	0.15	X												
24	0.05	X	0.07	X	0.07	X	X	X												
25	0.06	0.06	0.07	0.06	0.06	0.06	0.12	0.09												
26	0.06	0.05	0.05	0.05	0.06	0.05	0.09	0.09												
27	0.10	0.10	0.04	0.04	0.05	0.05	0.08	0.08												
28	0.09	0.09	0.05	0.05	0.05	0.05	0.08	0.08												
29	0.11	0.10	0.05	0.05	0.05	0.05	0.07	0.06												
30	0.10	X	0.05	X	0.05	X	0.07	X												
31																				

SUMMARY & COMPLIANCE ACTIONS	Filter No.											Plant
	Criteria											
	1	2	3	4	5	6	7	8	9	10		
	Number of days with event(s) above 0.5 NTU at 4.0 hrs this month	0	0	0	0							
	Number of days with event(s) above 1.0 NTU this month	0	0	0	0							
	Number of days with event(s) above 1.0 NTU last month	0	0	0	0							
	Number of days with event(s) above 1.0 NTU two months ago	0	0	0	0							
	Total number of days with event(s) above 1.0 NTU in three months	0	0	0	0							
	Number of days with event(s) above 2.0 NTU this month											0
	Number of days with event(s) above 2.0 NTU last month											0
Does the plant have an approved Corrective Action Plan?	N	N	N	N							N	
Is the plant required to submit a Filter Profile Report?	N	N	N	N								
Is the plant required to submit a Filter Assessment Report?	N	N	N	N								
Is the plant required to submit a Request for Compliance CPE?											N	

SUBMITTED BY: _____ Certificate No. and Grade: W00012234 A Date: July 2, 2007

SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER (cont.)
Disinfection Data Page

PUBLIC WATER SYSTEM NAME: City of Corsicana
PWS ID No.: 1750002

PLANT NAME OR NUMBER: Lake Halbert
Month: June Year: 2007

DISINFECTION PROCESS PARAMETERS						
APPROVED CT STUDY PARAMETERS					PERFORMANCE STANDARDS	
Parameters	Disinfection Zones				Log Inactivations	
	D1	D2	D3	D4	D5	Giardia lamblia Cysts
Flow Rate (MGD)	4.000	4.000	4.000			Viruses
T ₁₀ (minutes)	78.3	15.1	9.0			0.5
						2.0

PERFORMANCE DATA									
DISINFECTION PROCESS DATA									
Date	Disinfectant	C (mg/L)	Flow (MGD)	Temp (°C)	pH	Giardia Log	Virus Log	Inact. Ratio	Time <input type="checkbox"/>
1	NA D1								
	NA D2								
	NA D3					NA	NA	NA	
	D4								
	D5								
2	NA D1								
	FCL D2	3.4	2.500	24.0	7.3				
	CLA D3	2.5	2.500	24.0	7.6				
	D4								
	D5								
3	NA D1								
	FCL D2	2.7	2.500	22.0	7.3				
	CLA D3	2.9	2.500	23.0	7.2				
	D4								
	D5								
4	NA D1								
	FCL D2	3.9	2.500	25.0	7.3				
	CLA D3	3.9	2.500	25.0	7.3				
	D4								
	D5								
5	NA D1								
	FCL D2	3.8	3.800	24.0	7.2				
	CLA D3	3.7	3.800	24.0	7.1				
	D4								
	D5								
6	NA D1								
	NA D2								
	NA D3					NA	NA	NA	
	D4								
	D5								
7	NA D1								
	FCL D2	4.0	3.800	24.0	7.1				
	CLA D3	3.1	3.800	25.0	7.4				
	D4								
	D5								
8	NA D1								
	FCL D2	3.2	3.800	26.0	7.3				
	CLA D3	3.0	3.800	26.0	7.3				
	D4								
	D5								

PERFORMANCE DATA									
DISINFECTION PROCESS DATA									
Date	Disinfectant	C (mg/L)	Flow (MGD)	Temp (°C)	pH	Giardia Log	Virus Log	Inact. Ratio	Time <input type="checkbox"/>
9	NA D1								
	FCL D2	2.8	3.800	26.0	7.2				
	CLA D3	3.2	3.800	27.0	7.4				
	D4								
	D5								
10	NA D1								
	FCL D2	3.6	3.800	26.0	7.4				
	CLA D3	3.3	3.800	27.0	7.4				
	D4								
	D5								
11	NA D1								
	FCL D2	2.5	2.500	26.0	7.0				
	CLA D3	2.6	2.500	26.0	7.1				
	D4								
	D5								
12	NA D1								
	FCL D2	3.6	3.500	28.0	7.2				
	CLA D3	3.2	3.500	28.0	7.2				
	D4								
	D5								
13	NA D1								
	FCL D2	3.3	3.900	27.0	7.0				
	CLA D3	3.0	3.900	27.0	7.2				
	D4								
	D5								
14	NA D1								
	FCL D2	3.4	3.900	26.0	7.2				
	CLA D3	3.3	3.900	27.0	7.3				
	D4								
	D5								
15	NA D1								
	NA D2								
	NA D3					NA	NA	NA	
	D4								
	D5								
16	NA D1								
	FCL D2	3.5	3.800	25.0	7.2				
	CLA D3	3.1	3.800	26.0	7.3				
	D4								
	D5								

NOTE: ONLY use the "Time" column to show the length of time that the total inactivation ratio was less than 1.00.

SUBMITTED BY: _____ Certificate No. and Grade: W00012234 A Date: July 2, 2007

SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER (cont.)
Disinfection Data Page (cont.)

PUBLIC WATER SYSTEM NAME: City of Corsicana
PWS ID No.: 1750002

PLANT NAME OR NUMBER: Lake Halbert
Month: June Year: 2007

DISINFECTION PROCESS PARAMETERS							
APPROVED CT STUDY PARAMETERS					PERFORMANCE STANDARDS		
Parameters	Disinfection Zones					Log Inactivations	
	D1	D2	D3	D4	D5	Giardia lamblia Cysts	Virus
Flow Rate (MGD)	4.000	4.000	4.000				
T ₁₀ (minutes)	78.3	15.1	9.0			0.5	2.0

PERFORMANCE DATA									
DISINFECTION PROCESS DATA									
Date	Disinfectant	C (mg/L)	Flow (MGD)	Temp (°C)	pH	Giardia Log	Virus Log	Inact. Ratio	Time
17	NA D1								
	FCL D2	3.0	2.300	23.0	7.5				
	CLA D3	3.4	2.300	25.0	7.4				
	D4								
	D5								
18	NA D1								
	FCL D2	3.8	3.800	26.0	7.2				
	CLA D3	3.5	3.800	26.0	7.1				
	D4								
	D5								
19	NA D1								
	FCL D2	3.7	2.300	27.0	7.4				
	CLA D3	3.7	2.300	28.0	7.2				
	D4								
	D5								
20	NA D1								
	FCL D2	3.2	2.400	27.0	7.5				
	CLA D3	3.3	2.400	27.0	7.6				
	D4								
	D5								
21	NA D1								
	FCL D2	3.4	2.400	27.0	7.1				
	CLA D3	3.7	2.400	27.0	7.0				
	D4								
	D5								
22	NA D1								
	FCL D2	3.0	3.800	26.0	7.3				
	CLA D3	2.0	3.800	26.0	7.2				
	D4								
	D5								
23	NA D1								
	FCL D2	3.8	3.800	26.0	7.6				
	FCL D3	2.9	3.800	26.0	7.5				
	D4								
	D5								
24	NA D1								
	FCL D2	3.5	2.000	27.0	7.4				
	FCL D3	3.3	2.000	26.0	7.3				
	D4								
	D5								

PERFORMANCE DATA									
DISINFECTION PROCESS DATA									
Date	Disinfectant	C (mg/L)	Flow (MGD)	Temp (°C)	pH	Giardia Log	Virus Log	Inact. Ratio	Time
25	NA D1								
	FCL D2	3.4	2.400	28.0	7.3				
	FCL D3	3.6	2.400	28.0	7.3				
	D4								
	D5								
26	NA D1								
	FCL D2	3.8	3.900	27.0	7.3				
	FCL D3	3.4	3.900	27.0	7.3				
	D4								
	D5								
27	NA D1								
	FCL D2	3.1	3.900	26.0	7.4				
	FCL D3	2.7	3.900	26.0	7.4				
	D4								
	D5								
28	NA D1								
	FCL D2	3.5	3.900	25.0	7.2				
	FCL D3	2.8	3.900	27.0	7.3				
	D4								
	D5								
29	NA D1								
	FCL D2	4.4	2.400	26.0	7.2				
	FCL D3	2.1	2.400	27.0	7.5				
	D4								
	D5								
30	NA D1								
	FCL D2	4.2	2.400	26.0	7.2				
	FCL D3	3.5	2.400	27.0	7.2				
	D4								
	D5								
31	D1								
	D2								
	D3								
	D4								
	D5								

Max	NA	NA
Min	NA	NA
Avg	NA	NA
SD	NA	NA

NOTE: ONLY use the "Time" column to show the length of time that the total inactivation ratio was less than 1.00.

SUBMITTED BY: _____ Certificate No. and Grade: W00012234 A Date: July 2, 2007