

SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER

Summary Page

PUBLIC WATER SYSTEM NAME: <u>City of Corsicana</u>	PLANT NAME OR NUMBER: <u>Lake Halbert</u>
I certify that I am familiar with the information contained in this report and that, to the best of my knowledge, the information is true, complete, and accurate.	
PWS ID No.: <u>1750002</u> Report for the Month of: <u>March 2007</u>	Operator's Signature: _____ Certificate No. & Grade: <u>W00012234 A</u> Date: <u>April 2, 2007</u>

TREATMENT PLANT PERFORMANCE			
Total number of turbidity readings:	168	Number of 4-hour periods when plant was off-line:	18
Number of readings above 0.10 NTU:	34	Number of 4-hour periods when plant was on-line but turbidity data was not collected:	0
Number of readings above 0.3 NTU:	0		
Number of readings above 0.5 NTU:	0		
Number of readings above 1.0 NTU:	0		
Maximum allowable turbidity level:	0.3	Number of days with readings above 1.0 NTU:	0 (2)
Percentage of readings above this limit:	0.0 % (1)	Number of days with readings above 5.0 NTU:	0 (3)
Statistical Summary	Maximum turbidity reading:	Average turbidity value:	0.09 NTU
	Minimum turbidity reading:	Standard deviation:	0.026 NTU
Additional report(s) for individual filter monitoring required:		<input checked="" type="radio"/> NONE <input type="radio"/> Filter Profile <input type="radio"/> Filter Assessment <input type="radio"/> CPE	
Additional report(s) for individual filter monitoring submitted:		<input checked="" type="radio"/> NONE <input type="radio"/> Filter Profile <input type="radio"/> Filter Assessment <input type="radio"/> CPE	
		Number of days when plant was on-line but individual filter turbidity data was not collected: <u>0</u>	
Number of days with a low CT for no more than 4.0 consecutive hours:	0	Average log inactivation for Giardia:	NA
Number of days with a low CT for more than 4.0 consecutive hours:	0 (4)	Average log inactivation for viruses:	NA
		Number of days when profiling data was not collected:	30
		Number of days when CT data was not collected:	30
Minimum disinfectant residual required leaving the plant:	0.5 mg/L	<input type="radio"/> Free Chlorine <input checked="" type="radio"/> Total Chlorine	
Number of days with a low residual for no more than 4.0 consecutive hours:	0		
Number of days with a low residual for more than 4.0 consecutive hours:	0 (5)	Number of days when disinfectant residual leaving the plant was not properly monitored:	0

DISTRIBUTION SYSTEM			
Minimum disinfectant residual required in distribution system:	0.5 mg/L	<input type="radio"/> Free Chlorine <input checked="" type="radio"/> Total Chlorine	
Total number of readings this month:	61	Percentage of readings with a low residual this month:	0.0 % (6A)
Average disinfectant residual value:	2.32	Percentage of readings with a low residual last month:	0.0 % (6B)
Number of readings with a low residual:	0		
Number of readings with no detectable residual:	0		

PUBLIC NOTIFICATION			
TREATMENT TECHNIQUE VIOLATIONS	YES/NO	If YES, date when notice was given to:	
		COMMISSIONERS	CUSTOMERS*
Were more than 5.0% of the turbidity readings above the acceptable level? - see (1) above	No		
Were there any days with turbidity readings above 1.0 NTU? - see (2) above	No		
Were there any days with turbidity readings above 5.0 NTU? - see (3) above	No		
Were there any periods when the plant failed to meet the CT requirements for more than 4.0 consecutive hours? - see (4) above	No		
Were there any periods when the residuals leaving the plant fell below the acceptable level for more than 4.0 consecutive hours? - see (5) above	No		
Were more than 5.0% of the residuals in the distribution system below the acceptable level for two months in a row? - see (6A) and (6B) above	No		

Due by the end of the next business day.
 * Copies of each Public Notice must accompany this report.

Submit the report by the 10th of the month following the reporting period to:
 TEXAS COMMISSION ON ENVIRONMENTAL QUALITY
 WATER SUPPLY DIVISION/PUBLIC DRINKING WATER SECTION (MC-155)
 P.O. BOX 13087, AUSTIN, TEXAS 78711-3087

SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER (cont.)

Turbidity Data Page

PUBLIC WATER SYSTEM NAME: City of Corsicana

PLANT NAME OR NUMBER: Lake Halbert

PWS ID No.: 1750002

Connections: 11,500

Month: March Year: 2007

Population: 28,500

PERFORMANCE DATA																		
Date	Raw Water Pumpage (MGD)	Treated Water Pumpage (MGD)	RAW WATER ANALYSES		SETTLED WATER TURBIDITY (Optional Data)						FINISHED WATER QUALITY							
			NTU	Alk.	Basin No.						Turbidity						Lowest Residual	Time
					1	2	3	4	5	6	NTU1	NTU2	NTU3	NTU4	NTU5	NTU6		
1	3.146	3.097	54	99							0.07	0.07	0.09	0.09	0.07	0.07	3.4	
2	3.234	3.201	55	98							0.08	0.08	0.11	0.07	0.06	0.06	3.5	
3	3.254	3.123	54	100							0.08	0.07	0.07	0.07	0.06	0.07	3.6	
4	3.211	3.166	54	107							0.06	0.07	0.07	0.06	0.07	0.06	3.3	
5	3.224	3.070	44	105							0.06	0.06	0.07	0.06	0.06	0.06	3.4	
6	1.071	1.040	45	108							0.07	X	X	X	0.08	0.09	3.6	
7	1.025	1.023	30	96							0.07	0.08	0.07	0.07	X	X	3.6	
8	1.005	0.780	39	98							X	X	X	X	0.09	0.07	3.2	
9	1.902	1.834	29	98							0.07	0.08	0.10	0.07	0.07	0.06	3.3	
10	1.965	1.748	37	106							0.06	0.06	0.06	0.06	0.05	0.05	3.5	
11	2.039	1.973	41	103							0.10	0.07	0.07	0.06	0.05	0.05	2.8	
12	2.450	2.447	38	109							0.10	0.11	0.13	0.13	0.10	0.10	3.2	
13	2.131	2.102	37	107							0.08	0.09	0.10	0.07	0.09	0.10	3.1	
14	3.204	3.067	36	110							0.08	0.08	0.08	0.09	0.07	0.07	3.1	
15	3.216	3.175	34	99							0.10	0.09	0.10	0.10	0.08	0.07	3.1	
16	3.195	3.077	40	101							0.09	0.10	0.10	0.09	0.11	0.08	3.1	
17	2.864	2.674	37	97							0.08	0.09	0.08	0.08	0.09	0.08	3.4	
18	3.184	3.115	33	103							0.10	0.10	0.11	0.09	0.09	0.08	3.3	
19	2.468	2.333	34	101							0.09	0.08	0.12	0.10	0.10	0.10	3.0	
20	3.230	3.220	37	101							0.11	0.10	0.11	0.11	0.10	0.11	3.2	
21	3.206	2.932	40	98							0.09	0.09	0.12	0.13	0.13	0.15	3.1	
22	3.269	3.221	43	99							0.13	0.10	0.10	0.09	0.09	0.10	3.2	
23	3.296	3.226	38	96							0.10	0.09	0.09	0.10	0.11	0.11	3.2	
24	3.233	3.110	45	96							0.10	0.11	0.11	0.11	0.10	0.11	1.7	
25	3.145	3.047	37	97							0.09	0.09	0.09	0.09	0.08	0.08	3.3	
26	3.277	3.270	44	95							0.10	0.09	0.12	0.10	0.10	0.11	3.3	
27	3.199	3.094	44	91							0.16	0.11	0.10	0.11	0.10	0.10	3.2	
28	3.215	3.079	43	92							0.11	0.11	0.10	0.11	0.12	0.10	3.0	
29	2.687	2.645	45	98							0.09	0.08	0.08	0.08	0.07	X	3.1	
30	0.000	0.000	X	X	X	X					X	X	X	X	X	X	X	
31	2.295	2.245	98	69							X	X	0.22	0.21	0.20	0.10	3.1	
Total	81.840	79.134																
Avg	2.640	2.553																
Max	3.296	3.270																
Min	0.000	0.000																

NOTE: ONLY use the "Time" column to show the length of time that the disinfectant residual entering the distribution system fell below the acceptable level.

SUBMITTED BY: _____ Certificate No. and Grade: W00012234 A Date: April 2, 2007

SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER (cont.)

Filter Data Page

PUBLIC WATER
SYSTEM NAME: City of Corsicana
PWS ID No.: 1750002

PLANT NAME
OR NUMBER: Lake Halbert
Month: March Year: 2007

PERFORMANCE DATA																				
INDIVIDUAL FILTER TURBIDITY																				
Date	Filter No. 1		Filter No. 2		Filter No. 3		Filter No. 4		Filter No. 5		Filter No. 6		Filter No. 7		Filter No. 8		Filter No. 9		Filter No. 10	
	Max	4 Hrs																		
1	0.11	0.11	0.09	0.09	0.07	X	0.13	X												
2	0.07	X	0.07	X	0.11	0.11	0.10	X												
3	0.10	0.10	0.10	0.10	0.07	X	0.08	X												
4	0.06	X	0.07	X	0.10	0.10	0.07	X												
5	0.09	0.09	0.09	0.09	0.09	X	0.07	X												
6	0.07	0.05	0.07	0.06	0.07	0.06	0.07	0.07												
7	0.05	X	0.05	X	0.06	X	0.08	X												
8	0.05	0.05	X	X	0.06	0.06	0.08	0.08												
9	0.09	0.09	X	X	0.08	0.08	0.08	X												
10	0.06	X	X	X	0.07	X	0.07	X												
11	0.06	X	X	X	0.11	0.11	0.07	X												
12	0.13	0.12	X	X	0.09	X	0.07	X												
13	0.14	0.14	0.05	0.05	0.07	0.06	0.07	0.06												
14	0.12	X	0.12	0.12	0.12	0.12	0.10	0.09												
15	0.14	0.14	0.11	X	0.10	X	0.11	X												
16	0.14	0.14	0.13	0.13	0.14	0.14	0.10	X												
17	0.13	X	0.14	0.14	0.12	X	0.16	0.16												
18	0.14	0.14	0.12	X	0.10	0.10	0.15	X												
19	0.14	0.14	0.12	0.12	0.13	0.13	0.10	X												
20	0.12	X	0.11	X	0.12	X	0.10	X												
21	0.15	0.15	0.14	0.14	0.14	0.14	0.16	0.16												
22	0.14	0.14	0.11	X	0.12	X	0.15	X												
23	0.11	X	0.09	0.09	0.09	0.09	0.09	X												
24	0.12	0.12	0.08	0.08	0.09	X	0.27	0.27												
25	0.11	0.11	0.11	0.11	0.12	0.12	0.12	X												
26	0.11	0.11	0.11	0.11	0.08	X	0.11	X												
27	0.11	X	0.11	X	0.10	0.10	0.11	X												
28	0.13	0.13	0.10	0.09	0.10	0.10	0.11	0.10												
29	0.11	0.10	0.08	X	0.09	X	0.09	X												
30	X	X	X	X	X	X	X	X												
31	0.20	0.20	0.18	0.14	0.20	0.16	0.13	0.13												

SUMMARY & COMPLIANCE ACTIONS	Criteria											Plant
	Filter No.											
	1	2	3	4	5	6	7	8	9	10		
	Number of days with event(s) above 0.5 NTU at 4.0 hrs this month	0	0	0	0							
	Number of days with event(s) above 1.0 NTU this month	0	0	0	0							
	Number of days with event(s) above 1.0 NTU last month	0	0	0	0							
	Number of days with event(s) above 1.0 NTU two months ago	0	0	0	0							
	Total number of days with event(s) above 1.0 NTU in three months	0	0	0	0							
	Number of days with event(s) above 2.0 NTU this month											0
	Number of days with event(s) above 2.0 NTU last month											0
Does the plant have an approved Corrective Action Plan?	N	N	N	N							N	
Is the plant required to submit a Filter Profile Report?	N	N	N	N								
Is the plant required to submit a Filter Assessment Report?	N	N	N	N								
Is the plant required to submit a Request for Compliance CPE?											N	

SUBMITTED BY: _____ Certificate No. and Grade: W00012234 A Date: April 2, 2007

SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER (cont.)
Disinfection Data Page

PUBLIC WATER SYSTEM NAME: City of Corsicana
PWS ID No.: 1750002

PLANT NAME OR NUMBER: Lake Halbert
Month: March Year: 2007

DISINFECTION PROCESS PARAMETERS							
APPROVED CT STUDY PARAMETERS					PERFORMANCE STANDARDS		
Parameters	Disinfection Zones				Log Inactivations		
	D1	D2	D3	D4	D5	Giardia lamblia Cysts	Viruses
Flow Rate (MGD)	4.000	4.000	4.000			0.5	2.0
T ₁₀ (minutes)	78.3	15.1	9.0				

PERFORMANCE DATA									
DISINFECTION PROCESS DATA									
Date	Disinfectant	C (mg/L)	Flow (MGD)	Temp (°C)	pH	Giardia Log	Virus Log	Inact. Ratio	Time
1	NA D1								
	FCL D2	3.6	3.500	15.0	7.7				
	CLA D3	3.5	3.500	15.0	7.6				
	D4								
	D5								
2	NA D1								
	FCL D2	3.7	3.500	14.0	7.3				
	CLA D3	3.7	3.500	14.0	7.1				
	D4								
	D5								
3	NA D1								
	FCL D2	3.9	3.500	15.0	7.4				
	CLA D3	3.6	3.500	15.0	7.4				
	D4								
	D5								
4	NA D1								
	FCL D2	3.8	3.500	15.0	7.5				
	CLA D3	3.5	3.500	15.0	7.5				
	D4								
	D5								
5	NA D1								
	FCL D2	3.6	3.500	15.0	7.5				
	CLA D3	3.4	3.500	14.0	7.6				
	D4								
	D5								
6	NA D1								
	FCL D2	3.8	3.500	14.0	7.7				
	CLA D3	3.6	3.500	13.0	7.6				
	D4								
	D5								
7	NA D1								
	FCL D2	3.9	2.200	15.0	7.7				
	CLA D3	4.0	2.200	13.0	7.7				
	D4								
	D5								
8	NA D1								
	FCL D2	3.9	2.200	15.0	6.6				
	CLA D3	3.3	2.200	14.0	7.5				
	D4								
	D5								

PERFORMANCE DATA									
DISINFECTION PROCESS DATA									
Date	Disinfectant	C (mg/L)	Flow (MGD)	Temp (°C)	pH	Giardia Log	Virus Log	Inact. Ratio	Time
9	NA D1								
	FCL D2	4.0	2.200	15.0	7.2				
	CLA D3	3.9	2.200	15.0	7.2				
	D4								
	D5								
10	NA D1								
	FCL D2	3.3	2.500	17.0	7.6				
	CLA D3	3.6	2.500	16.0	7.8				
	D4								
	D5								
11	NA D1								
	FCL D2	3.9	2.500	17.0	7.6				
	CLA D3	3.9	2.500	17.0	7.7				
	D4								
	D5								
12	NA D1								
	FCL D2	3.3	2.900	18.0	7.4				
	CLA D3	3.6	2.900	17.0	7.6				
	D4								
	D5								
13	NA D1								
	FCL D2	3.7	3.500	19.0	7.2				
	CLA D3	3.1	3.500	18.0	7.6				
	D4								
	D5								
14	NA D1								
	FCL D2	3.5	3.500	19.0	7.4				
	CLA D3	3.3	3.500	18.0	7.4				
	D4								
	D5								
15	NA D1								
	FCL D2	3.4	3.500	19.0	7.8				
	CLA D3	3.2	3.500	18.0	7.7				
	D4								
	D5								
16	NA D1								
	FCL D2	3.4	3.500	19.0	7.4				
	CLA D3	3.1	3.500	19.0	7.2				
	D4								
	D5								

NOTE: ONLY use the "Time" column to show the length of time that the total inactivation ratio was less than 1.00.

SUBMITTED BY: _____ Certificate No. and Grade: W00012234 A Date: April 2, 2007

SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER (cont.)
Disinfection Data Page (cont.)

PUBLIC WATER SYSTEM NAME: City of Corsicana
PWS ID No.: 1750002

PLANT NAME OR NUMBER: Lake Halbert
Month: March Year: 2007

DISINFECTION PROCESS PARAMETERS							
APPROVED CT STUDY PARAMETERS					PERFORMANCE STANDARDS		
Parameters	Disinfection Zones					Log Inactivations	
	D1	D2	D3	D4	D5	Giardia lamblia Cysts	Virus
Flow Rate (MGD)	4.000	4.000	4.000			0.5	2.0
T ₁₀ (minutes)	78.3	15.1	9.0				

PERFORMANCE DATA									
DISINFECTION PROCESS DATA									
Date	Disinfectant	C (mg/L)	Flow (MGD)	Temp (°C)	pH	Giardia Log	Virus Log	Inact. Ratio	Time <input type="checkbox"/>
17	NA D1								
	FCL D2	3.6	3.500	18.0	7.4				
	CLA D3	3.5	3.500	18.0	7.3				
	D4								
	D5								
18	NA D1								
	FCL D2	3.9	3.500	20.0	7.5				
	CLA D3	3.7	3.500	18.0	7.5				
	D4								
	D5								
19	NA D1								
	FCL D2	3.8	3.500	20.0	7.2				
	CLA D3	3.6	3.500	18.0	7.1				
	D4								
	D5								
20	NA D1								
	FCL D2	3.7	3.500	19.0	7.5				
	CLA D3	3.7	3.500	19.0	7.3				
	D4								
	D5								
21	NA D1								
	FCL D2	3.9	3.500	19.0	7.6				
	CLA D3	3.3	3.500	20.0	7.5				
	D4								
	D5								
22	NA D1								
	FCL D2	3.9	3.500	20.0	7.5				
	CLA D3	3.7	3.500	19.0	7.5				
	D4								
	D5								
23	NA D1								
	FCL D2	3.5	3.500	20.0	7.3				
	CLA D3	3.3	3.500	19.0	7.4				
	D4								
	D5								
24	NA D1								
	FCL D2	3.9	3.500	20.0	7.0				
	CLA D3	3.8	3.500	20.0	7.0				
	D4								
	D5								

PERFORMANCE DATA									
DISINFECTION PROCESS DATA									
Date	Disinfectant	C (mg/L)	Flow (MGD)	Temp (°C)	pH	Giardia Log	Virus Log	Inact. Ratio	Time <input type="checkbox"/>
25	NA D1								
	FCL D2	3.6	3.500	20.0	7.3				
	CLA D3	3.6	3.500	20.0	7.1				
	D4								
	D5								
26	NA D1								
	FCL D2	3.8	3.500	22.0	7.3				
	CLA D3	3.6	3.500	21.0	7.3				
	D4								
	D5								
27	NA D1								
	FCL D2	3.7	3.500	21.0	7.6				
	CLA D3	3.3	3.500	21.0	7.6				
	D4								
	D5								
28	NA D1								
	FCL D2	3.9	3.500	22.0	7.5				
	CLA D3	3.8	3.500	21.0	7.7				
	D4								
	D5								
29	NA D1								
	FCL D2	3.7	3.500	22.0	7.8				
	CLA D3	3.3	3.500	21.0	7.7				
	D4								
	D5								
30	NA D1								
	NA D2								
	NA D3					NA	NA	NA	
	D4								
	D5								
31	NA D1								
	FCL D2	4.5	3.500	20.0	7.2				
	CLA D3	3.3	3.500	21.0	7.2				
	D4								
	D5								
						Max	NA	NA	
						Min	NA	NA	
						Avg	NA	NA	
						SD	NA	NA	

NOTE: ONLY use the "Time

SUBMITTED BY: _____ Certificate No. and Grade: W00012234 A Date: April 2, 2007