

SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER

Summary Page

PUBLIC WATER SYSTEM NAME: City of Corsicana

PLANT NAME OR NUMBER: Lake Halbert

I certify that I am familiar with the information contained in this report and that, to the best of my knowledge, the information is true, complete, and accurate.

PWS ID No.: 1750002
Report for the Month of: December 2006

Operator's Signature: _____
Certificate No. & Grade: W00012234 A Date: January 2, 2007

TREATMENT PLANT PERFORMANCE			
Total number of turbidity readings:	<u>171</u>	Number of 4-hour periods when plant was off-line:	<u>15</u>
Number of readings above 0.10 NTU:	<u>29</u>	Number of 4-hour periods when plant was on-line but turbidity data was not collected:	<u>0</u>
Number of readings above 0.3 NTU:	<u>0</u>		
Number of readings above 0.5 NTU:	<u>0</u>		
Number of readings above 1.0 NTU:	<u>0</u>		
Maximum allowable turbidity level:	<u>0.3</u>	Number of days with readings above 1.0 NTU:	<u>0</u> (2)
Percentage of readings above this limit:	<u>0.0</u> % (1)	Number of days with readings above 5.0 NTU:	<u>0</u> (3)
Statistical Summary	Maximum turbidity reading: <u>0.14</u> NTU	Average turbidity value:	<u>0.09</u> NTU
	Minimum turbidity reading: <u>0.05</u> NTU	Standard deviation:	<u>0.020</u> NTU
Additional report(s) for individual filter monitoring required:	<input checked="" type="radio"/> NONE <input type="radio"/> Filter Profile <input type="radio"/> Filter Assessment <input type="radio"/> CPE		
Additional report(s) for individual filter monitoring submitted:	<input checked="" type="radio"/> NONE <input type="radio"/> Filter Profile <input type="radio"/> Filter Assessment <input type="radio"/> CPE		
	Number of days when plant was on-line but individual filter turbidity data was not collected: <u>0</u>		
Number of days with a low CT for no more than 4.0 consecutive hours:	<u>0</u>	Average log inactivation for Giardia:	<u>NA</u>
Number of days with a low CT for more than 4.0 consecutive hours:	<u>0</u> (4)	Average log inactivation for viruses:	<u>NA</u>
		Number of days when profiling data was not collected:	<u>30</u>
		Number of days when CT data was not collected:	<u>30</u>
Minimum disinfectant residual required leaving the plant:	<u>0.5</u> mg/L	<input type="radio"/> Free Chlorine <input checked="" type="radio"/> Total Chlorine	
Number of days with a low residual for no more than 4.0 consecutive hours:	<u>0</u>		
Number of days with a low residual for more than 4.0 consecutive hours:	<u>0</u> (5)	Number of days when disinfectant residual leaving the plant was not properly monitored:	<u>0</u>

DISTRIBUTION SYSTEM			
Minimum disinfectant residual required in distribution system:	<u>0.5</u> mg/L	<input type="radio"/> Free Chlorine <input checked="" type="radio"/> Total Chlorine	
Total number of readings this month:	<u>56</u>		
Average disinfectant residual value:	<u>2.30</u>	Percentage of readings with a low residual this month:	<u>0.0</u> % (6A)
Number of readings with a low residual:	<u>0</u>		
Number of readings with no detectable residual:	<u>0</u>	Percentage of readings with a low residual last month:	<u>0.0</u> % (6B)

PUBLIC NOTIFICATION			
TREATMENT TECHNIQUE VIOLATIONS	YES/NO	If YES, date when notice was given to:	
		COMMISSION	CUSTOMERS*
Were more than 5.0% of the turbidity readings above the acceptable level? - see (1) above	No		
Were there any days with turbidity readings above 1.0 NTU? - see (2) above	No		
Were there any days with turbidity readings above 5.0 NTU? - see (3) above	No		
Were there any periods when the plant failed to meet the CT requirements for more than 4.0 consecutive hours? - see (4) above	No		
Were there any periods when the residuals leaving the plant fell below the acceptable level for more than 4.0 consecutive hours? - see (5) above	No		
Were more than 5.0% of the residuals in the distribution system below the acceptable level for two months in a row? - see (6A) and (6B) above	No		

Due by the end of the next business day.

* Copies of each Public Notice must accompany this report.

Submit the report by the 10th of the month following the reporting period to:

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY
WATER SUPPLY DIVISION/PUBLIC DRINKING WATER SECTION (MC-155)
P.O. BOX 13087, AUSTIN, TEXAS 78711-3087

SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER (cont.)

Turbidity Data Page

PUBLIC WATER SYSTEM NAME: City of Corsicana

PLANT NAME OR NUMBER: Lake Halbert

PWS ID No.: 1750002

Connections: 8,734

Month: December Year: 2006

Population: 24,485

PERFORMANCE DATA																		
Date	Raw Water Pumpage (MGD)	Treated Water Pumpage (MGD)	RAW WATER ANALYSES		SETTLED WATER TURBIDITY (Optional Data)						FINISHED WATER QUALITY							
			NTU	Alk.	Basin No.						Turbidity						Lowest Residual	Time
					1	2	3	4	5	6	NTU1	NTU2	NTU3	NTU4	NTU5	NTU6		
1	3.249	3.068	28	119							0.10	0.11	0.05	0.06	0.06	0.10	3.1	
2	0.730	0.729	31	120							0.08	0.08	X	X	X	X	3.6	
3	0.000	0.000	X	X	X	X					X	X	X	X	X	X	X	
4	2.815	2.809	31	121							X	X	0.08	0.07	0.08	0.08	2.6	
5	3.505	3.396	30	123							0.06	0.06	0.08	0.08	0.09	0.08	2.4	
6	3.608	3.566	25	123							0.06	0.06	0.10	0.07	0.06	0.10	3.0	
7	3.493	3.383	22	120							0.07	0.08	0.08	0.08	0.06	0.08	3.1	
8	3.556	3.467	25	120							0.07	0.08	0.07	0.06	0.07	0.06	2.7	
9	2.850	2.820	31	119							0.07	0.07	0.08	0.08	0.08	0.08	2.6	
10	3.299	3.156	30	121							0.08	0.07	0.08	0.08	0.07	0.05	3.0	
11	3.090	3.085	22	125							0.07	0.08	0.10	0.10	0.08	0.08	3.0	
12	3.261	3.202	26	124							0.07	0.08	0.09	0.08	0.08	0.08	3.1	
13	3.260	3.151	30	124							0.09	0.09	0.11	0.11	0.11	0.09	3.0	
14	3.300	3.295	31	121							0.12	0.12	0.13	0.11	0.11	0.09	3.2	
15	3.162	3.111	24	120							0.11	0.10	0.11	0.05	0.08	0.07	2.9	
16	3.187	3.063	32	120							0.07	0.06	0.07	0.08	0.08	0.07	2.6	
17	3.186	3.150	37	122							0.07	0.06	0.07	0.08	0.07	0.07	3.0	
18	3.174	3.100	29	122							0.08	0.07	0.06	0.07	0.09	0.07	2.1	
19	3.233	3.189	21	118							0.06	0.06	0.06	0.06	0.08	0.08	3.0	
20	1.741	1.661	18	124							0.06	0.07	0.08	X	X	X	3.2	
21	3.249	3.169	12	129							0.08	0.08	0.08	0.07	0.07	0.07	2.7	
22	3.188	3.087	13	127							0.06	0.07	0.09	0.09	0.09	0.09	3.1	
23	3.259	3.159	13	125							0.09	0.08	0.08	0.08	0.10	0.08	3.2	
24	3.181	3.071	14	124							0.08	0.10	0.09	0.10	0.10	0.09	3.2	
25	2.275	2.244	23	127							0.12	0.10	0.11	0.10	0.09	0.10	3.5	
26	3.265	3.205	22	128							0.09	0.09	0.11	0.09	0.10	0.10	2.9	
27	3.222	3.142	22	127							0.10	0.10	0.11	0.12	0.10	0.12	3.0	
28	3.200	3.199	21	133							0.12	0.12	0.13	0.14	0.10	0.11	2.8	
29	3.223	3.138	26	137							0.12	0.12	0.13	0.14	0.12	0.10	2.0	
30	3.268	3.132	28	129							0.12	0.12	0.08	0.07	0.07	0.06	2.3	
31	3.214	3.155	22	128							0.06	0.07	0.08	0.08	0.07	0.06	2.9	
Total	92.243	90.102																
Avg	2.976	2.907																
Max	3.608	3.566																
Min	0.000	0.000																

NOTE: ONLY use the "Time" column to show the length of time that the disinfectant residual entering the distribution system fell below the acceptable level.

SUBMITTED BY: _____ Certificate No. and Grade: W00012234 A Date: January 2, 2007

SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER (cont.)
Filter Data Page

PUBLIC WATER
SYSTEM NAME: City of Corsicana
PWS ID No.: 1750002

PLANT NAME
OR NUMBER: Lake Halbert
Month: December Year: 2006

PERFORMANCE DATA																				
INDIVIDUAL FILTER TURBIDITY																				
Date	Filter No. 1		Filter No. 2		Filter No. 3		Filter No. 4		Filter No. 5		Filter No. 6		Filter No. 7		Filter No. 8		Filter No. 9		Filter No. 10	
	Max	4 Hrs																		
1	0.06	X	0.09	0.09	0.07	X	0.10	0.10												
2	0.08	0.08	0.08	X	0.06	X	0.09	X												
3	X	X	X	X	X	X	X	X												
4	0.07	0.07	0.07	0.07	0.05	0.04	0.10	0.08												
5	0.09	0.09	0.06	X	0.09	0.09	0.07	X												
6	0.08	X	0.06	0.06	0.07	X	0.07	X												
7	0.09	0.09	0.07	X	0.09	0.09	0.07	X												
8	0.07	X	0.06	X	0.08	X	0.09	0.09												
9	0.07	X	0.09	0.09	0.06	X	0.09	X												
10	X	X	0.05	0.05	0.06	X	0.08	X												
11	X	X	0.08	X	0.08	0.08	0.07	X												
12	X	X	0.05	X	0.06	X	0.09	0.09												
13	X	X	0.07	0.07	0.08	0.08	0.09	X												
14	X	X	0.06	X	0.08	X	0.08	X												
15	X	X	0.08	0.08	0.05	X	0.07	X												
16	X	X	0.07	X	0.09	0.09	0.10	0.10												
17	X	X	0.09	0.09	0.06	X	0.09	X												
18	X	X	0.08	X	0.10	0.10	0.08	X												
19	X	X	0.07	0.07	0.08	X	0.07	X												
20	X	X	0.07	X	0.05	X	0.10	0.10												
21	X	X	0.07	0.07	0.08	0.08	0.10	X												
22	X	X	0.07	0.07	0.08	0.08	0.08	X												
23	X	X	0.06	X	0.07	X	0.07	X												
24	X	X	0.08	0.08	0.08	0.08	0.10	0.10												
25	X	X	0.09	0.09	0.07	X	0.10	X												
26	X	X	0.07	X	0.06	X	0.08	X												
27	X	X	0.07	0.07	0.08	0.08	0.09	0.09												
28	X	X	0.08	X	0.06	X	0.08	X												
29	X	X	0.07	0.07	0.08	0.08	0.07	X												
30	X	X	0.06	X	0.06	X	0.09	0.09												
31	X	X	0.07	0.07	0.09	0.08	0.09	X												

SUMMARY & COMPLIANCE ACTIONS	Criteria	Filter No.										Plant	
		1	2	3	4	5	6	7	8	9	10		
	Number of days with event(s) above 0.5 NTU at 4.0 hrs this month	0	0	0	0								
	Number of days with event(s) above 1.0 NTU this month	0	0	0	0								
	Number of days with event(s) above 1.0 NTU last month	0	0	0	0								
	Number of days with event(s) above 1.0 NTU two months ago	0	0	0	0								
	Total number of days with event(s) above 1.0 NTU in three months	0	0	0	0								
	Number of days with event(s) above 2.0 NTU this month											0	
	Number of days with event(s) above 2.0 NTU last month											0	
	Does the plant have an approved Corrective Action Plan?	N	N	N	N							N	
Is the plant required to submit a Filter Profile Report?	N	N	N	N									
Is the plant required to submit a Filter Assessment Report?	N	N	N	N									
Is the plant required to submit a Request for Compliance CPE?											N		

SUBMITTED BY: _____ Certificate No. and Grade: W00012234 A Date: January 2, 2007

SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER (cont.)
Disinfection Data Page

PUBLIC WATER SYSTEM NAME: City of Corsicana
PWS ID No.: 1750002

PLANT NAME OR NUMBER: Lake Halbert
Month: December Year: 2006 PWS IC

DISINFECTION PROCESS PARAMETERS										
APPROVED CT STUDY PARAMETERS					PERFORMANCE STANDARDS					
Parameters	Disinfection Zones					Log Inactivations				Parar
	D1	D2	D3	D4	D5	Giardia lamblia Cysts		Viruses		
Flow Rate (MGD)	4.000	4.000	4.000			0.5		2.0		Flow
T ₁₀ (minutes)	78.3	15.1	9.0							T ₁₀ (m

PERFORMANCE DATA										
DISINFECTION PROCESS DATA										
Date	Disinfectant	C (mg/L)	Flow (MGD)	Temp (°C)	pH	Giardia Log	Virus Log	Inact. Ratio	Time	
1	NA D1									
	FCL D2	3.9	3.800	16.0	7.6					
	CLA D3	3.3	3.800	16.0	7.5					
	D4									
	D5									
2	NA D1									
	FCL D2	4.0	3.800	13.0	7.5					
	CLA D3	3.7	3.800	12.0	7.4					
	D4									
	D5									
3	NA D1									
	NA D2					NA	NA	NA		
	NA D3									
	D4									
	D5									
4	NA D1									
	FCL D2	2.9	3.800	12.0	7.4					
	CLA D3	2.6	3.800	11.0	7.5					
	D4									
	D5									
5	NA D1									
	FCL D2	3.3	3.800	11.0	7.6					
	CLA D3	2.8	3.800	11.0	7.7					
	D4									
	D5									
6	NA D1									
	FCL D2	3.6	3.800	11.0	7.6					
	CLA D3	3.0	3.800	11.0	7.5					
	D4									
	D5									
7	NA D1									
	FCL D2	3.6	3.800	12.0	7.6					
	CLA D3	3.2	3.800	10.0	7.7					
	D4									
	D5									
8	NA D1									
	FCL D2	3.7	3.800	11.0	7.6					
	CLA D3	3.3	3.800	10.0	7.5					
	D4									
	D5									

PERFORMANCE DATA										
DISINFECTION PROCESS DATA										
Date	Disinfectant	C (mg/L)	Flow (MGD)	Temp (°C)	pH	Giardia Log	Virus Log	Inact. Ratio	Time	Date
9	NA D1									17
	FCL D2	3.9	3.800	11.0	7.5					
	CLA D3	4.0	3.800	9.0	7.5					
	D4									
	D5									
10	NA D1									18
	FCL D2	3.4	3.500	9.0	7.5					
	CLA D3	3.0	3.500	9.0	7.5					
	D4									
	D5									
11	NA D1									19
	FCL D2	3.2	3.500	12.0	7.5					
	CLA D3	3.5	3.500	11.0	7.5					
	D4									
	D5									
12	NA D1									20
	FCL D2	3.6	3.500	10.0	7.5					
	CLA D3	3.3	3.500	10.0	7.5					
	D4									
	D5									
13	NA D1									21
	FCL D2	3.6	3.500	11.0	7.6					
	CLA D3	3.3	3.500	10.0	7.6					
	D4									
	D5									
14	NA D1									22
	FCL D2	3.7	3.500	12.0	7.6					
	CLA D3	3.2	3.500	11.0	7.6					
	D4									
	D5									
15	NA D1									23
	FCL D2	3.6	3.500	12.0	7.5					
	CLA D3	3.2	3.500	12.0	7.4					
	D4									
	D5									
16	NA D1									24
	FCL D2	3.7	3.500	12.0	7.4					
	CLA D3	3.7	3.500	12.0	7.7					
	D4									
	D5									

NOTE: ONLY use the "Time" column to show the length of time that the total inactivation ratio was less than 1.00.

NOTE:

SUBMITTED BY: _____ Certificate No. _____ and Grade: W00012234 A Date: January 2, 2007 SUBMI

