

# SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES  
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER

## Summary Page

<b>PUBLIC WATER SYSTEM NAME:</b> <u>City of Corsicana</u>	<b>PLANT NAME OR NUMBER:</b> <u>Navarro Mills</u>
I certify that I am familiar with the information contained in this report and that, to the best of my knowledge, the information is true, complete, and accurate.	
<b>PWS ID No.:</b> <u>1750002</u> <b>Report for the Month of:</b> <u>September 2006</u>	<b>Operator's Signature:</b> _____ <b>Certificate No. &amp; Grade:</b> <u>WO0004220 A</u> <b>Date:</b> <u>October 3, 2006</u>

TREATMENT PLANT PERFORMANCE			
Total number of turbidity readings:	180	Number of 4-hour periods when plant was off-line:	0
Number of readings above 0.10 NTU:	3	Number of 4-hour periods when plant was on-line but turbidity data was not collected:	0
Number of readings above 0.3 NTU:	0		
Number of readings above 0.5 NTU:	0		
Number of readings above 1.0 NTU:	0		
Maximum allowable turbidity level:	0.3	Number of days with readings above 1.0 NTU:	0 (2)
Percentage of readings above this limit:	0.0 % (1)	Number of days with readings above 5.0 NTU:	0 (3)
Statistical Summary	Maximum turbidity reading:	0.12 NTU	Average turbidity value:
	Minimum turbidity reading:	0.05 NTU	0.08 NTU
			Standard deviation:
			0.013 NTU
Additional report(s) for individual filter monitoring required:		<input type="radio"/> NONE <input type="radio"/> Filter Profile <input type="radio"/> Filter Assessment <input type="radio"/> CPE	
Additional report(s) for individual filter monitoring submitted:		<input checked="" type="radio"/> NONE <input type="radio"/> Filter Profile <input type="radio"/> Filter Assessment <input type="radio"/> CPE	
#NAME?		Number of days when plant was on-line but individual filter turbidity data was not collected:	0
Number of days with a low CT for no more than 4.0 consecutive hours:	0	Average log inactivation for Giardia:	NA
Number of days with a low CT for more than 4.0 consecutive hours:	0 (4)	Average log inactivation for viruses:	NA
		Number of days when profiling data was not collected:	30
		Number of days when CT data was not collected:	30
Minimum disinfectant residual required leaving the plant:	0.5 mg/L	<input type="radio"/> Free Chlorine <input checked="" type="radio"/> Total Chlorine	
Number of days with a low residual for no more than 4.0 consecutive hours:	0		
Number of days with a low residual for more than 4.0 consecutive hours:	0 (5)	Number of days when disinfectant residual leaving the plant was not properly monitored:	0

DISTRIBUTION SYSTEM			
Minimum disinfectant residual required in distribution system:	0.5 mg/L	<input type="radio"/> Free Chlorine <input checked="" type="radio"/> Total Chlorine	
Total number of readings this month:	55	Percentage of readings with a low residual this month:	0.0 % (6A)
Average disinfectant residual value:	2.69	Percentage of readings with a low residual last month:	0.0 % (6B)
Number of readings with a low residual:	0		
Number of readings with no detectable residual:	0		

PUBLIC NOTIFICATION			
TREATMENT TECHNIQUE VIOLATIONS	YES/NO	If YES, date when notice was given to:	
		COMMISSIONERS	CUSTOMERS*
Were more than 5.0% of the turbidity readings above the acceptable level? - see (1) above	No		
Were there any days with turbidity readings above 1.0 NTU? - see (2) above	No		
Were there any days with turbidity readings above 5.0 NTU? - see (3) above	No		
Were there any periods when the plant failed to meet the CT requirements for more than 4.0 consecutive hours? - see (4) above	No		
Were there any periods when the residuals leaving the plant fell below the acceptable level for more than 4.0 consecutive hours? - see (5) above	No		
Were more than 5.0% of the residuals in the distribution system below the acceptable level for two months in a row? - see (6A) and (6B) above	No		

Due by the end of the next business day.  
 \* Copies of each Public Notice must accompany this report.

**Submit the report by the 10th of the month following the reporting period to:**

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY  
 WATER SUPPLY DIVISION/PUBLIC DRINKING WATER SECTION (MC-155)  
 P.O. BOX 13087, AUSTIN, TEXAS 78711-3087

# SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES  
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER (cont.)

## Turbidity Data Page

PUBLIC WATER SYSTEM NAME: City of Corsicana

PLANT NAME OR NUMBER: Navarro Mills

PWS ID No.: 1750002

Connections: 8,734

Month: September Year: 2006

Population: 24,485

PERFORMANCE DATA																		
Date	Raw Water Pumpage (MGD)	Treated Water Pumpage (MGD)	RAW WATER ANALYSES		SETTLED WATER TURBIDITY (Optional Data)						FINISHED WATER QUALITY							
			NTU	Aik.	Basin No.						Turbidity						Lowest Residual	Time
					1	2	3	4	5	6	NTU1	NTU2	NTU3	NTU4	NTU5	NTU6		
1	8.430	6.637	33	95	0.8	0.8	0.9	0.9	1.0	1.0	0.08	0.07	0.08	0.08	0.06	0.07	3.3	
2	7.420	5.824	33	94	0.7	0.7	1.0	0.8	0.7	0.7	0.07	0.07	0.08	0.08	0.08	0.08	3.4	
3	6.560	5.498	36	97	0.9	0.8	1.1	1.0	0.9	0.8	0.08	0.08	0.07	0.06	0.06	0.06	3.3	
4	4.470	4.411	47	97	0.8	1.0	1.6	1.0	1.0	0.7	0.07	0.06	0.07	0.06	0.09	0.06	3.2	
5	7.700	5.938	42	97	0.9	0.9	1.2	1.0	1.0	0.9	0.06	0.06	0.08	0.08	0.08	0.07	2.7	
6	7.620	6.242	49	99	0.9	0.8	1.2	0.8	0.8	0.7	0.08	0.08	0.08	0.08	0.08	0.07	3.2	
7	6.960	5.642	51	100	0.6	0.6	0.7	0.7	0.6	0.6	0.09	0.08	0.05	0.06	0.06	0.06	3.2	
8	6.630	5.947	46	98	0.9	0.6	0.8	0.8	0.7	0.7	0.07	0.08	0.06	0.06	0.05	0.05	3.2	
9	8.010	5.711	41	96	0.8	0.7	0.9	0.7	0.7	0.7	0.06	0.06	0.05	0.06	0.09	0.08	3.4	
10	7.850	6.476	40	99	0.9	0.8	1.0	0.9	1.1	0.8	0.08	0.08	0.08	0.08	0.08	0.08	3.2	
11	7.440	6.141	44	98	0.8	0.8	1.0	0.8	0.9	0.8	0.08	0.07	0.09	0.08	0.12	0.08	3.2	
12	6.210	5.330	47	99	0.6	0.7	0.7	0.8	0.8	0.8	0.08	0.08	0.07	0.07	0.07	0.06	3.1	
13	7.260	6.218	36	98	0.8	0.8	1.2	0.9	0.8	0.8	0.08	0.07	0.10	0.09	0.09	0.08	3.0	
14	7.250	6.173	30	100	0.6	0.6	0.7	0.8	0.8	0.7	0.08	0.08	0.09	0.09	0.08	0.08	3.0	
15	8.990	6.811	35	95	0.8	0.9	0.9	0.8	0.9	0.8	0.08	0.08	0.10	0.10	0.09	0.08	2.9	
16	6.750	5.193	31	94	0.6	0.5	0.6	0.6	0.6	0.5	0.08	0.08	0.07	0.08	0.10	0.11	2.9	
17	6.590	5.476	28	94	0.7	0.7	0.6	0.6	0.6	0.6	0.08	0.08	0.06	0.06	0.07	0.07	3.0	
18	4.770	4.200	30	96	0.8	0.6	0.8	0.6	0.7	0.5	0.06	0.07	0.06	0.06	0.06	0.07	3.0	
19	6.820	5.383	35	95	0.6	0.7	0.7	0.7	0.7	0.6	0.06	0.06	0.08	0.08	0.08	0.08	2.9	
20	7.100	5.418	35	96	0.7	0.6	1.0	0.7	0.7	0.7	0.08	0.08	0.06	0.07	0.07	0.07	2.9	
21	4.680	4.350	34	95	0.7	0.7	0.7	0.7	0.7	0.7	0.09	0.09	0.07	0.06	0.06	0.07	3.0	
22	9.420	7.361	38	95	0.7	0.7	0.8	0.8	0.7	0.6	0.08	0.07	0.06	0.07	0.06	0.06	3.0	
23	5.350	4.621	36	94	0.6	0.8	0.7	0.6	0.6	0.6	0.06	0.06	0.06	0.06	0.08	0.07	3.1	
24	7.040	5.651	40	94	0.8	1.0	0.8	0.7	0.7	0.7	0.08	0.07	0.10	0.09	0.10	0.09	3.3	
25	8.240	6.385	47	95	0.8	0.8	1.1	0.9	0.8	0.8	0.07	0.08	0.06	0.07	0.10	0.08	2.8	
26	4.660	4.480	47	95	0.8	1.2	1.0	0.9	0.8	0.8	0.08	0.08	0.07	0.07	0.06	0.06	3.0	
27	6.580	4.911	47	93	0.8	1.1	1.1	0.8	0.9	0.8	0.07	0.07	0.09	0.09	0.08	0.08	3.0	
28	6.350	4.973	44	93	0.8	1.0	0.9	0.8	0.8	0.8	0.07	0.07	0.07	0.09	0.11	0.10	3.0	
29	6.030	4.725	45	93	0.9	0.8	1.0	0.9	0.9	0.8	0.08	0.10	0.10	0.09	0.09	0.09	2.9	
30	6.650	5.105	46	92	0.9	0.8	1.1	0.9	0.9	0.8	0.09	0.09	0.08	0.07	0.09	0.08	2.9	
31																		
<b>Total</b>	205.830	167.231																
<b>Avg</b>	6.861	5.574																
<b>Max</b>	9.420	7.361																
<b>Min</b>	4.470	4.200																

NOTE: ONLY use the "Time" column to show the length of time that the disinfectant residual entering the distribution system fell below the acceptable level.

SUBMITTED BY: \_\_\_\_\_ Certificate No. and Grade: WO0004220 A Date: October 3, 2006

# SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES  
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER (cont.)

Filter Data Page

PUBLIC WATER  
SYSTEM NAME: City of Corsicana  
PWS ID No.: 1750002

PLANT NAME  
OR NUMBER: Navarro Mills  
Month: September Year: 2006

PERFORMANCE DATA																				
INDIVIDUAL FILTER TURBIDITY																				
Date	Filter No. 1		Filter No. 2		Filter No. 3		Filter No. 4		Filter No. 5		Filter No. 6		Filter No. 7		Filter No. 8		Filter No. 9		Filter No. 10	
	Max	4 Hrs	Max	4 Hrs																
1	0.14	X	0.21	0.13	0.09	X	0.18	X	0.10	X	0.23	0.20								
2	0.17	X	0.13	X	0.18	0.16	0.10	X	0.08	X	0.16	X								
3	0.52	0.15	0.13	X	0.12	X	0.13	X	0.41	0.11	0.15	X								
4	0.28	X	0.13	X	0.10	X	0.11	X	0.13	X	0.12	X								
5	0.16	X	0.85	0.16	0.19	0.15	0.56	0.16	0.15	X	0.16	X								
6	0.15	X	0.16	X	0.15	X	0.13	X	0.12	X	0.22	0.17								
7	0.31	0.13	0.19	X	0.12	X	0.12	X	0.16	X	0.16	X								
8	0.13	X	0.41	X	0.36	X	0.09	X	0.07	X	0.12	X								
9	0.30	X	0.46	0.17	0.21	0.16	0.35	0.17	0.74	0.11	0.17	X								
10	0.36	X	0.16	X	0.15	X	0.16	X	0.12	X	0.23	0.16								
11	0.21	0.20	0.37	X	0.28	X	0.13	X	0.18	X	0.21	X								
12	0.25	X	0.28	0.26	0.21	X	0.15	X	0.13	X	0.22	X								
13	0.20	X	0.23	X	0.24	0.12	0.21	X	0.16	0.16	0.21	X								
14	0.26	X	0.16	X	0.16	X	0.93	0.17	0.16	X	0.22	0.22								
15	0.93	0.18	0.22	0.15	0.23	0.16	0.15	X	0.12	X	0.23	0.19								
16	0.21	X	0.17	X	0.19	X	0.10	X	0.08	X	0.14	X								
17	0.13	X	0.15	X	0.13	X	0.12	X	0.07	X	0.13	X								
18	0.17	X	0.18	X	0.12	X	0.20	0.15	0.26	0.16	0.20	X								
19	0.65	0.12	0.20	0.13	0.17	X	0.19	X	0.18	X	0.25	0.19								
20	0.14	X	0.20	X	0.18	0.14	0.11	X	0.09	X	0.14	X								
21	0.12	X	0.13	X	0.11	X	0.11	X	0.09	X	0.13	X								
22	0.15	X	0.12	X	0.12	X	0.59	0.12	0.07	X	0.10	X								
23	0.32	X	0.55	X	0.14	X	0.14	X	0.15	0.15	0.22	0.22								
24	0.22	0.16	0.50	0.15	0.23	X	0.16	X	0.16	X	0.22	X								
25	0.15	X	0.18	X	0.34	0.12	0.47	X	0.12	X	0.15	X								
26	0.15	X	0.12	X	0.14	X	0.21	X	0.08	X	0.11	X								
27	0.16	X	0.15	X	0.14	X	0.38	0.13	0.12	0.06	0.16	X								
28	0.26	0.19	0.19	0.12	0.20	X	0.17	X	0.18	X	0.41	0.21								
29	0.30	X	0.19	X	0.13	X	0.13	X	0.14	X	0.17	X								
30	0.27	X	0.21	X	0.31	X	0.15	X	X	X	0.15	X								
31																				

  

SUMMARY & COMPLIANCE ACTIONS	Criteria											Filter No.										Plant
	1	2	3	4	5	6	7	8	9	10	1	2	3	4	5	6	7	8	9	10		
	Number of days with event(s) above 0.5 NTU at 4.0 hrs this month	0	0	0	0	0	0															
	Number of days with event(s) above 1.0 NTU this month	0	0	0	0	0	0															
	Number of days with event(s) above 1.0 NTU last month	0	0	0	0	0	0															
	Number of days with event(s) above 1.0 NTU two months ago	0	0	0	0	0	0															
	Total number of days with event(s) above 1.0 NTU in three months	#####	#####	#####	#####	#####	#####	#####	#####	#####	#####	#####	#####	#####	#####	#####	#####	#####	#####	#####	#####	
	Number of days with event(s) above 2.0 NTU this month																					0
	Number of days with event(s) above 2.0 NTU last month																					0
	Does the plant have an approved Corrective Action Plan?	N	N	N	N	N	N															N
Is the plant required to submit a Filter Profile Report?	#####	#####	#####	#####	#####	#####	#####	#####	#####	#####	#####	#####	#####	#####	#####	#####	#####	#####	#####	#####		
Is the plant required to submit a Filter Assessment Report?	#####	#####	#####	#####	#####	#####	#####	#####	#####	#####	#####	#####	#####	#####	#####	#####	#####	#####	#####	#####		
Is the plant required to submit a Request for Compliance CPE?																					N	

SUBMITTED BY: \_\_\_\_\_ Certificate No. and Grade: WO0004220 A Date: October 3, 2006

# SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES  
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER (cont.)

*Disinfection Data Page*

PUBLIC WATER SYSTEM NAME: City of Corsicana  
PWS ID No.: 1750002

PLANT NAME OR NUMBER: Navarro Mills  
Month: September Year: 2006

DISINFECTION PROCESS PARAMETERS							
APPROVED CT STUDY PARAMETERS					PERFORMANCE STANDARDS		
Parameters	Disinfection Zones					Log Inactivations	
	D1	D2	D3	D4	D5	Giardia lamblia Cysts	Viruses
Flow Rate (MGD)	20.250	20.250	20.250			0.5	2.0
T <sub>10</sub> (minutes)	109.1	13.0	100.0				

PERFORMANCE DATA									
DISINFECTION PROCESS DATA									
Date	Disinfectant	C (mg/L)	Flow (MGD)	Temp (°C)	pH	Giardia Log	Virus Log	Inact. Ratio	Time
1	NA D1								
	FCL D2	3.0	9.400	28.0	7.3				
	CLA D3	4.2	9.400	28.0	7.5				
	D4								
	D5								
2	NA D1								
	FCL D2	3.1	9.000	28.0	7.4				
	CLA D3	3.7	9.000	29.0	7.5				
	D4								
	D5								
3	NA D1								
	FCL D2	3.3	9.000	29.0	7.4				
	CLA D3	3.4	9.000	28.0	7.5				
	D4								
	D5								
4	NA D1								
	FCL D2	3.5	8.600	28.0	7.6				
	CLA D3	3.6	8.600	28.0	7.6				
	D4								
	D5								
5	NA D1								
	FCL D2	2.5	9.000	28.0	7.5				
	CLA D3	2.8	9.000	28.0	7.6				
	D4								
	D5								
6	NA D1								
	FCL D2	2.8	8.600	27.0	7.4				
	CLA D3	3.8	8.600	27.0	7.6				
	D4								
	D5								
7	NA D1								
	FCL D2	3.0	8.800	26.0	7.4				
	CLA D3	3.4	8.800	26.0	7.6				
	D4								
	D5								
8	NA D1								
	FCL D2	3.0	8.200	26.0	7.5				
	CLA D3	3.5	8.200	26.0	7.6				
	D4								
	D5								

PERFORMANCE DATA									
DISINFECTION PROCESS DATA									
Date	Disinfectant	C (mg/L)	Flow (MGD)	Temp (°C)	pH	Giardia Log	Virus Log	Inact. Ratio	Time
9	NA D1								
	FCL D2	2.8	7.900	26.0	7.5				
	CLA D3	4.1	7.900	26.0	7.6				
	D4								
	D5								
10	NA D1								
	FCL D2	2.7	7.800	27.0	7.6				
	CLA D3	3.8	7.800	26.0	7.8				
	D4								
	D5								
11	NA D1								
	FCL D2	3.3	9.600	26.0	7.4				
	CLA D3	3.2	9.600	27.0	7.7				
	D4								
	D5								
12	NA D1								
	FCL D2	2.6	9.500	26.0	7.4				
	CLA D3	3.2	9.500	27.0	7.7				
	D4								
	D5								
13	NA D1								
	FCL D2	2.7	9.500	26.0	7.3				
	CLA D3	3.1	9.500	26.0	7.6				
	D4								
	D5								
14	NA D1								
	FCL D2	2.6	9.500	24.0	7.4				
	CLA D3	3.3	9.500	25.0	7.6				
	D4								
	D5								
15	NA D1								
	FCL D2	2.7	9.800	26.0	7.5				
	CLA D3	3.2	9.800	26.0	7.7				
	D4								
	D5								
16	NA D1								
	FCL D2	2.9	9.800	25.0	7.5				
	CLA D3	3.2	9.800	25.0	7.6				
	D4								
	D5								

NOTE:  ONLY use the "Time" column to show the length of time that the total inactivation ratio was less than 1.00.

SUBMITTED BY: \_\_\_\_\_ Certificate No. and Grade: W00004220 A Date: October 3, 2006

# SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES  
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER (cont.)  
Disinfection Data Page (cont.)

PUBLIC WATER SYSTEM NAME: City of Corsicana  
PWS ID No.: 1750002

PLANT NAME OR NUMBER: Navarro Mills  
Month: September Year: 2006

DISINFECTION PROCESS PARAMETERS							
APPROVED CT STUDY PARAMETERS					PERFORMANCE STANDARDS		
Parameters	Disinfection Zones					Log Inactivations	
	D1	D2	D3	D4	D5	Giardia lamblia Cysts	Virus
Flow Rate (MGD)	20.250	20.250	20.250			0.5	2.0
T <sub>10</sub> (minutes)	109.1	13.0	100.0				

PERFORMANCE DATA									
Date	DISINFECTION PROCESS DATA								
	Disinfectant	C (mg/L)	Flow (MGD)	Temp (°C)	pH	Giardia Log	Virus Log	Inact. Ratio	Time
17	NA D1								
	FCL D2	2.7	9.600	26.0	7.5				
	CLA D3	3.2	9.600	27.0	7.7				
	D4								
	D5								
18	NA D1								
	FCL D2	3.1	9.800	27.0	7.4				
	CLA D3	3.0	9.800	26.0	7.7				
	D4								
	D5								
19	NA D1								
	FCL D2	2.4	9.600	25.0	7.4				
	CLA D3	3.4	9.600	26.0	7.7				
	D4								
	D5								
20	NA D1								
	FCL D2	2.7	9.500	26.0	7.5				
	CLA D3	3.4	9.500	26.0	7.7				
	D4								
	D5								
21	NA D1								
	FCL D2	2.5	4.400	25.0	7.4				
	CLA D3	3.5	4.400	25.0	7.7				
	D4								
	D5								
22	NA D1								
	FCL D2	2.8	9.800	25.0	7.5				
	CLA D3	3.5	9.800	25.0	7.7				
	D4								
	D5								
23	NA D1								
	FCL D2	3.8	9.800	25.0	7.5				
	CLA D3	3.6	9.800	26.0	7.7				
	D4								
	D5								
24	NA D1								
	FCL D2	2.9	9.700	25.0	7.4				
	CLA D3	3.7	9.700	26.0	7.6				
	D4								
	D5								

PERFORMANCE DATA									
Date	DISINFECTION PROCESS DATA								
	Disinfectant	C (mg/L)	Flow (MGD)	Temp (°C)	pH	Giardia Log	Virus Log	Inact. Ratio	Time
25	NA D1								
	FCL D2	2.4	9.600	25.0	7.4				
	CLA D3	3.3	9.600	25.0	7.6				
	D4								
	D5								
26	NA D1								
	FCL D2	3.0	9.500	25.0	7.4				
	CLA D3	3.0	9.500	25.0	7.6				
	D4								
	D5								
27	NA D1								
	FCL D2	2.6	9.700	24.0	7.4				
	CLA D3	3.2	9.700	24.0	7.5				
	D4								
	D5								
28	NA D1								
	FCL D2	2.5	9.800	24.0	7.4				
	CLA D3	3.3	9.800	24.0	7.5				
	D4								
	D5								
29	NA D1								
	FCL D2	2.6	9.500	24.0	7.5				
	CLA D3	3.5	9.500	25.0	7.7				
	D4								
	D5								
30	NA D1								
	FCL D2	2.6	9.800	24.0	7.4				
	CLA D3	3.1	9.800	24.0	7.7				
	D4								
	D5								
31	D1								
	D2								
	D3								
	D4								
	D5								

Max	NA	NA
Min	NA	NA
Avg	NA	NA
SD	NA	NA

NOTE:  ONLY use the "Time" column to show the length of time that the total inactivation ratio was less than 1.00.

SUBMITTED BY: \_\_\_\_\_ Certificate No. \_\_\_\_\_ and Grade: WO0004220 A Date: October 3, 2006