

SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER

Summary Page

PUBLIC WATER SYSTEM NAME: City of Corsicana

PLANT NAME OR NUMBER: Lake Halbert

I certify that I am familiar with the information contained in this report and that, to the best of my knowledge, the information is true, complete, and accurate.

PWS ID No.: 1750002
Report for the Month of: June 2006

Operator's Signature: _____
Certificate No. & Grade: W00012234 A Date: July 5, 2006

TREATMENT PLANT PERFORMANCE			
Total number of turbidity readings:	<u>108</u>	Number of 4-hour periods when plant was off-line:	<u>72</u>
Number of readings above 0.10 NTU:	<u>30</u>	Number of 4-hour periods when plant was on-line but turbidity data was not collected:	<u>0</u>
Number of readings above 0.3 NTU:	<u>0</u>		
Number of readings above 0.5 NTU:	<u>0</u>		
Number of readings above 1.0 NTU:	<u>0</u>		
Maximum allowable turbidity level:	<u>0.3</u>	Number of days with readings above 1.0 NTU:	<u>0</u> (2)
Percentage of readings above this limit:	<u>0.0</u> % (1)	Number of days with readings above 5.0 NTU:	<u>0</u> (3)
Statistical Summary	Maximum turbidity reading: <u>0.16</u> NTU	Average turbidity value:	<u>0.09</u> NTU
	Minimum turbidity reading: <u>0.04</u> NTU	Standard deviation:	<u>0.024</u> NTU
Additional report(s) for individual filter monitoring required:	<input checked="" type="radio"/> NONE	<input type="radio"/> Filter Profile	<input type="radio"/> Filter Assessment
Additional report(s) for individual filter monitoring submitted:	<input checked="" type="radio"/> NONE	<input type="radio"/> Filter Profile	<input type="radio"/> Filter Assessment
		<input type="radio"/> CPE	<input type="radio"/> CPE
		Number of days when plant was on-line but individual filter turbidity data was not collected:	<u>0</u>
Number of days with a low CT for no more than 4.0 consecutive hours:	<u>0</u>	Average log inactivation for Giardia:	<u>NA</u>
Number of days with a low CT for more than 4.0 consecutive hours:	<u>0</u> (4)	Average log inactivation for viruses:	<u>NA</u>
		Number of days when profiling data was not collected:	<u>26</u>
		Number of days when CT data was not collected:	<u>26</u>
Minimum disinfectant residual required leaving the plant:	<u>0.5</u> mg/L	<input type="radio"/> Free Chlorine	<input checked="" type="radio"/> Total Chlorine
Number of days with a low residual for no more than 4.0 consecutive hours:	<u>0</u>		
Number of days with a low residual for more than 4.0 consecutive hours:	<u>0</u> (5)	Number of days when disinfectant residual leaving the plant was not properly monitored:	<u>0</u>

DISTRIBUTION SYSTEM			
Minimum disinfectant residual required in distribution system:	<u>0.5</u> mg/L	<input type="radio"/> Free Chlorine	<input checked="" type="radio"/> Total Chlorine
Total number of readings this month:	<u>55</u>		
Average disinfectant residual value:	<u>2.10</u>	Percentage of readings with a low residual this month:	<u>0.0</u> % (6A)
Number of readings with a low residual:	<u>0</u>		
Number of readings with no detectable residual:	<u>0</u>	Percentage of readings with a low residual last month:	<u>0.0</u> % (6B)

PUBLIC NOTIFICATION			
TREATMENT TECHNIQUE VIOLATIONS	YES/NO	If YES, date when notice was given to:	
		COMMISSION	CUSTOMERS*
Were more than 5.0% of the turbidity readings above the acceptable level? - see (1) above	No		
Were there any days with turbidity readings above 1.0 NTU? - see (2) above	No		
Were there any days with turbidity readings above 5.0 NTU? - see (3) above	No		
Were there any periods when the plant failed to meet the CT requirements for more than 4.0 consecutive hours? - see (4) above	No		
Were there any periods when the residuals leaving the plant fell below the acceptable level for more than 4.0 consecutive hours? - see (5) above	No		
Were more than 5.0% of the residuals in the distribution system below the acceptable level for two months in a row? - see (6A) and (6B) above	No		

*Due by the end of the next business day.
* Copies of each Public Notice must accompany this report.

Submit the report by the 10th of the month following the reporting period to:
TEXAS COMMISSION ON ENVIRONMENTAL QUALITY
WATER SUPPLY DIVISION/PUBLIC DRINKING WATER SECTION (MC-155)
P.O. BOX 13087, AUSTIN, TEXAS 78711-3087

SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER (cont.)

Turbidity Data Page

PUBLIC WATER SYSTEM NAME: City of Corsicana

PLANT NAME OR NUMBER: Lake Halbert

PWS ID No.: 1750002

Connections: 8,734

Month: June Year: 2006

Population: 24,485

PERFORMANCE DATA																			
Date	Raw Water Pumpage (MGD)	Treated Water Pumpage (MGD)	RAW WATER ANALYSES		SETTLED WATER TURBIDITY (Optional Data)						FINISHED WATER QUALITY								
			NTU	Alk.	Basin No.						Turbidity						Lowest Residual	Time	
					1	2	3	4	5	6	NTU1	NTU2	NTU3	NTU4	NTU5	NTU6			
1	2.015	2.010	34	122							0.07	0.06	0.11	0.12	0.12	0.11	3.0		
2	0.000	0.000	X	X	X	X					X	X	X	X	X	X	X	X	
3	1.580	1.578	31	126							0.09	0.07	0.08	0.04	X	X	3.1		
4	0.000	0.000	X	X	X	X					X	X	X	X	X	X	X	X	
5	0.736	0.600	28	128							X	X	X	X	0.07	0.05	2.6		
6	1.991	1.952	37	119							0.05	0.05	0.12	0.10	0.06	0.07	3.3		
7	2.610	2.561	42	123							0.11	0.07	0.05	0.07	0.09	0.09	2.8		
8	2.425	2.224	34	124							0.09	0.06	0.09	0.07	0.07	0.07	2.9		
9	2.760	2.758	44	123							0.11	0.09	0.06	0.06	0.06	0.07	3.2		
10	1.385	1.380	44	123							0.07	X	X	0.07	0.06	0.07	3.0		
11	1.703	1.602	38	128							0.07	X	X	X	0.05	0.06	3.0		
12	3.760	3.759	26	127							0.07	0.06	0.07	0.09	0.08	0.06	2.9		
13	2.275	2.271	37	122							0.06	0.05	0.05	0.06	0.07	0.08	3.0		
14	1.360	1.359	25	119							0.07	0.07	0.10	X	X	X	3.4		
15	1.515	1.512	26	122							X	X	X	0.16	0.14	0.11	3.0		
16	2.346	2.248	23	121							0.11	0.11	0.04	0.12	0.11	0.11	3.2		
17	2.035	2.033	32	121							0.10	0.10	0.07	0.09	0.09	0.09	3.0		
18	0.000	0.000	X	X	X	X					X	X	X	X	X	X	X	X	
19	1.640	1.637	46	120							X	X	X	X	0.11	0.12	2.5		
20	2.875	2.870	33	115							0.10	0.09	0.13	0.10	0.09	0.09	3.1		
21	0.000	0.000	X	X	X	X					X	X	X	X	X	X	X	X	
22	2.428	2.216	40	109							X	X	X	0.12	0.11	0.09	3.2		
23	1.530	1.525	42	108							0.12	0.10	X	X	X	X	3.3		
24	3.325	3.322	39	107							X	X	X	0.13	0.12	0.11	3.1		
25	1.265	1.261	43	108							0.11	0.11	X	X	X	X	3.2		
26	3.360	3.350	64	119							X	X	X	0.13	0.09	0.08	2.5		
27	1.987	1.938	56	117							0.07	0.08	0.07	X	X	X	2.8		
28	3.260	3.206	61	123							X	X	X	0.13	0.09	0.08	2.5		
29	2.582	2.476	61	120							0.09	0.09	0.12	0.11	X	X	3.0		
30	3.225	3.223	53	111							X	X	0.10	0.10	0.10	0.10	3.2		
31																			
Total	57.973	56.871																	
Avg	1.932	1.896																	
Max	3.760	3.759																	
Min	0.000	0.000																	

NOTE: ONLY use the "Time" column to show the length of time that the disinfectant residual entering the distribution system fell below the acceptable level.

SUBMITTED BY: _____ Certificate No. and Grade: W00012234 A Date: July 5, 2006

SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER (cont.)

Filter Data Page

PUBLIC WATER
SYSTEM NAME: City of Corsicana
PWS ID No.: 1750002

PLANT NAME
OR NUMBER: Lake Halbert
Month: June Year: 2006

PERFORMANCE DATA																				
INDIVIDUAL FILTER TURBIDITY																				
Date	Filter No. 1		Filter No. 2		Filter No. 3		Filter No. 4		Filter No. 5		Filter No. 6		Filter No. 7		Filter No. 8		Filter No. 9		Filter No. 10	
	Max	4 Hrs																		
1	0.09	X	0.10	X	0.10	X	0.15	X												
2	X	X	X	X	X	X	X	X												
3	0.03	0.03	0.04	0.04	0.04	0.04	0.05	0.05												
4	X	X	X	X	X	X	X	X												
5	X	X	0.04	0.04	0.06	0.06	X	X												
6	0.07	X	X	X	0.06	X	X	X												
7	0.05	0.05	0.03	0.03	0.09	0.09	0.09	0.08												
8	0.04	X	0.04	X	0.08	X	0.08	X												
9	0.03	X	0.07	0.07	0.06	X	0.05	X												
10	0.03	0.03	0.06	0.05	0.05	0.04	0.05	0.04												
11	0.06	0.06	0.05	0.05	0.05	0.05	0.05	0.05												
12	0.06	X	0.05	X	0.05	X	0.05	X												
13	0.04	X	0.04	X	0.04	X	0.05	X												
14	0.03	X	0.04	X	0.04	X	0.04	X												
15	0.03	0.03	0.04	0.04	0.04	0.04	0.04	0.04												
16	0.03	X	0.04	X	0.07	0.07	0.08	0.07												
17	0.04	X	0.07	0.07	0.08	X	0.06	X												
18	X	X	X	X	X	X	X	X												
19	0.05	0.05	0.06	0.06	0.07	0.07	0.09	0.09												
20	0.04	X	0.05	X	0.06	X	0.08	X												
21	X	X	X	X	X	X	X	X												
22	0.03	0.03	0.04	0.04	0.05	0.05	0.05	0.04												
23	0.03	X	0.04	X	0.05	X	0.05	X												
24	0.03	0.03	0.05	0.05	0.06	0.06	0.07	0.07												
25	0.03	X	0.04	X	0.05	X	0.05	X												
26	0.03	0.03	0.04	0.04	0.05	0.05	0.05	0.05												
27	0.03	X	0.04	X	0.04	X	0.05	X												
28	0.06	0.06	0.07	0.07	0.04	0.04	0.05	0.04												
29	0.06	X	0.06	X	0.04	X	0.06	0.06												
30	0.04	0.04	0.05	0.05	0.08	0.08	0.07	0.07												
31																				

SUMMARY & COMPLIANCE ACTIONS	Criteria		Filter No.										Plant			
	1	2	3	4	5	6	7	8	9	10						
	Number of days with event(s) above 0.5 NTU at 4.0 hrs this month		0	0	0	0										
	Number of days with event(s) above 1.0 NTU this month		0	0	0	0										
	Number of days with event(s) above 1.0 NTU last month		0	0	0	0										
	Number of days with event(s) above 1.0 NTU two months ago		0	0	0	0										
	Total number of days with event(s) above 1.0 NTU in three months		0	0	0	0										
	Number of days with event(s) above 2.0 NTU this month												0			
	Number of days with event(s) above 2.0 NTU last month												0			
	Does the plant have an approved Corrective Action Plan?		N	N	N	N										N
Is the plant required to submit a Filter Profile Report?		N	N	N	N											
Is the plant required to submit a Filter Assessment Report?		N	N	N	N											
Is the plant required to submit a Request for Compliance CPE?												N				

SUBMITTED BY: _____ Certificate No. and Grade: W00012234 A Date: July 5, 2006

SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER (cont.)
Disinfection Data Page

PUBLIC WATER SYSTEM NAME: City of Corsicana
PWS ID No.: 1750002

PLANT NAME OR NUMBER: Lake Halbert
Month: June Year: 2006 PWS IC

DISINFECTION PROCESS PARAMETERS										
APPROVED CT STUDY PARAMETERS					PERFORMANCE STANDARDS					
Parameters	Disinfection Zones					Log Inactivations				Parar
	D1	D2	D3	D4	D5	Giardia lamblia Cysts		Viruses		
Flow Rate (MGD)	4.000					0.5		2.0		Flow
T ₁₀ (minutes)	18.0									T ₁₀ (r)

PERFORMANCE DATA									
DISINFECTION PROCESS DATA									
Date	Disinfectant	C (mg/L)	Flow (MGD)	Temp (°C)	pH	Giardia Log	Virus Log	Inact. Ratio	Time _{in}
1	FCL D1	3.3	2.300	27.0	7.5				
	D2								
	D3								
	D4								
	D5								
2	NA D1								
	D2								
	D3					NA	NA	NA	
	D4								
	D5								
3	FCL D1	3.0	2.300	26.0	7.4				
	D2								
	D3								
	D4								
	D5								
4	NA D1								
	D2								
	D3					NA	NA	NA	
	D4								
	D5								
5	FCL D1	3.0	2.300	25.0	7.4				
	D2								
	D3								
	D4								
	D5								
6	FCL D1	3.8	2.300	26.0	7.1				
	D2								
	D3								
	D4								
	D5								
7	FCL D1	3.6	4.000	28.0	7.3				
	D2								
	D3								
	D4								
	D5								
8	FCL D1	3.3	3.400	27.0	7.4				
	D2								
	D3								
	D4								
	D5								

PERFORMANCE DATA										
DISINFECTION PROCESS DATA										
Date	Disinfectant	C (mg/L)	Flow (MGD)	Temp (°C)	pH	Giardia Log	Virus Log	Inact. Ratio	Time _{in}	Date
9	FCL D1	2.8	3.800	28.0	7.6					17
	D2									
	D3									
	D4									
	D5									
10	FCL D1	2.5	2.500	28.0	7.4					18
	D2									
	D3									
	D4									
	D5									
11	FCL D1	3.0	3.800	29.0	7.4					19
	D2									
	D3									
	D4									
	D5									
12	FCL D1	3.0	4.000	26.0	7.4					20
	D2									
	D3									
	D4									
	D5									
13	FCL D1	3.8	2.500	27.0	7.3					21
	D2									
	D3									
	D4									
	D5									
14	FCL D1	3.6	2.500	29.0	7.6					22
	D2									
	D3									
	D4									
	D5									
15	FCL D1	2.7	2.500	27.0	7.5					23
	D2									
	D3									
	D4									
	D5									
16	FCL D1	3.0	2.900	27.0	7.5					24
	D2									
	D3									
	D4									
	D5									

NOTE: ONLY use the "Time_{in}" column to show the length of time that the total inactivation ratio was less than 1.00.

NOTE:

SUBMITTED BY: _____ Certificate No. _____ and Grade: W00012234 A Date: July 5, 2006 SUBMI

SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER (cont.)
Disinfection Data Page (cont.)

C WATER
 EM NAME: City of Corsicana
 D No.: 1750002

PLANT NAME
 OR NUMBER: Lake Halbert
 Month: June Year: 2006

DISINFECTION PROCESS PARAMETERS									
APPROVED CT STUDY PARAMETERS					PERFORMANCE STANDARDS				
Disinfection Zones					Log Inactivations				
meters	D1	D2	D3	D4	D5	Giardia lamblia Cysts		Virus	
Rate (MGD)	4.000					0.5		2.0	
minutes)	18.0								

PERFORMANCE DATA									
DISINFECTION PROCESS DATA									
Disinfectant	C (mg/L)	Flow (MGD)	Temp (°C)	pH	Giardia Log	Virus Log	Inact. Ratio	Time	
FCL D1	3.1	2.600	26.0	7.4					
D2									
D3									
D4									
D5									
NA D1									
D2									
D3									
D4									
D5									
FCL D1	2.6	4.000	27.0	7.3					
D2									
D3									
D4									
D5									
FCL D1	3.5	4.000	28.0	7.3					
D2									
D3									
D4									
D5									
NA D1									
D2									
D3									
D4									
D5									
FCL D1	3.0	2.500	25.0	7.4					
D2									
D3									
D4									
D5									
FCL D1	3.5	2.500	27.0	7.5					
D2									
D3									
D4									
D5									
FCL D1	4.0	3.800	27.0	7.3					
D2									
D3									
D4									
D5									

PERFORMANCE DATA									
DISINFECTION PROCESS DATA									
Date	Disinfectant	C (mg/L)	Flow (MGD)	Temp (°C)	pH	Giardia Log	Virus Log	Inact. Ratio	Time
25	FCL D1	3.1	3.800	27.0	7.3				
	D2								
	D3								
	D4								
	D5								
26	FCL D1	4.0	3.800	27.0	7.3				
	D2								
	D3								
	D4								
	D5								
27	FCL D1	3.0	2.800	28.0	7.4				
	D2								
	D3								
	D4								
	D5								
28	FCL D1	4.0	3.800	26.0	7.2				
	D2								
	D3								
	D4								
	D5								
29	FCL D1	3.7	3.800	28.0	7.4				
	D2								
	D3								
	D4								
	D5								
30	FCL D1	3.9	3.800	26.0	7.2				
	D2								
	D3								
	D4								
	D5								
31	D1								
	D2								
	D3								
	D4								
	D5								
						Max	NA	NA	
						Min	NA	NA	
						Avg	NA	NA	
						SD	NA	NA	

ONLY use the "Time" column to show the length of time that the total inactivation ratio was less than 1.00.

ISSUED BY: _____ Certificate No. _____ and Grade: W00012234 A Date: July 5, 2006