

SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER (cont.)
Turbidity Data Page

PUBLIC WATER SYSTEM NAME: <u>City of Corsicana</u>	PLANT NAME OR NUMBER: <u>Lake Halbert</u>
PWS ID No.: <u>1750002</u> Plant ID No.: <u>15000</u>	Connections: <u>11,950</u>
Month: <u>March</u> Year: <u>2024</u>	Population: <u>24,190</u>

PERFORMANCE DATA																		
Date	Raw Water Pumpage (MGD)	Treated Water Pumpage (MGD)	RAW WATER ANALYSES		SETTLED WATER TURBIDITY (Optional Data)						FINISHED WATER QUALITY							
			NTU	Alk.	Basin No.						Combined Filter Effluent Turbidity						Lowest Residual	Time=
					1	2	3	4	5	6	NTU1	NTU2	NTU3	NTU4	NTU5	NTU6		
1	1.963	1.790	7	100							0.04	0.04	0.04	0.05	0.04	0.06	3.2	
2	1.192	1.180	7	100							0.07	0.06	0.03	0.05	0.05	0.05	3.1	
3	0.555	0.540	7	108							x	x	x	x	0.08	0.07	2.9	
4	1.222	1.190	8	108							0.05	0.04	0.05	0.04	0.04	0.04	3.1	
5	1.615	1.490	7	104							0.04	0.04	0.04	0.05	0.04	0.05	3.0	
6	1.212	1.020	9	106							0.04	0.04	0.04	0.04	0.07	0.04	3.2	
7	1.215	1.200	9	106							0.04	0.03	0.04	0.04	0.04	0.05	3.3	
8	1.224	1.170	10	106							0.04	0.04	0.04	0.07	0.05	0.03	3.2	
9	1.138	1.040	8	104							0.04	0.04	0.04	0.04	0.05	0.04	3.2	
10	0.713	0.700	8	106							x	x	x	0.05	0.05	0.05	2.7	
11	0.782	0.760	9	106							0.05	0.04	x	x	0.05	0.04	3.0	
12	1.210	1.220	7	104							0.04	0.06	0.04	0.04	0.04	0.04	3.0	
13	1.199	0.960	7	102							0.04	0.05	0.04	0.04	0.04	0.04	3.1	
14	1.200	0.920	8	104							0.05	0.04	0.05	0.05	0.05	0.04	3.2	
15	1.216	1.190	9	106							0.05	0.05	0.04	0.04	0.04	0.04	3.3	
16	1.091	1.020	8	106							0.04	0.04	0.07	0.03	0.04	0.03	3.2	
17	0.516	0.450	8	112							x	x	x	x	0.06	0.06	2.9	
18	1.215	1.170	9	110							0.07	0.06	0.05	0.06	0.06	0.06	3.2	
19	1.215	1.090	8	102							0.05	0.04	0.04	0.03	0.03	0.05	3.2	
20	1.225	1.150	9	106							0.04	0.05	0.05	0.05	0.03	0.03	3.3	
21	1.093	1.060	9	106							0.04	0.04	0.04	0.04	0.06	0.05	3.2	
22	0.719	0.690	10	98							x	x	x	0.04	0.09	0.06	3.1	
23	1.094	1.070	8	102							0.05	0.04	0.04	0.03	0.07	0.04	3.2	
24	0.607	0.520	9	108							x	x	x	x	0.08	0.05	2.9	
25	1.210	1.190	9	106							0.05	0.05	0.04	0.04	0.08	0.06	2.9	
26	1.213	1.170	8	108							0.04	0.04	0.04	0.04	0.05	0.05	3.1	
27	1.226	1.090	9	106							0.04	0.04	0.04	0.04	0.05	0.04	3.2	
28	1.755	1.530	9	108							0.04	0.05	0.04	0.05	0.06	0.08	2.8	
29	1.736	1.570	10	106							0.05	0.05	0.05	0.05	0.03	0.04	3.2	
30	1.091	1.060	8	106							0.04	0.04	0.05	0.05	0.07	0.06	3.0	
31	0.516	0.520	10	106							x	x	x	x	0.06	0.05	3.0	
Total	35.178	32.720			Max	ND	ND				NOTE: ONLY use the "Time" column to show the length of time that the disinfectant residual entering the distribution system fell below the acceptable level.							
Avg	1.135	1.055			Avg	ND	ND											
Max	1.963	1.790			95th %	ND	ND											
Min	0.516	0.450			Min	ND	ND											
95th percentile based on data from all basins										ND								

SUBMITTED BY: _____ Certificate No. and Grade: WO0029648, A Date: April 5, 2024