

# SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES  
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER (cont.)  
*Turbidity Data Page*

<b>PUBLIC WATER SYSTEM NAME:</b> <u>City of Corsicana</u>	<b>PLANT NAME OR NUMBER:</b> <u>Lake Halbert</u>
<b>PWS ID No.:</b> <u>1750002</u> <b>Plant ID No.:</b> <u>15000</u>	<b>Connections:</b> <u>11,950</u>
<b>Month:</b> <u>July</u> <b>Year:</b> <u>2024</u>	<b>Population:</b> <u>24,190</u>

PERFORMANCE DATA																			
Date	Raw Water Pumpage (MG)	Treated Water Pumpage (MG)	RAW WATER ANALYSES		SETTLED WATER TURBIDITY (Optional Data)						FINISHED WATER QUALITY								
			NTU	Alk.	Basin No.						Combined Filter Effluent Turbidity						Lowest		
					1	2	3	4	5	6	NTU1	NTU2	NTU3	NTU4	NTU5	NTU6	Residual	Time=	
1	3.215	3.050	3	94								0.04	0.03	0.04	0.05	0.06	0.05	3.1	
2	3.215	2.740	3	98								0.04	0.05	0.04	0.05	0.07	0.06	3.3	
3	2.430	2.340	2	90								0.05	0.05	0.04	0.04	0.07	0.07	3.0	
4	2.010	1.890	3	98								0.04	0.07	0.04	0.04	0.03	0.05	3.3	
5	2.795	2.460	2	100								0.04	0.03	0.04	0.03	0.03	0.03	3.2	
6	3.209	2.690	3	106								0.07	0.07	0.03	0.03	0.07	0.05	2.9	
7	3.215	2.970	2	96								0.05	0.04	0.03	0.03	0.04	0.04	3.2	
8	2.695	2.390	3	100								0.06	0.03	0.05	0.05	0.04	0.05	3.1	
9	1.947	1.650	3	96								0.04	0.05	0.05	0.05	0.04	0.05	3.1	
10	1.615	1.510	2	98								0.04	0.06	0.04	0.05	0.04	0.06	3.2	
11	1.615	1.520	2	96								0.05	0.04	0.04	0.04	0.04	0.08	2.7	
12	2.580	2.170	2	94								0.04	0.07	0.03	0.05	0.06	0.08	3.2	
13	3.208	2.860	2	94								0.04	0.06	0.04	0.04	0.05	0.04	3.3	
14	2.607	2.380	2	90								0.05	0.05	0.06	0.06	0.06	0.04	3.2	
15	1.616	1.500	2	94								0.04	0.04	0.04	0.03	0.03	0.05	3.2	
16	2.208	1.970	2	92								0.03	0.03	0.03	0.03	0.04	0.05	3.1	
17	2.670	2.400	3	90								0.04	0.05	0.05	0.04	0.05	0.07	3.2	
18	2.105	1.820	2	92								0.04	0.03	0.03	0.03	0.06	0.05	3.2	
19	2.311	2.080	2	94								0.04	0.04	0.04	0.04	0.02	0.03	3.1	
20	2.544	2.340	1	92								0.03	0.07	0.05	0.06	0.05	0.05	3.2	
21	2.805	2.460	2	90								0.05	0.06	0.04	0.05	0.06	0.04	3.2	
22	2.006	1.920	3	90								0.05	0.05	0.05	0.04	0.07	0.05	3.0	
23	1.600	1.480	2	92								0.06	0.05	0.03	0.04	0.04	0.04	3.2	
24	1.615	1.400	2	90								0.05	0.07	0.04	0.05	0.07	0.04	3.2	
25	2.404	2.030	2	92								0.05	0.06	0.05	0.05	0.05	0.06	3.1	
26	2.167	2.050	4	90								0.07	0.05	0.05	0.03	0.04	0.06	3.0	
27	1.616	1.470	2	90								0.05	0.03	0.03	0.04	0.03	0.03	3.2	
28	2.123	1.920	2	90								0.04	0.04	0.04	0.04	0.04	0.03	3.2	
29	1.795	1.590	4	94								0.06	0.04	0.03	0.04	0.04	0.04	3.0	
30	1.435	1.260	2	92								0.06	0.04	0.04	0.04	0.04	0.04	3.2	
31	2.397	2.150	2	92								0.06	0.05	0.04	0.04	0.05	0.05	3.0	
<b>Total</b>	71.773	64.460			<b>Max</b>	ND	ND					NOTE: ONLY use the "Time=" column to show the length of time that the disinfectant residual entering the distribution system fell below the acceptable level.							
<b>Avg</b>	2.315	2.079			<b>Avg</b>	ND	ND												
<b>Max</b>	3.215	3.050			<b>95th %</b>	ND	ND												
<b>Min</b>	1.435	1.260			<b>Min</b>	ND	ND												
<b>95th percentile based on data from all basins</b>											ND								

SUBMITTED BY: \_\_\_\_\_ Certificate No. and Grade: WO0029648, A Date: August 2, 2024