

SURFACE WATER MONTHLY OPERATING REPORT


FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER (cont.)
Turbidity Data Page

PUBLIC WATER SYSTEM NAME: City of Corsicana PLANT NAME OR NUMBER: Navarro Mills

PWS ID No.: 1750002 Plant ID No.: 15001 Connections: 11,950

Month: November Year: 2025 Population: 25,885

PERFORMANCE DATA																			
Date	Raw Water Pumpage (MG)	Treated Water Pumpage (MG)	RAW WATER ANALYSES		SETTLED WATER TURBIDITY (Mandatory Data)						FINISHED WATER QUALITY								
			NTU	Alk.	Basin No.						Combined Filter Effluent Turbidity						Lowest Residual	Time ^h	
					1	2	3	4	5	6	NTU1	NTU2	NTU3	NTU4	NTU5	NTU6			
1	7.050	5.864	45	99	1.0	2.2	1.1	0.9	1.5	1.1	0.06	0.05	0.06	0.07	0.05	0.05	3.3		
2	6.970	6.581	36	94	1.2	1.1	1.4	0.9	1.5	2.8	0.05	0.05	0.06	0.07	0.05	0.05	3.4		
3	7.070	6.542	34	94	1.3	1.5	1.2	1.4	1.9	1.2	0.04	0.04	0.06	0.06	0.07	0.07	3.4		
4	7.050	6.015	41	95	1.5	1.8	1.6	1.7	2.2	1.8	0.06	0.06	0.06	0.06	0.07	0.06	3.4		
5	8.460	6.404	31	93	1.9	1.4	0.9	0.9	1.5	1.3	0.06	0.06	0.07	0.08	0.06	0.07	3.3		
6	8.560	6.949	30	100	0.7	0.8	1.2	0.8	X	0.9	0.07	0.06	0.08	0.06	0.07	0.09	3.3		
7	7.690	6.663	27	95	1.2	1.1	1.3	1.2	1.2	X	0.08	0.07	0.07	0.06	0.06	0.07	3.1		
8	7.080	6.224	23	98	0.8	1.0	0.8	0.7	1.5	0.9	0.06	0.07	0.05	0.06	0.07	0.06	3.0		
9	7.160	6.113	30	100	1.1	1.2	1.1	1.0	1.3	1.1	0.06	0.05	0.07	0.08	0.06	0.06	3.0		
10	7.190	6.886	33	98	1.1	1.2	1.4	1.0	1.6	1.2	0.05	0.04	0.07	0.06	0.06	0.07	3.1		
11	7.240	5.593	26	98	1.7	2.2	1.6	1.6	1.3	1.5	0.07	0.06	0.06	0.07	0.06	0.07	3.1		
12	7.200	6.811	27	97	1.8	2.0	1.3	1.3	1.6	1.2	0.07	0.06	0.07	0.07	0.07	0.07	3.2		
13	7.360	6.646	36	101	1.1	1.3	1.3	0.8	1.3	1.4	0.07	0.07	0.07	0.07	0.09	0.10	3.1		
14	7.850	6.624	34	98	1.2	1.6	1.5	1.3	1.7	1.2	0.07	0.06	0.06	0.07	0.07	0.07	3.2		
15	8.040	6.249	29	100	1.0	1.3	1.2	0.9	1.4	1.2	0.05	0.05	0.06	0.06	0.05	0.05	3.2		
16	8.410	7.461	24	100	1.3	1.4	1.1	1.2	1.4	1.2	0.05	0.05	0.06	0.06	0.05	0.04	3.2		
17	8.570	6.805	25	100	1.6	1.4	3.0	1.1	2.7	1.1	0.04	0.04	0.10	0.08	0.06	0.05	3.1		
18	7.940	6.352	26	101	1.4	1.3	1.1	1.2	1.6	1.1	0.05	0.07	0.08	0.10	0.09	0.09	3.1		
19	6.340	7.202	23	96	1.4	2.1	1.4	1.4	2.3	1.4	0.07	0.07	0.09	0.09	0.08	0.08	2.9		
20	5.570	5.233	17	101	0.8	0.9	0.8	0.8	1.0	0.8	0.08	0.07	0.10	0.09	0.10	0.08	2.8		
21	5.850	5.985	21	116	1.3	1.5	1.1	2.0	1.2	2.0	0.10	0.09	0.12	0.11	0.10	0.08	2.8		
22	6.520	5.337	16	101	0.8	1.0	0.9	0.8	1.3	1.0	0.05	0.05	0.05	0.08	0.05	0.04	3.2		
23	7.470	6.835	28	100	1.0	1.4	1.1	0.8	1.2	0.9	0.05	0.05	0.08	0.07	0.05	0.05	3.2		
24	6.620	6.324	29	105	1.4	1.4	1.6	1.1	1.7	1.3	0.04	0.05	0.09	0.08	0.06	0.05	3.0		
25	5.910	5.839	30	105	1.7	1.5	1.1	0.9	1.5	1.2	0.05	0.05	0.07	0.05	0.07	0.08	3.1		
26	6.590	5.575	27	102	1.6	1.3	1.1	0.8	1.2	1.2	0.05	0.05	0.09	0.08	0.06	0.07	3.1		
27	7.370	5.639	25	96	1.5	1.3	1.3	0.8	1.0	1.1	0.08	0.08	0.06	0.07	0.07	0.06	3.5		
28	7.470	6.189	33	100	1.0	0.9	1.2	0.8	0.8	0.9	0.08	0.06	0.05	0.05	0.07	0.07	3.3		
29	6.990	5.579	31	96	1.0	1.0	0.9	0.8	1.7	1.2	0.05	0.05	0.05	0.04	0.05	0.05	3.4		
30	5.830	5.715	28	97	0.6	0.7	0.7	0.6	0.7	0.6	0.05	0.04	0.07	0.08	0.05	0.04	3.2		
31																			
Total	215.420	188.234			Max	1.9	2.2	3.0	2.0	2.7	2.8	NOTE: ONLY use the "Time ^h " column to show the length of time that the disinfectant residual entering the distribution system fell below the acceptable level.							
Avg	7.181	6.274			Avg	1.2	1.4	1.2	1.1	1.5	1.2								
Max	8.570	7.461			95th %	1.8	2.2	1.6	1.7	2.3	1.9								
Min	5.570	5.233			Min	0.6	0.7	0.7	0.6	0.7	0.6								
95th percentile based on data from all basins											2								

SUBMITTED BY:  Certificate No. and Grade: W00024634, A Date: December 4, 2025